MILITARY SPECIFICATION

REACTOR: 10525925

This amendment forms a part of Military Specification MIL-R-60191(MU), dated 23 February 1965.

Paragraph 1.1: Delete "TF5RX0422" and substitute "TF5RX94ZZ".

Paragraph 3.1: Delete "TF5RX0422" and substitute "TF5RX94ZZ".

Paragraph 3.3.4.1: Delete "135°F." and substitute "135°F, except that it shall meet the requirements of 3.4.3 after being thoroughly dried."

* Paragraph 3.4.2: Delete in its entirety and substitute:

"3.4.2 DC resistance.- The dc resistance shall be as follows:

Room Temp	+135°F	-40°F
0.60ohms max - 0.40 ohms min	0.675 ohms max	0.298 ohms min"

* Following paragraph 4.1.1, add paragraphs 4.1.2., 4.1.2.1 and 4.1.2.2.

"4.1.2 First article (initial production) approval.- The requirement for first article approval and the responsibility (Government or contractor) for first article testing shall be as specified in the contract. The sample for first article approval tests shall consist of three (3) reactors manufactured in the same manner using the same materials, equipment, processes, and procedures as used in regular production. All parts and materials, including packaging and packing, shall be obtained from the same source of supply as used in regular production.

4.1.2.1 Government testing.- When the Government is responsible for conducting first article approval tests, the contractor, prior to submitting the sample to the Government, shall inspect the sample to insure that it conforms to all the requirements of the contract and submit a record of this inspection with the sample, including certificates of conformance for materials.

4.1.2.2 Contractor testing.- When the contractor is responsible for conducting first article approval tests, the sample shall be inspected by the contractor for all the requirements of the contract. The sample and a record of this inspection, including certificates of conformance for materials, shall be submitted to the Government for approval. The Government reserves the right to witness the contractor's inspection."

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T00:15Z
Check the source to verify that this is the current version before use.

* Paragraph 4.2.3: Add the following sentence: "No lots shall be accepted until control samples have been satisfactorily tested."

* Paragraph 4.3.2: Delete first sentence and substitute:

"The units shall be selected at random by a Government representative as control samples from each three (3) months production or portion thereof as follows:

3 units per first 100 produced
5 units per 200
7 units per 300
9 units per 400
10 units per 500
12 units per 700
15 units per 1000
and 2 units for each 100 items produced in excess of 1000."

Paragraph 4.5.1.3.2: Delete "95 ± 5 percent" and substitute "92 to 97 percent"; delete "specified requirements of 3.3.4.1" and substitute "requirements of 3.3.4.1, except the unit shall be tested as specified in 4.5.2.3 after being thoroughly dried".

Paragraph 4.5.1.5, line 1: Delete "Fungus" and substitute "Fungus resistance".

Custodian:

Army - MU

Preparing activity

Army - MU

Project No. 1220 - A120

Source: https://assist.dla.mil - Downloaded: 2026-10-23T00:15Z
Check the source to verify that this is the current version before use.