INCH-POUND
MIL-PRF-15160/15C
12 October 1999
SUPERSEDING
MIL-PRF-15160/15B
29 October 1990

PERFORMANCE SPECIFICATION SHEET

FUSES, INSTRUMENT, POWER, AND TELEPHONE (NONINDICATING), STYLE F15

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification and MIL-PRF-15160.



ALTERNATE FERRULE CONSTRUCTION
FOR CHARACTERISTIC B ONLY

Inches	mm
0.008	.20
0.031	.78
0.50	12.7
0.562	14.27
2.00	50.8

NOTES:
1. Dimensions are in inches.
2. Metric equivalents are given for general information only.

FIGURE 1. Style F15, characteristics A and B.

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:42Z
Check the source to verify that this is the current version before use.



DETAIL OF REJECTION GROOVE

Inches	mm	Inches	mm
0.008	0.20	0.150	3.81
0.016	0.40	0.156	3.96
0.031	0.79	0.50	12.7
0.070	1.78	0.562	14.27
0.085	2.16	2.00	50.8
0.115	2.92		

NOTES:
1. Dimensions are in inches.
2. The diameter of the rejection ferrule shall be within zero and minus 0.050 inch of the diameter of the main contact area.
3. The end of the ferrule shall be flat with not greater than 0.015 inch concavity.

FIGURE 2. Style F15, characteristic BR.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:42Z
Check the source to verify that this is the current version before use.

REQUIREMENTS:

Interface and physical dimensions: See figures 1 and 2.

Case: Fiber or alternate material.
(Alternate to fiber material (tube) shall have an average burst strength of 2,100 pounds per square inch with a value of not less than 1,450 pounds per square inch).

Ferrule: Brass.

Finish: Nickel, bright alloy, or bright dipped, silver plated when specified.

Terminal strength: Method 211 of MIL-STD-202, test condition E, 5 inch-pound torque between ferrules and fuse body.

Electrical:

Electrical requirements shall be as specified in table I.

Shock: MIL-STD-202, method 207, HI shock.

Vibration: MIL-STD-202, method 204, test condition A (except 5g peak).

TABLE I Electrical requirements.

	Characteristic		
	A	B	BR
Voltage rating	250 V ac 250 V dc 450 V rms ac	250 V ac 250 V dc N/A	250 V ac 250 V dc N/A
Overload test 1/			
135%	0 – 1 hour	0 – 1 hour	0 – 1 hour
500%	N/A	10 – 25 seconds	10 – 25 seconds
Short circuit test			
at 250 V dc	10,000A	10,000A	10,000A
at 250 V ac	N/A	N/A	200,000A (20% PF max.)
at 450 V rms ac 2/	(50% PF max.) 3/		
0 – 20A fuse	8,000A	N/A	N/A
25 – 30A fuse	1,500A	N/A	N/A

1/ Overload is shown as a percentage of the current rating of the fuse.
2/ Characteristic A fuses may be used for 450 V rms ac.
3/ Power factor (PF).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:42Z
Check the source to verify that this is the current version before use.

Type designation: Type designation shall be as specified in table II.

TABLE II Type designations and electrical rating. 1/

Style	Characteristic	Maximum voltage	Current rating 4/
F15	A	250V	1A
F15	A	250V	3A
F15	A	250V	6A
F15	A	250V	10A
F15	A	250V	15A
F15	A	250V	20A
F15	A	250V	25A
F15	A	250V	30A
F15	B 2/, 3/	250V	1A
F15	B	250V	1 6/10A
F15	B	250V	2A
F15	B	250V	2 1/2A
F15	B	250V	3 2/10A
F15	B	250V	4A
F15	B	250V	5A
F15	B	250V	6 1/4A
F15	B	250V	8A
F15	B	250V	10A
F15	B	250V	12A
F15	B	250V	15A
F15	B	250V	20A
F15	B	250V	25A
F15	B	250V	30A
F15	BR 4/	250V	1A
F15	BR 4/	250V	1 6/10A
F15	BR 4/	250V	2A
F15	BR 4/	250V	2 1/2A
F15	BR 4/	250V	3 2/10A
F15	BR 4/	250V	4A
F15	BR 4/	250V	5A
F15	BR 4/	250V	6 1/4A
F15	BR 4/	250V	8A
F15	BR 4/	250V	10A
F15	BR 4/	250V	12A
F15	BR 4/	250V	20A
F15	BR 4/	250V	25A
F15	BR	250V	30A

1/ For silver plated terminals, the designator “S” is added after the current rating.
2/ The characteristic B fuse is cancelled upon the issue of this document and establishment of a QPL for the type BR fuse.
3/ A characteristic B fuse shall not be used to replace characteristic BR fuse.
4/ The characteristic BR fuse may be used to replace the characteristic B fuse of the same current rating.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:42Z
Check the source to verify that this is the current version before use.

VERIFICATION:

Qualification inspections: The number of qualification samples required shall be:

a. 24 samples maximum current rating of each voltage and design.
b. 24 samples minimum current rating of each voltage and design.

NOTE: If labels are used, five additional samples of any rating are required.

Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extent of the changes.

Custodians:
Army - CR
Navy - SH
Air Force - 11
DLA - CC

Review activities:
Army - AR, AT, CR4, MI
Navy - AS, CG, MC, OS, YD2
Air Force - 19, 99

Preparing activity:
DLA - CC

(Project 5920-0607-06)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:42Z
Check the source to verify that this is the current version before use.