INCH-POUND
MIL-PRF-15160/19F
w/Amendment 2
01 March 2022
SUPERSEDING
MIL-PRF-15160/19F
w/Amendment 1
21 March 2017

PERFORMANCE SPECIFICATION SHEET

FUSES, INSTRUMENT, POWER, AND TELEPHONE (NONINDICATING), STYLE F19

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and MIL-PRF-15160.




FIGURE 1. Style F19, characteristic BR.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:43Z
Check the source to verify that this is the current version before use.

Ltr	Inches	Inches	mm	mm		Ltr	Inches	Inches	mm	mm
	Min	Max	Min	Max			Min	Max	Min	Max
A	5.813	5.937	147.65	150.80		G	.122	.128	3.10	3.25
B	1.031	1.093	26.19	27.76		H	.219	.281	5.56	7.14
C	1.000	---	25.40	---		J	.276	.306	7.01	7.77
D	1.031	---	26.19	---		K	---	.125	---	3.18
E	.715	.785	18.16	19.94		L	.492	.508	12.50	12.90
F	---	1.312	---	33.32						

NOTES:
1. Dimensions are in inches.
2. Metric equivalents are given for general information only.

FIGURE 1. Style F19, characteristic BR - Continued.

REQUIREMENTS:

Interface and physical dimensions: See figure 1.

Case: Fiber or alternate material.
(Alternate to fiber material (tube) shall have an average burst strength of 1,900 pounds per square inch with a value of not less than 1,400 pounds per square inch).

Knifeblade: Copper.

Finish: Nickel, bright alloy, or bright dipped, silver plated when specified.

Terminal strength: MIL-STD-202-211, test condition E, 5 inch-pound torque between ferrules and fuse body.

Electrical:

Electrical requirements shall be as specified in table I.

Shock: MIL-STD-202-207, HI shock.

Vibration: MIL-STD-202-204, test condition A (except 5g peak).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:43Z
Check the source to verify that this is the current version before use.

TABLE I Electrical requirements.

Characteristics	BR
Voltage rating	250 V ac 250 V dc
Overload test 1/ 135% 500%	 0 – 2 hour 10 – 25 seconds
Short circuit test at 250 V dc at 250 V ac	 10,000A 200,000A (20% PF max.) 2/

1/ Overload is shown as a percentage of the current rating of the fuse.
2/ Power factor (PF).

Part or Identifying Number (PIN): The PIN shall be constructed from table II (e.g., F19BR250V80A).

TABLE II Part or Identifying Number. 1/ 2/

Style	Characteristic	Maximum voltage	Current rating
F19	BR 3/	250V	70A
F19	BR 3/	250V	80A
F19	BR 3/	250V	90A
F19	BR 3/	250V	100A

1/ For silver plated terminals, the designator “S” is added after the current rating.
2/ The characteristic A fuse has been discontinued without replacement.
3/ The characteristic B fuse has been discontinued. The characteristic BR fuse may be used to replace the old characteristic B fuse of the same current rating.

VERIFICATION:

Qualification inspections: Not applicable for this specification sheet.

Conformance inspection: Group A and Group B inspections of MIL-PRF-15160 shall be applicable.

a. 24 samples maximum current rating of each voltage and design.
b. 24 samples minimum current rating of each voltage and design.

NOTE: If labels are used, five additional samples of any rating are required.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:43Z
Check the source to verify that this is the current version before use.

Referenced documents. In addition to MIL-PRF-15160, this document references the following:

Referenced documents:
MIL-STD-202-204
MIL-STD-202-207
MIL-STD-202-211

Amendment notations. The margins of this specification are marked with vertical lines to indicate modifications generated by this amendment. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations.

Custodians:
Army - CR
Navy - SH
Air Force - 85
DLA - CC

Preparing activity:
DLA - CC

(Project 5920-2022-001)

Review activities:
Army - AT, CR4, MI
Navy - AS, CG, MC, OS
Air Force - 19

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the Assist Online database at https://assist.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:43Z
Check the source to verify that this is the current version before use.