
COMMERCIAL ITEM DESCRIPTION

FUSEHOLDER, EXTRACTOR POST

The General Services Administration has authorized the use of this commercial item description (CID).

Abstract. This CID covers the general requirements for an extractor post fuseholder. Fuseholders covered by this CID are intended for commercial/industrial applications.

Part or Identifying Number (PIN). The PIN for the CID shall be as shown in the following example:



Salient characteristics.

Design and construction. Fuseholders supplied to this CID shall be as specified herein (see figure 1).

Ampere rating. The ampere rating shall be as specified in table I.

Voltage rating. The voltage rating shall be 32 V dc.


Marking. Fuseholders supplied to this CID shall be marked with the manufacturer's standard commercial PIN.

Fuseholder configuration. A-A-55499-001 and A-A-55499-003 include lead wire contacts and a wire loop. A-A-55499-002 and A-A-55499-004 include lead wire contacts only.

Regulatory requirements. This section is not applicable to this CID.

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:49Z
Check the source to verify that this is the current version before use.



mm	Inches
10.16	.400
19.05	.750
24.00	.945
25.00	.984
36.40	1.433
37.50	1.476

NOTES:
1. Dimensions are in millimeters.
2. Tolerance is ±0.25 millimeter (.010 inch).
3. The US government preferred system of measurement is the metric SI system. However, this item was originally designed using inch-pound units of measurement. In the event of conflict between the metric and inch-pound units, the inch-pound units shall take precedence.

Figure 1. Configuration and dimensions.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:49Z
Check the source to verify that this is the current version before use.

TABLE I. Electrical characteristics.

CID PIN A-A-55499-	Ampere rating	Wire loop size		Wire contact size (AWG)	Fuse accommodation (CID PIN)
		Length millimeters (inches)	gauge (AWG)		
001	20 amperes maximum	203.2 (8)	14	N/A	A-A-55423-001 through A-A-55423-007
002	20 amperes maximum	N/A	N/A	14	A-A-55423-001 through A-A-55423-007
003	30 amperes maximum	203.2 (8)	10	N/A	A-A-55423-008 and A-A-55423-009
004	30 amperes maximum	N/A	N/A	10	A-A-55423-008 and A-A-55423-009

Quality assurance provisions.

Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection, examination, and test requirements specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections, examinations, or tests set forth in this description where such inspections, examinations, and tests are deemed necessary to assure supplies and services conform to prescribed requirements.

Contractor certification statement. The contractor shall certify and maintain objective quality evidence that the product offered meets the requirements of this CID, and that the product conforms to the producer's own drawings, specifications, standards, quality assurances practices, and is the same as the product provided as a bid sample. The Government reserves the right to require proof of such conformance prior to the first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Certificate of compliance. A certificate of compliance shall accompany all fuseholder extractor posts supplied to this CID. The letter of certification shall state that the fuseholder extractor post meets all the requirements of this CID.

Packaging.

Preservation, packaging, packing, labeling, and marking. Preservation, packaging, packing, labeling, and marking shall be as specified in the contract or purchase order.

Notes. This section contains relevant information which is useful to buyers, users, and suppliers in the process of acquiring the item, but is not mandatory.

Ordering data. The contract or purchase order shall specify the following:

a. CID document number and revision and CID PIN.

b. Quality assurance provisions.

c. Packaging requirements.

Comments. Comments on this CID should be directed to Defense Electronics Supply Center, ATTN: DESC-ELDM, 1507 Wilmington Pike, Dayton, OH 45444-5765, or telephone (513) 296-6189, or facsimile (FAX) (513) 296-8868.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:49Z
Check the source to verify that this is the current version before use.

Suggested sources of supply. Suggested sources of supply are listed herein. Additional sources will be added as they become available.

CID dash number (see table I) A-A-55499-	Vendor commercial PIN CAGE 75915
001	155300
002	155320U
003	155400
004	155430U

Vendor CAGE number	Vendor name and address
75915	Littelfuse, Incorporated 800 E. Northwest Highway Des Plaines, IL 60016-3096 (312) 824-1188

CIVIL AGENCY COORDINATING ACTIVITY:

GSA - 7FXE

PREPARING ACTIVITY:

DLA-ES

Project 5920-D223

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:49Z
Check the source to verify that this is the current version before use.