O-C-230
AMENDMENT-4
September 12, 1961

SUPERSEDING
Interim Amendment-3
February 25, 1960

FEDERAL SPECIFICATION

CHARGE, FIRE EXTINGUISHER, FOAM

This amendment, which forms a part of Federal Specification O-C-230, dated May 6, 1955, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Page 3, paragraph 3.3.1, last sentence: Delete and substitute: "Percentage of aluminum sulphate passing through the screen mesh shall be as follows:

Screen analysis of aluminum sulphate

Mesh size	Percentage passing through screen		
	Type I	Type III	Type VII
16	100	100	100
60	35 max.	70-85	35 max.
100	20 max.	40-45	20 max.

Page 4, paragraph 3.5.2, third line: Delete "four minutes" and substitute "eight minutes". Delete last sentence in paragraph.

Page 4, paragraph 3.5.3.3: Delete last sentence and substitute: "The foam shall be of sufficient depth to furnish complete coverage to the remaining fuel and shall prevent re-ignition when a lighted torch is passed over the foam surface after one minute."

Page 4, paragraph 3.6.1.1: Items "A" and "B": Delete in their entirety and substitute the following:

A—COMPONENT (FOR INNER CHAMBER)

Instructions for Use

(1) Wash inner chamber thoroughly.

(2) Using separate container, dissolve contents of this package in not more than 2¼ pints of water at approximately 150°F. If hot water is not available, cold water may be used.

(3) Stir until completely dissolved and pour solution into inner chamber to filler mark.

(4) Replace stopple on inner chamber.

B—COMPONENT (FOR OUTER CHAMBER)

Instructions for Use

(1) Wash outer chamber thoroughly.

(2) Run water through hose to make sure hose is unobstructed.

(3) Using separate container, dissolve contents of this package in not more than 1¾ U. S. gallons of water at approximately 100°F. (never to exceed 110°F.). If warm water is not available cold water may be used.

(4) Pour solution into outer chamber to filler mark.

(5) Place inner chamber in extinguisher.

(6) Screw cap on tight.

(7) Record date on tag attached to extinguisher.

Page 5, paragraph 3.6.1.2: Items "A" and "B": Delete in their entirety and substitute the following:

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:12Z
Check the source to verify that this is the current version before use.

A—COMPONENT (FOR INNER CHAMBER)

Instructions for Use

(1) Wash inner chamber thoroughly.

(2) Using separate container, dissolve contents of this package in not more than 5¼ U. S. gallons of water at approximately 150°F. If hot water is not available cold water may be used.

(3) Stir until complete dissolved.

(4) After filling outer chamber and inserting inner chamber into extinguisher, pour solution into inner chamber to filler mark.

(5) Screw cap on tight.

(6) Close valve on cap.

(7) Record date on tag attached to extinguisher.

B—COMPONENT (FOR OUTER CHAMBER)

Instructions for Use

(1) Wash outer chamber thoroughly.

(2) Run water through hose to make sure hose is unobstructed.

(3) Using separate container, dissolve contents of this package in not more than 29 U. S. gallons of water at approximately 100°F. (never to exceed 110°F.). If warm water is not available cold water may be used.

(4) Pour solution into outer chamber to filler mark.

(5) Place inner chamber in extinguisher.

(6) Screw cap on tight.

(7) Record date on tag attached to extinguisher.

Page 7, paragraph 4.3.2: Delete and substitute:

4.3.2 *Test conditions.*—Tests shall be performed with the test apparatus stabilized at a temperature of plus 70°F. plus or minus 3°F. with an ambient temperature between plus 40°F. and plus 80°F. The tests shall be performed in an area virtually free from drafts.

Page 8, paragraph 4.3.3.2, fourth line: Delete "83 octane motor fuel" and substitute "standard commercial motor gasoline".

Page 8, paragraph 4.3.5.1.3: Delete and substitute:

4.3.5.1.3 *Type III.*—The foam generator conforming to Military Specification MIL–G–636, type I, shall be used and shall be charged as specified in 3.6.3 with plain water as the solvent. The generator shall be completely discharged into a container of sufficient size to hold and calibrate the total discharge volume of the extinguisher. Water shall be supplied to the generator at 50 p.s.i.g. The foam shall be discharged through 100 feet of standard 2½-inch fire hose and a nozzle having a 1¾-inch tip.

Page 9, paragraph 5.1.1.1.1, third sentence: Delete and substitute: "A silicon release agent may be used as a lubricant, provided it does not come in contact with the inner surfaces of the bag and does not interfere with complete sealing."

Page 10, paragraph 5.1.1.2: At end of first sentence add: "; or in polyethelene bags commercially used by the manufacturer for shipment of these components. Marking for identification shall be as specified in 3.6."

Page 10, paragraph 5.1.1.3: At end of first sentence add: "of metal thickness not less than 0.022 inch. Weight of charge shall be not less than 50 pounds."

Page 10, paragraph 5.1.1.4: Delete and substitute:

5.1.1.4 *Type VII charges.*—The A and B components shall be packaged separately in containers in quantity required for each charge. The containers shall be as specified for type III charges. Minimum total net weight components A and B as packaged shall be 100 pounds. Marking for identification shall be as specified in 3.6.

MILITARY CUSTODIANS:

Army—E O T

Navy—Y

Air Force—MEMPHIS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:12Z
Check the source to verify that this is the current version before use.