A-A-50746
7 August 1987

COMMERCIAL ITEM DESCRIPTION

# DEHUMIDIFIER, SPACE

The General Services Administration has authorized the use of this commercial item description as a replacement for military specification MIL-D-83952 which is canceled.

## Scope:

This commercial item description covers multiple types and sizes of dehumidifiers, and it is intended that the parameters listed herein be representative of commercially available dehumidifiers.

## Salient Characteristics:

This commercial item description covers a range of dehumidifiers capable of condensing from 10 to 50 pints of water per day based on 80° ambient, 60 percent relative humidity. The dehumidifier shall be designed as a self-contained, portable unit, which will be used to remove moisture from air. The dehumidifier shall be mounted on free-swiveling casters.

The dehumidifier shall operate on 115 or 230 volt, 50-60 hertz, single phase, alternating current. Power consumption shall not exceed 40 watts per pint per hour of condensate. The controls shall include an on-off switch, and an adjustable humidistat. The unit shall contain an automatic shutoff switch that stops operation when the moisture container is full. The moisture container shall have a drain fitting that allows a hose to be attached for direct removal of water to a drain.

## Contractor Certification:

The contractor shall certify that the product offered meets the salient characteristics of this description and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices and is the same product as the product offered for sale in the commercial marketplace. Small businesses that cannot offer products with established commercial market acceptability, may compete by submission of bid samples. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

## Regulatory Requirements:

The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practical. Equipment assemblies and parts shall be marked for identification in accordance with MIL-STD-130.

Safety design shall conform to Underwriter's Laboratories, Inc., standards for Safety, Dehumidifiers, UL 474.

FSC 4440

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:46Z
Check the source to verify that this is the current version before use.

Preservation, Packaging, Packing, Labeling, and Marking:

The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

NOTES. Purchaser should specify type and size. UL standard 474 is available from Underwriter's Laboratories (UL), Inc., 333 Pfingsten Road, Northbrook, Illinois 60062.

MILITARY INTERESTS:

Custodians

Air Force - 99

Reviewer Activities

Navy - YD
Army - ME

User Activity

Navy - YD

Preparing Activity

Air Force - 84

Agent: Air Force - 99

Project Number 4440-0052

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:46Z
Check the source to verify that this is the current version before use.