INCH-POUND

MIL-C-915/9E
29 September 1989
SUPERSEDING
MIL-C-915/9D
18 June 1985

MILITARY SPECIFICATION SHEET

CABLE, POWER ELECTRICAL, 600 VOLTS, FOR OUTBOARD USE ONLY (NOT FOR INBOARD USE), TYPE JAS

This specification sheet is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and the issue of the following specification in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation: MIL-C-915.

REQUIREMENTS:

Qualification required.

Construction (non-water tight)

Conductor size 250 MCM (two required)

First - Copper conductor, AWG size 250 MCM, class M stranding, uncoated.
Second - Separator.
Third - Synthetic rubber insulation. Nominal wall thickness 0.070 inch. Standard identification code applied by method 3, if not accomplished under fourth.
Fourth - Tape or braid at manufacturer's option. Standard identification code applied by the tape or braid if not accomplished under third.

Conductor size 12 (two required)

First - Copper conductor, AWG size 12, class K stranding, uncoated.
Second - Separator.
Third - Synthetic rubber insulation. Nominal wall thickness 0.031 inch.

AMSC N/A FSC 6145

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T12:06Z
Check the source to verify that this is the current version before use.

REQUIREMENTS - Continued

Fourth - Marker braid. Standard identification code applied by method 4.
Fifth - Two conductors cabled with 3.5 to 4.24-inch lay. Fillers shall be used to form a round assembly.

Assembly

First - Two conductors, size 250, laid parallel with the pair of size 12 laid between them. Fillers of synthetic elastomer or polychloroprene shall be used to fill all spaces and to hold the pair well centered. At manufacturer's option, fillers may be integral with the jacket.
Second - Nylon reinforcement over the assembly.
Third - Polychloroprene jacket (black). Nominal wall thickness 0.156 inch.
Fourth - Cable surface marking in addition to standard marker tape.

NOTES: 1. Fillers and jacket shall be readily removable from the completed cable without damage to the insulation on the conductors.
2. When the insulation on size 250 is applied as a "D" shaped section, the centering and circularity requirements shall not apply.

TABLE I. Details.

Type and size	Conductors			Overall diameter oval shape maximum (inches)
	Number	Size AWG	Diameter nominal (inch)	
JAS-250	2	12	0.097	1.260 minor and 2.480 major
	2	250 MCM	0.713	

EXAMINATION AND TESTS:

	Requirements
Basic electrical:	
Conductor resistance - ohms/1000 feet at 25°C, maximum	
Size 12	1.65
Size 250 MCM	0.046
Voltage withstand - volts, root mean square, minimum	2000
Insulation resistance - megohms/1000 feet, minimum	
Conductor to conductor and conductor to water	

Source: https://assist.dla.mil -- Downloaded: 20261O-16T12:06Z
Check the source to verify that this is the current version before use.

EXAMINATION AND TESTS - Continued

	Requirements
Conductor size 12	200
Conductor size 250 MCM	100
Group A:	
Visual and dimensional	No failure
Bending endurance - at 25°C, (performed on one specimen from each lot); 14-inch maximum diameter mandrel, flatwise, cycles, minimum	100,000
Group B:	
Physicals (unaged)	
Insulation (conductor)	
Tensile strength - lbf/in², minimum	600
Elongation - percent, minimum	300
Jacket (cable)	
Tensile strength - lbf/in², minimum	1800
Elongation - percent, minimum	300
Group C:	
Flammability - inches, maximum	2
Physicals (aged)	
Insulation (conductor)	
Air pressure heat	
Tensile strength - percent of unaged, minimum	50
Elongation - percent of unaged, minimum	50
Jacket (cable)	
Air pressure heat	
Tensile strength - lbf/in², minimum	50
Elongation - percent, minimum	50
Hot oil immersion	
Tensile strength - percent of unaged, minimum	60
Elongation - percent of unaged, minimum	60
Permanence of printing (jacket) - cycles, minimum	250
Cable filler removability	No failure

QUALIFICATION INSPECTION:

Qualification inspection shall include basic electrical, plus all of groups A, B, and C.

UNIT ORDERING LENGTH: 500 feet (nominal).

NOTE: Not for Air Force use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T12:06Z
Check the source to verify that this is the current version before use.

Revision letters are not used to denote changes due to the extensiveness of the changes.

Custodians:
Army - MI
Navy - SH

Preparing activity:
Navy - SH
(Project 6145-1127-06)

Review activities:
Army - CR, ER
Navy - EC
DLA - IS

User activities:
Army - AL, AR, ME
Navy - CG

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T12:06Z
Check the source to verify that this is the current version before use.