MILITARY SPECIFICATION

METER, VOLUMETRIC, POSITIVE DISPLACEMENT, LIQUID, TYPE F-1, AIRCRAFT FUEL, 300 GALLONS PER MINUTE

This amendment forms a part of Military Specification MIL-M-6404A (USAF) dated 7 April 1965, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 1

2.1
SPECIFICATIONS

Military, Add: "MIL-F-8901 Filter-Separator, Aviation And Motor Fuel, Ground and Shipboard Use, General Requirements And Test Procedures For."

PAGE 3

3.3.4.1, line 1: Delete "A drain shall be provided at the lowest point of the meter housing" and substitute "A drain shall be provided at the lowest point of the meter at a location where it is easily accessible."

PAGE 4

Figure 1, Delete "12-3/4±3/8" and substitute "12-3/4±3/8(REF)"

Delete "9/16±1/64DIA" and substitute "9/16±1/64DIA(DRILL)"
4 HOLES 4 HOLES

Delete "8 MAX" and substitute "8"

PAGE 5

3.4.2, Delete "The performance of the meter shall not be critically affected by the foreign substance passed through a Type F-1 filter conforming to USAF Drawing No. 50D7936" and substitute "The performance of the meter shall not be critically affected by the foreign substance passed through a filter conforming to MIL-F-8901."

FSC 6680

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T07:01Z
Check the source to verify that this is the current version before use.

PAGE 12

Concluding Material, Delete and substitute:

"Custodian:
Air Force - 99

Preparing Activity:
Air Force - 99

Review Activity:
DGSC - GS"

Custodian:
Air Force - 99

Preparing Activity:
Air Force - 99

Review Activity:
DGSC - GS

Project No. 6680-F172

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T07:01Z
Check the source to verify that this is the current version before use.