A-A-2298
November 29, 1984

# COMMERCIAL ITEM DESCRIPTION

## SIAMESE CONNECTION, FIRE HOSE
## (PLAIN; CLAPPERED; PUMPER SUCTION; WATER THIEF)

The General Services Administration has authorized the use of this commercial item description.

This description covers plain, clappered, pumper suction and water thief siamese connections which are used to join two or more lines into one or to attach to the pumper. They shall be furnished in the following types, classes, and styles, as specified. All sizes shown are in inches.

Type I - Cast brass
Type II - Aluminum, hardcoated
  Class A - Plain
  Class B - Single Clapper
  Class C - Double Clapper

| Style | Inlet Size | Outlet Size |
|---|---|---|
| 1 | 1-1/2 x 1-1/2 | 1-1/2 |
| 2 | 2-1/2 x 2-1/2 | 2-1/2 |
| 3 | 2-1/2 x 2-1/2 | 3 |

Class D - Triple Clapper
Class E - Pumper suction, clappered

| Style | Inlet Size | Outlet Size |
|---|---|---|
| 1 | 2-1/2 x 2-1/2 | 4 |
| 2 | 2-1/2 x 2-1/2 | 4-1/2 |
| 3 | 2-1/2 x 2-1/2 | 5 |
| 4 | 2-1/2 x 2-1/2 x 2-1/2 | 4 |
| 5 | 2-1/2 x 2-1/2 x 2-1/2 | 4-1/2 |
| 6 | 2-1/2 x 2-1/2 x 2-1/2 | 5 |

Class F - Two- and three-way, ball valve, pumper suction.

| Style | Inlet Size | Outlet Size |
|---|---|---|
| 1 | 2-1/2 x 2-1/2 | 4 |
| 2 | 2-1/2 x 2-1/2 | 4-1/2 |
| 3 | 2-1/2 x 2-1/2 | 5 |
| 4 | 2-1/2 x 2-1/2 x 2-1/2 | 4 |
| 5 | 2-1/2 x 2-1/2 x 2-1/2 | 4-1/2 |
| 6 | 2-1/2 x 2-1/2 x 2-1/2 | 5 |

Class G - Water thief

| Style | Inlet Size | Outlet Size |
|---|---|---|
| 1 | 2-1/2 | 1-1/2 x 2-1/2 x 1-1/2 |

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Salient characteristics.

All threads shall be of the NH series unless otherwise specified.
All inlet connections shall be provided with female couplings which shall swivel freely and shall be provided with rocker lugs unless otherwise specified.
Outlet connections for Classes A, B, C, and G shall be provided with male couplings. Classes D, E, and F shall be provided with either female, long handles or Storz quick connect couplings, as specified.
Drain valves and carrying handles shall be optional with the manufacturer.
Handles shall be parallel with the central axis of the inlet waterways when in the fully open position (Classes F and G only).
Each inlet branch shall be provided with quarter-turn full-flow ball valves (Classes F and G only).

Conformance testing.

Dry torque test. The siamese connection shall be dry and without hydrostatic pressure. A torque wrench shall be installed in place of the valve handle and the valve turned to its open and closed positions. The peak torque shall not exceed 150 pound-inches (Classes F and G only).

Hydrostatic pressure torque test. The siamese will be connected to a hydrostatic pressure source and 400 psig shall be applied. The valve discharge ends shall be open. The torque wrench shall be turned to the valve open and closed positions. The peak torque shall not exceed 200 pound-inches (Classes F and G only).

Working pressure test. After the hydrostatic pressure torque test the pressure will be increased to 600 psig. (Classes F and G only). For classes A, B, C, D, and E the siamese, with the discharge ends closed, will be connected to a hydrostatic pressure source and 600 psig will be applied. No leakage is permissable.

Proof pressure test. After the working pressure test the pressure shall be increased to 1000 psig and the valve examined for any distortion, mechanical damage, failure, or leaks.

Workmanship. Cast parts shall be fine-grained and free from blowholes, porosity, hard spots, shrinkage, cracks, and other defects. Exterior surfaces shall be smooth. Excessive material on edges shall not be allowed. Valve shall be free of any defects which may affect the durability, appearance, or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling and marking shall be as specified in the contract or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Note. When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Purchaser shall specify type, class, style, and type of coupling for Classes D, E, and F.

Review Activity

Army - ME

PREPARING ACTIVITY:

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.