MIL-F-52429E
13 August 1982
SUPERSEDING
MIL-F-52429D
4 December 1974

MILITARY SPECIFICATION

FILTER-SEPARATOR, LIQUID FUEL:

SKID MOUNTED, 15 GPM (57 LITERS) CAPACITY

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers a 15-gallon-per-minute (gpm) (57 liters) filter-separator for use in removing undissolved water and solid contaminants from petroleum fuels.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. Unless otherwise specified (see 6.2), the following specifications and standards of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation, form a part of this specification to the extent specified herein.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: US Army Mobility Equipment Research and Development Command, ATTN: DRDME-DS, Fort Belvoir, VA 22060 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 4330

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:17Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

FEDERAL

L-P-378	- Plastic Sheet and Strip, Thin Gauge, Polyolefin.
QQ-P-416	- Plating, Cadmium (Electrodeposited).
PPP-B-601	- Boxes, Wood, Cleated-Plywood.
PPP-B-636	- Boxes, Shipping, Fiberboard.
PPP-B-640	- Boxes, Fiberboard, Corrugated, Triple-Wall.
PPP-T-60	- Tape: Packaging, Waterproof.

MILITARY

MIL-P-116	- Preservation, Methods of.
MIL-T-704	- Treatment and Painting of Materiel.
MIL-C-5541	- Chemical Conversion Coatings on Aluminum and Aluminum Alloys.
MIL-A-8625	- Anodic Coatings, for Aluminum and Aluminum Alloys.
MIL-F-8901	- Filter-Separators, Liquid Fuel: And Filter-Coalescer Elements, Fluid Pressure: Inspection Requirements and Test Procedures For.
MIL-W-22248	- Weldments, Aluminum and Aluminum Alloy.
MIL-F-52308	- Filter Element, Fluid Pressure.
MIL-C-81740	- Coatings, Aluminum and Aluminum Alloys.
MIL-C-81751	- Coating, Metallic-Ceramic.
MIL-C-83488	- Coating, Aluminum Ion Vapor Deposited.

STANDARDS

FEDERAL

FED-STD-H28	- Screw-Thread Standards for Federal Services.

MILITARY

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-130	- Identification Marking of US Military Property.

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:17Z
Check the source to verify that this is the current version before use.

MIL-STD-781	- Reliability Tests: Exponential Distribution.
MIL-STD-810	- Environmental Test Methods.
MIL-STD-889	- Dissimilar Metals.
MIL-STD-1188	- Commercial Packaging of Supplies and Equipment.
MIL-STD-1472	- Human Engineering Design Criteria for Military Systems, Equipment and Facilities.

2.1.2 Other Government documents, drawings, and publications. The following other Government documents form a part of this specification to the extent specified herein.

DRAWINGS

ME

TA13217E6620	- Filter-Separator, Liquid Fuel: Skid Mounted, 15-GPM (57 liters).

(Copies of specifications, standards, and drawings required by manufacturers in connection with specific acquisition functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DoD adopted shall be the issue listed in the current DoDISS and the supplement thereto, if applicable.

ALUMINUM ASSOCIATION (AA)

Aluminum Construction Manual, Section 1, Specifications for Aluminum Structures, 7.2 Welding Fabrication.

(Application for copies should be addressed to the Aluminum Association, 420 Lexington Avenue, New York, NY 10017.)

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

Boiler and Pressure Vessel Code, Section IX, Welding Qualifications.

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

AMERICAN WELDING SOCIETY, INC. (AWS)

D1.1 - Structural Welding Code, Section 5, Qualification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

(Application for copies should be addressed to the American Welding Society, Inc., 2501 N.W. Seventh Street, Miami, FL 33125.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

B633 - Electrodeposited Coatings of Zinc on Iron and Steel.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103).

(Industry associations specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.

2.3 Order of precedence. In the event of a conflict between the text of this specification and the reference cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 Description. The filter-separator shall be in accordance with Top Assembly TA13217E6620 and as specified herein. The filter-separator shall consist essentially of a vertical aluminum vessel, a removable flat cover, a manually operated air vent, inlet and outlet connections, a filter element, an outside-to-inside flow canister, a water level sight gage, and a manually operated water drain valve. The filter-separator shall be mounted on a skid. The general requirements, operating, and environmental conditions shall be in accordance with MIL-F-8901. The filter-separator shall have a capacity of 15 gpm (57 liters) and a maximum working pressure of 25 pounds per square inch (psi) (1.7 bars).

3.1.1 Drawings. The drawings forming a part of this specification are end product drawings. No deviation from the prescribed dimensions or tolerances is permissible without prior approval of the contracting officer. Any data (e.g. shop drawings, layouts, flow sheets, processing procedures, etc.) prepared by the contractor or obtained from a vendor to support fabrication and manufacture of the production item shall be made available, upon request, for inspection by the contracting officer or his designated representative.

3.2. First article. The contractor shall furnish a filter-separator for examination and test within the time frame specified (see 6.2) to prove prior to starting production that his production methods will produce filter-separators that comply with the requirements of this specification. Examination and tests shall be as specified in Section 4; and, unless otherwise specified herein, all examination and tests shall be conducted by the contractor subject to surveillance and approval by the Government (see 6.3). When specified (see 6.2), the Government will conduct any or all of the first article examination and tests, as specified (see 6.2).

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:17Z
Check the source to verify that this is the current version before use.

3.3 Initial production. When specified (see 6.2) the contractor shall furnish to the Government one or more filter-separators for inspection as specified in 4.4.

3.4 Materials. Materials shall be as specified herein and as shown on the applicable drawings (see 6.10 and 6.11). All dissimilar materials if used shall be in accordance with MIL-STD-889.)

3.5 Environmental conditions.

3.5.1 Operating temperatures. The filter-separator shall permit rated flow in any ambient temperature in the range of plus 125° F (+52° C) to minus 25° F (-32°C).

3.5.2 Storage temperatures. The filter-separator shall not be damaged by storage at ambient temperatures from plus 160° F (+71° C) to minus 50° F (-46° C).

3.6 Human factors. The filter-separator shall conform to the applicable human factors engineering criteria as specified in MIL-STD-1472 and shall be operable and maintainable by 5th percentile females through 95th percentile males (stature).

3.7 Maintainability.

3.7.1 Maintenance support. Assemblages or support elements such as technical manuals, repair parts, special tools, or lubrication charts as specified (see 6.7 and 6.8) shall be adequate to perform the intended function of assisting or conducting maintenance operations on the filter-separator.

3.7.2 Maintenance ratio. The filter-separator shall have a maintenance ratio of no greater than 0.03.

3.8 Reliability. The specified Mean-Time-Between-Failure (MTBF) shall be 140 hours when the filter-separator is operated at rated capacity and tested as specified in 4.6.2.5.

3.9 Transportability. The filter-separator shall withstand the dynamic vibrational stresses encountered in transportation and service. The filter-separator shall operate as specified herein when tested as specified in 4.6.2.6.

3.10 Vessel (tank). The filter-separator vessel shall be fabricated of aluminum-alloy as specified on the drawings. The vessel shall withstand a hydrostatic pressure of 60 psi (4.14 bars) without leakage, permanent deformation, or other defects that could harmfully affect the performance and serviceability of the filter-separator.

3.10.1 Fuel inlet manifold. The fuel inlet manifold shall be fabricated of aluminum-alloy as specified on the drawings. The manifold shall withstand a

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

minimum of 30 psi (2.07 bars) without leakage, permanent deformation, or other defects that could harmfully affect the performance and serviceability of the filter-separator.

3.11 Media. The media shall consist of one filter element conforming to MIL-F-52308, and one outside-to-inside flow canister as shown on the applicable drawing. The Government will furnish two filter elements NSN 4330-00-983-0998 for each filter-separator (see 6.4), one to be installed in the filter-separator and one as a replacement.

3.12 Hardware. Bolts, nuts, and washers shall be fabricated from materials as specified on the applicable drawings. When ferrous materials are specified, the bolts, nuts, and washers shall be cadmium plated in accordance with QQ-P-416, Type III, Class 1, or zinc coated in accordance with ASTM B633, finish type IV, service condition SC-4, or aluminum coated in accordance with MIL-C-83488, Type II, Class 2, or in accordance with MIL-C-81740, Type II, Class 1, or coated in accordance with MIL-C-81751, Type II. The selection of any treatment shall be in conform- ance with MIL-STD-889. Threads shall conform to FED-STD-H28.

3.13 Gasket replacements. One extra cover gasket and one extra sight gage gasket shall be furnished with each filter-separator as replacement items.

3.14 Identification marking. The filter-separator shall be identified in accordance with MIL-STD-130. The identification, instruction, and warning plates and markings shall be in accordance with the applicable drawing.

3.15 Treatment and painting. The exterior of the filter-separator normally painted shall be cleaned, treated, and painted in accordance with MIL-T-704, type A. Unless otherwise specified (see 6.2), the color of the finish paint shall be forest green.

3.15.1 Chemical coating. The interior of the filter-separator vessel and all components fabricated from aluminum alloy which are in direct contact with the petroleum fuels, shall be anodized in accordance with MIL-A-8625, Type II, Class 1 to a thickness of at least 0.0004 inches, or coated in accordance with MIL-C-5541, Class 1A.

3.16 Cleaning and drying after tests. After conclusion of all tests, and after removal of the canister and element, the filter-separator shall be wiped clean and air-dried at room temperature to exhaust all traces of fuel and water.

3.17 Workmanship. The filter-separator shall be free from defects such as misaligned components, incomplete welds, cracks, burns, leaks, and other defects that could impair the operation and serviceability of the filter-separator. All parts shall be clean and free from dirt, sand, grease, oil, and metal chips. Nonfunctional sharp edges and projecting points, which might present a hazard to personnel, shall be eliminated.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:17Z
Check the source to verify that this is the current version before use.

3.17.1 Welders and welding.

3.17.1.1 Welders. Before assigning any welder to manual welding work covered by this specification, the contractor shall provide the contracting officer with certification that the welder has passed qualification tests as prescribed by the following listed codes for the type of welding operations to be performed and that such qualification is effective as defined by the following codes:

Welding Qualification of the ASME, Section IX.
AWS D1.1 - Structural Welding Code, Section 5, Qualification.
AA, Aluminum Construction Manual, Section 1, Specifications for Aluminum Structures, 7.2 Welding Fabrication.

3.17.1.2 Welding (aluminum). Welding performed in the fabrication of filter-separators shall be in accordance with MIL-W-22248. Classes of welds shall be as specified on the drawings. Welds shall transmit stress without permanent deformation or failure when the parts connected by the welds are subjected to proof and service loading.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspections. Unless otherwise specified in the contract, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications and standards.

4.1.2 Parts and components. Parts and components detailed on the drawings shall be inspected in accordance with the Quality Assurance Provisions (QAP) shown on the applicable drawings. The drawings specify the characteristics requiring inspection, the sampling plan, and the basis for acceptance and rejection (see 6.5 and 6.6).

4.1.3 Disassembly inspection. Failure of a performance test by the first article filter-separator shall require disassembly of the filter-separator in the presence of a Government representative. Each disassembled part shall be inspected in detail for compliance with this specification and referenced drawings in regard to materials, dimensions, tolerances, and workmanship. Parts not complying with such requirements shall be rejected.

4.2 Classification of inspections. Inspections shall be classified as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

(a) First article inspection (see 4.3).
(b) Initial production inspection (see 4.4).
(c) Quality conformance inspection (see 4.5).
(d) Inspection comparison (see 4.7).
(e) Inspection of packaging (see 4.8).

4.3 First article inspection.

4.3.1 Examination. The filter-separator shall be examined as specified in 4.6.1. Presence of one or more defects shall be cause for rejection.

4.3.2 Tests. The filter-separator shall be tested as specified in 4.6.2.1 (a), (b), (c), (d), 4.6.2.2, and 4.6.2.6. Failure of any test shall be cause for rejection or shall be cause for performing the inspection specified in 4.1.3.

4.4 Initial production inspection. When specified (see 3.3), one or more initial production filter-separators will be selected at random by the Government from the filter-separators being produced by production tooling. The filter-separators will be examined as specified in 4.6.1 and subjected to the test specified in 4.6.2 to determine conformance to the requirements of this specification. The inspection will be performed by the Government at a site selected by the Government. Acceptance of an initial production filter-separator shall not exclude the remaining filter-separators from the quality conformance inspection and acceptance provisions specified in Section 4. In addition to any test specified as part of the initial production test, the Government reserves the right to conduct any and all other tests contained in this specification as part of the initial production test and failure of such additional tests shall have the same effect as failure of those tests specified as initial production tests.

4.4.1 Inspection failure. Failure of an initial production filter-separator to meet any requirement specified herein during and as a result of the examination and tests specified in 4.4 shall be cause for rejection of the initial production filter-separator and shall be cause for refusal by the Government to continue acceptance of production filter-separators until evidence has been provided by the contractor that corrective action has been taken to eliminate the deficiencies. Correction of such deficiencies shall be accomplished by the contractor at no cost to the Government on filter-separators previously accepted and produced under the contract. Any deficiencies found as a result of the initial production inspection will be considered prima facie evidence that all filter-separators accepted prior to the completion of the initial production inspection are similarly deficient unless evidence to the contrary is furnished by the contractor and such evidence is acceptable to the contracting officer.

4.5 Quality conformance inspection.

4.5.1 Sampling. Sampling for examination shall be in accordance with MIL-STD-105, Inspection Level II.

Source: https://assist.dla.mil -- Downloaded: 202640-22T21:17Z
Check the source to verify that this is the currentversion before use.

4.5.2 Examination.

4.5.2.1 Samples. Samples selected in accordance with 4.5.1 shall be examined for the major and minor defects specified in 4.6.1. AQL shall be 2.5 percent defective for major defects and 4.0 percent defective for minor defects.

4.5.3 Tests.

4.5.3.1 Individual. Each filter-separator shall be tested as specified in 4.6.2.1 (a) and (b). Failure of either test shall be cause for rejection.

4.6 Inspection procedure.

4.6.1 Examination. Filter-separators shall be examined as specified herein for the following defects:

Major

101. Any part or component not in accordance with the QAP requirements as shown on the drawings see (see 2.1.2).
102. Materials not as specified (see 3.4).
103. Hardware such as bolts, nuts, washers, and screw threads not as specified (see 3.12).
104. Aluminum parts and components not coated as specified (see 3.15.1).
105. Filter-separators not cleaned and air-dried after testing (see 3.16).
106. Workmanship not as specified (see 3.17).
107. Weldings and castings not as specified (see 3.17.1.2).

Minor

201. Dimensions, other than those identified by QAP data, not as specified (see 2.1.2).
202. Identification marking, incorrect, illegible or missing (see 3.14).
203. Instruction plates not as specified (see 3.14).
204. Treatment and painting not as specified (see 3.15).

4.6.2 Tests.

4.6.2.1 Performance test. The filter-separators shall be tested to the following performance requirements as specified in MIL-F-8901, Table III:

(a) Hydrostatic pressure test.
(b) Permanent separator stage (outside-to-inside design).
(c) Differential pressure.
(d) Water removal, 5 percent.

Nonconformance to 3.10, 3.10.1, 3.11, or to the applicable requirements of MIL-F-8901 shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:17Z
Check the source to verify that this is the currentversion before use.

4.6.2.2 Temperature.

4.6.2.2.1 High temperature. The filter-separator shall be tested as specified in MIL-STD-810, Method 501.1, Procedure I. The maximum test temperature for storage shall be plus 160° F (+71° C) and the maximum operating temperature shall be plus 125° F (+52° C). The operating period of procedure I shall be 1 hour or the operating time required to check for any component failure due to high temperatures.

4.6.2.2.2 Low temperature. The filter-separator shall be tested as specified in MIL-STD-810, Method 502.1, Procedure I. The minimum test temperature for storage shall be minus 50° F (-46° C) and the minimum operating temperature shall be minus 25° F (-32° C). The operating period of procedure I shall be 1 hour, or the operating time required to check for any component failure due to low temperatures.

4.6.2.2.3 Failure criteria. Nonconformance to 3.5 or to the applicable requirements of MIL-STD-810 shall constitute failure of either temperature test.

4.6.2.3 Human factors. The filter-separator shall be evaluated by a human factors engineer to determine conformance to 3.6. Nonconformance to 3.6 shall constitute failure of this test.

4.6.2.4 Maintainability.

4.6.2.4.1 Maintenance support. Maintenance operations required during initial production testing shall be accomplished by operating personnel in accordance with the requirements of 3.7.1. Failure of the support elements to maintain the filter-separator as specified shall constitute failure of this test.

4.6.2.4.2 Maintenance ratio. The maintenance ratio shall be computed during initial production testing to determine compliance with 3.7.2. The maintenance ratio is defined as the total active maintenance man-hours (scheduled and unscheduled) required to the total operating time. Nonconformance to 3.7.2 shall constitute failure of this test.

4.6.2.5 Reliability. Using the MTBF specified in 3.8, the initial production filter-separator(s) shall be tested as specified in 4.6.2.1 and 4.6.2.2, with "accept" and "reject" criteria in accordance with MIL-STD-781, Test Plan IV. At completion of above testing, continue testing in accordance with 4.6.2.1 (d) until "accept" or "reject" decision is reached. A failure is defined as any malfunction which causes or may cause:

(a) Failure to commence operation, cessation of operation, or degradation of performance below specified levels.
(b) Damage to the filter-separator by continued operation.
(c) Safety hazards to personnel.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:17Z
Check the source to verify that this is the current version before use.

Nonconformance to 3.8 shall constitute failure of this test. Dependent failures or malfunctions occurring as the result of improper maintenance procedures or operator error are excluded from consideration as chargeable failures. Note: Replacement of filter elements shall not be considered a failure.

4.6.2.6 Transportability. The filter-separator, shall be transported by 2-1/2 ton cargo truck over cross-country at an average speed of 15 mph (24 Kph) for a total of 100 miles (161 kilometers). Damage to the filter-separator or components or nonconformance to 3.9 shall constitute failure of this test.

4.7 Inspection comparison. The Government may select filter-separators at any time during the contract production period and subject the filter-separators to the examination specified in 4.6.1 and the tests specified in 4.6.2 to determine conformance to the requirements of this specification. The inspection will be performed by the Government, at a site selected by the Government, on filter-separators selected at random from those which have been accepted by the Government and will not include the previously inspected first article and initial production filter-separators. In addition to any test specified as part of the inspection comparison, the Government reserves the right to conduct any and all other tests contained in this specification as part of the inspection comparison and failure of such additional tests shall have the same effect as failure of those tests specified as inspection comparison.

4.7.1 Inspection failure. Failure of an inspection comparison filter-separator to meet any requirement specified herein during and as a result of the examination and tests specified in 4.7 shall be cause for rejection of the inspection comparison filter-separator(s) and shall be cause for refusal by the Government to continue acceptance of production filter-separators until evidence has been provided by the contractor that corrective action has been taken to eliminate the deficiencies. Correction of such deficiencies shall be accomplished by the contractor at no cost to the Government on filter-separators previously accepted and produced under the contract. Any deficiencies found as a result of the inspection comparison will be considered prima facie evidence that all filter-separators accepted prior to the completion of inspection comparison are similarly deficient unless evidence to the contrary is furnished by the contractor and such evidence is acceptable to the contracting officer.

4.8 Inspection of packaging.

4.8.1 Quality conformance inspection of pack.

4.8.1.1 Unit of product. For the purpose of inspection, a completed pack prepared for shipment shall be considered a unit of product.

4.8.1.2 Sampling. Sampling for examination shall be in accordance with MIL-STD-105.

4.8.1.3 Examination. Samples selected in accordance with 4.8.1.2 shall be examined for the following defects. AQL shall be 2.5 percent defective.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

108. Materials, methods, and containers not as specified. Each incorrect material, method, or container shall be considered one defect (see 5).
109. Canister and filter element not installed (see 5.1).
110. Dust plug and dust cap not installed (see 5.1).
111. Drain valve not open (see 5.1).
112. Extra element not preserved by one of the methods specified (see 5.1.1).
113. Extra gaskets not preserved as specified (see 5.1.2).
114. Contents not cushioned and blocked within the consolidation container, in a manner to prevent free movement and damage (see 5.1.3).
115. Consolidation container not closed and sealed as specified (see 5.1.3).
116. Gross weight exceeds 200 pounds for level A (see 5.2.1).
117. Gross weight or size exceeds the limitations of the applicable box specification for level B (see 5.2.2).
118. Commercial marking not in accordance with the referenced document (see 5.3.2).
119. Marking missing, illegible, incorrect, or incomplete for level A, level B, or commercial (see 5.3).

5. PACKAGING

5.1 Preservation. The filter-separator with canister and filter element installed shall not require preservation (see 6.9). The water drain valve shall be opened. Dust plug and cap shall be installed.

5.1.1 Extra element. The extra filter element shall be preserved by one of the following methods:

(a) The filter element shall be preserved in accordance with MIL-P-116, method IA-13.
(b) The filter element shall be inserted in polyethylene bag fabricated from material conforming to L-P-378, type I, class 1, grade and finish optional, thickness not less than .0040 inch and closed by heat sealing. The bag containing the element shall be placed in a close-fitting box conforming to PPP-B-636, W6c. The box shall be closed and sealed as specified for method V in the appendix to the box specification using tape conforming to PPP-T-60, type IV.

5.1.2 Extra sight gage gasket and cover gasket. Each gasket shall be laid flat between two pieces of fiberboard and individually preserved in accordance with MIL-P-116, method IC-1. The fiberboard shall be slightly larger than each gasket.

5.1.3 Consolidation. The filter-separator, extra element, and extra gaskets, shall be placed together in a close-fitting box conforming to PPP-B-636, W5c, style optional. The contents shall be cushioned and blocked to prevent free movement and damage. The box shall be closed and sealed as specified for method V in the appendix to the box specification using tape conforming to PPP-T-60, type IV.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

5.2 Packing. Packing shall be level A, B, or commercial as specified.

5.2.1 Level A. The filter-separators, preserved as specified in 5.1, shall be packed in quantities not to exceed 200 pounds in close-fitting boxes conforming to PPP-B-601, Overseas Type, style optional. Box closure and strapping shall be in accordance with the appenidx to the box specification.

5.2.2 Level B. The filter-separators, preserved as specified in 5.1, shall be packed as specified for level A, except the boxes shall be domestic type. As an alternate, the filter-separators may be packed in close-fitting fiberboard boxes conforming to PPP-B-640, class 2, style optional of PPP-B-636, V3c, style optional. The gross weight or size of each box shall not exceed the limitations of the applicable box specification. Box closure and strapping shall be in accordance with the appendix to the applicable box specification.

5.2.3 Commercial. The filter-separators, preserved as specified in 5.1, shall be packed in accordance with MIL-STD-1188.

5.3 Marking (see 6.9).

5.3.1 Military. Marking for military levels of protection (level A or B) shall be in accordance with MIL-STD-129.

5.3.2 Commercial. Commercial marking shall be in accordance with MIL-STD-1188.

6. NOTES

6.1 Intended use. The filter-separator is intended for use in portable refueling systems for the removal of undissolved water and solid contaminants from aviation, diesel, or motor fuels.

6.2 Ordering data. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Date of issue of DoDISS applicable to this contract and exceptions thereto (see 2.1.1).
(c) Time frame required for submission of first article (see 3.2).
(d) When the Government will conduct any or all of the first article model examination and tests. When the Government will conduct some but not all of the first article examination and tests, the contracting officer should specify which examination and tests will be conducted by the Government and which examination and tests shall be conducted by the contractor (see 3.2).
(e) When initial production inspection is required and number of filter-separators to be furnished, when applicable (see 3.3).
(f) Finish paint, when other than as specified (see 3.15).
(g) Degree of packing required (see 5.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

6.3 First article. Any changes or deviations of production filter-separators from the approved first article during production will be subject to the approval of the contracting officer. Approval of the first article will not relieve the contractor of his obligation to furnish filter-separators conforming to this specification.

6.4 Government-furnished property. The contracting officer should arrange to furnish the property specified in 3.11.

6.5 Quality Assurance Provisions (QAP). The contracting officer should require the contractor to maintain records of all QAP inspections. A suggested paragraph is as follows:

"The contractor shall maintain complete records of all examinations and tests performed to verify the requirements of classified QAP characteristics. The records shall include as a minimum, lot size, sample size, drawing requirement, actual measurement, number and type of deficiencies found, quantity approved, quantity rejected, corrected action taken when applicable."

6.6 Definition of QAP. A QAP is a contractural requirement that supplements Section 4 of the specification. QAP indicates the minimum requirements which must be inspected on the product drawings to verify the design objectives of the product and assure interchangeability of repair parts.

6.7 Data requirements. The contracting officer should include requirements for such data as technical publications, instructional materials, illustrated parts lists, and contractor's maintenance and operation manual to be furnished with each filter-separator.

6.8 Provisioning. The contracting officer should include provisioning requirements for repair parts and maintenance tools as necessary (including any special tools), and instructions on shipment of filter-separators.

6.9 Preservation and packing level marking. Degrees of preservation have not been included, since the protection specified is the minimum acceptable. For purposes of preservation and packing level marking, preservation shall be designated level A.

6.10 Recycled material. It is encouraged that recycled material be used when practical as long as it meets the requirements of the specification (see 3.4).

6.11 Material deterioration prevention and control (MADPAC). The contracting officer should consider for inclusion in all applicable invitations for bid, requests for proposal, and contracts the following:

"The technical proposal shall provide assurance that all system/item parts shall be fabricated from compatible materials, suitably finished, to provide protection from corrosion and other forms of materiel deterioration. The assurance shall be in the form of a finish plan, utilizing state-of-art

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

technology, which clearly identifies the specific finish or treatment to be used on the various components and assemblies, to provide protection against the various forms of materiel deterioration in the applicable operating and storage environments to which they may be exposed."

Custodians:
Army - ME
Navy - YD
Air Force - 99

Review activities:
Navy - AS
DLA - CS

User activity:
Army - AV

Preparing activity:
Army - ME

Project 4330-0026

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS: This form is provided to solicit beneficial comments which may improve this document and enhance its use. DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.
NOTE: This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

DOCUMENT IDENTIFIER *(Number)* AND TITLE MIL-F-52429E Filter-Separator, Liquid Fuel: Skid Mounted, 15 GPM (57 Liters) Capacity

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1. ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A. GIVE PARAGRAPH NUMBER AND WORDING

B. RECOMMENDED WORDING CHANGE

C. REASON FOR RECOMMENDED CHANGE(S)

2. REMARKS

SUBMITTED BY *(Printed or typed name and address — Optional)*

TELEPHONE NO.

DATE

DD FORM 1 OCT 76 1426 EDITION OF 1 JAN 72 WILL BE USED UNTIL EXHAUSTED.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:17Z
Check the source to verify that this is the current version before use.