A-A-2212
July 18, 1984

COMMERCIAL ITEM DESCRIPTION

LAMP SODIUM (High Pressure)

The General Services Administration has authorized the use of this commercial item description.

This description covers high pressure sodium lamps for general and street lighting.

Salient characteristics.

Burning position - Any.
The base shall be made of brass.
The lamps shall be clear.
Volts - 52
The lamps shall have the characteristics that are described in Table I.

TABLE I - LAMP CHARACTERISTICS

Type	ANSI Code	Watts	Base	Bulb	Max. Overall Length (inches)	Avg. Rated Life (10 hrs. per start)	Approx. Lumens Initial*/Mean**	
1	S76HA-35	35	Medium	E-17, B-17	5-7/16	16,000	2,250	2,025
2	S68LP-50	50	Medium	E-17, B-17	5-7/16	24,000+	4,000	3,600
3	S68MS-50	50	Mogul	E-23½, BT-25	7-3/4	24,000+	4,000	3,600
4	S62LG-70	70	Medium	E-17, B-17	5-7/16	24,000+	5,800	5,220
5	S62ME-70	70	Mogul	E-23½, BT-25	7-3/4	24,000+	5,800	5,220

* Initial lumen ratings are based upon 100-hour photometry reading at rated lamp watts.

** Mean lumens are based on operation at approximately 50 percent of rated life, under specified test conditions with 100 or more burning hours per start.

FSC 6240

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

The lamps shall be measured in accordance with ANSI Standard C78.388. The S62, 70 watt lamp shall be in accordance with ANSI Standard C78.1353.

The issues of ANSI Standard C78.388 and C78.1353 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preproduction inspection. One package of lamps, produced using the same tooling, production, and assembly methods that are used for production lots, shall be submitted for examination and test in accordance with the above requirements. Documentation consisting of the certification and test data shall be presented for examination during performance of the preproduction inspection. Failure of the preproduction samples to pass the examination of one or more of the tests, the lack of required documentation, or failure of the documentation to substantiate conformance to the requirements of this CID shall be cause for rejection.

Notes. ANSI Standards C78.388 and C78.1353 are available from the American National Standards Institute, Inc., 1430 Broadway, New York, New York 10018.

The commercial item certification clause is not required when this commercial item description is used for procurement.

Although the outer bulb is made of heat resistant glass, external protection of the lamp is still required to eliminate the chance of bulb breakage due to direct contact with water during lamp operation.

Military Coordinating Activity

None. DoD has waived coordination on this commercial item description until further notice.

PREPARING ACTIVITY:
GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.