[INCH-POUND]
A-A-244A
June 25, 1996
SUPERSEDING
A-A-244
April 12, 1980

COMMERCIAL ITEM DESCRIPTION

VALVE, AIR VENTING, STEAM, THERMOSTATIC

The General Services Administration has authorized the use of this commercial item description by all federal agencies.

1. SCOPE

1.1 Scope. This commercial item description (CID) covers a thermostatically operated, nonadjustable vent valve, intended to be mounted on an individual radiator to automatically free the steam heating system of air.

2. SALIENT CHARACTERISTICS

2.1 Rating. At the normal fixed vent setting, the valve shall maintain a radiator with at least 100 square feet (9.3 m^2) of rated surface within 3°F (-16°C) of inlet steam temperature, except the last radiator section, which shall be within 20°F (-7°C).

2.2 Temperature equilibrium. Equilibrium shall be attained within 50 minutes when supplied with steam at 1/2 psi (3.4 kPa).

2.3 Pressure. The valve shall be designed for 15 psi (103 kPa) maximum steam pressure.

2.4 Pattern. The valve pattern shall be an angle configuration.

2.5 Material/finish. The valve body and base shall be brass, with the exterior chrome or nickel plated.

2.6 Mounting. The valve shall be capable of being mounted on individual steam radiators by 1/8 American Standard taper pipe thread connection.

2.7 Workmanship. The valve shall have no defect that affects function, appearance or serviceability.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data which may improve this document should be sent to: General Services Administration, Engineering Group (7FXEE), 819 Taylor St., Fort Worth, TX 76102

DISTRIBUTION STATEMENT A: Approved for public release; distribution is unlimited.

FSC 4520

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:06Z
Check the source to verify that this is the current version before use.

2.8 Measurement system. The values stated in inch-pound units are to be regarded as the standard. The metric values stated in parentheses are for information purposes only.

2.9 Metric products. Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, providing they fall within the tolerances specified and all other requirements of this document are met. If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch-pound units, a request should be made to the contracting officer to determine if the product is acceptable.

3. REGULATORY REQUIREMENTS

3.1 Regulatory requirements. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

4. QUALITY ASSURANCE PROVISIONS

4.1 Product Conformance. The products provided shall meet the salient characteristics of this commercial item description, conform to the producer's own drawings, specifications, standards, and quality assurance practices and be the same product offered for sale in the commercial market. The government reserves the right to require proof of such conformance.

5. PACKAGING

5.1 Packaging. Preservation, packing, and marking shall be as specified in the contract or order.

6. NOTES

6.1 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents (if applicable).

a. Title, number and date of this commercial item description.
b. The preservation, packing, and marking desired.

6.2 National Stock Number: The following NSN is assigned which corresponds to this CID. The NSN may not be indicative of all possible NSNs associated with the CID.

NSN: 4520-00-222-3559

MILITARY INTEREST:

Review Activity
DLA - CS

CIVIL AGENCY COORDINATING ACTIVITY:
GSA-FSS

Preparing Activity:
GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:06Z
Check the source to verify that this is the current version before use.