HH-I-1972/2
Amendment 1
3 October 1985

FEDERAL SPECIFICATION

INSULATION BOARD, THERMAL, POLYURETHANE OR POLYISOCRYANURATE FACED WITH ASPHALT/ORGANIC FELT, ASPHALT/ASBESTOS FELT OR ASPHALT/GLASS FIBER FELT ON BOTH SIDES OF THE FOAM

This amendment, which forms a part of HH-I-1972, dated August 12, 1981, is approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

PAGE 1

Title, delete and replace with:

"INSULATION BOARD, THERMAL, POLYURETHANE OR POLYISOCYANURATE FACED WITH ASPHALT/ORGANIC FELT, POLYMER/ORGANIC MAT, ASPHALT/GLASS MAT, OR POLYMER/GLASS MAT ON BOTH SIDES OF THE FOAM."

Paragraph 1.1, delete and replace with:

"1.1 Scope. This specification covers the requirements for faced insulation boards composed of rigid cellular polyurethane or polyisocyanurate faced with asphalt/organic felt, polymer/organic mat, asphalt/glass mat or polymer/glass mat on both sides of the foam. This specification does not cover cyrogenic applications. For intended use see 6.1 of HH-I-1972/GEN."

Paragraph 1.2, delete and replace with the following:

"1.2 Classification. The insulation boards shall be class 1 and meet the physical requirements of 3.3, table I.

Class 1 - Compressive strength - 16 psi minimum."

PAGE 2

Paragraph 2.2, delete:

"D250 - Asphalt-Saturated Asbestos Roofing Felt for Use in Waterproofing and Constructing Built-Up Roofs."

FSC 5640

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:56Z
Check the source to verify that this is the currentversion before use.

Paragraph 3.3.1, delete and replace with the following:

"3.1.1 Facing materials. Unless otherwise specified (see 6.2 of HH-I-1972/GEN), the facing material incorporated in the design of the faced thermal insulation board shall be at the manufacturer's option one of the following, asphalt/organic felt, polymer/organic mat, asphalt/glass mat, or polymer/glass mat, or polymer/glass mat on both sides of the foam. The facing material shall meet the requirements of 3.1.1.1 through 3.1.1.3."

Paragraph 3.1.1.2, delete and replace with the following:

"3.1.1.2 Polymer/organic mat. The polymer/organic mat shall consist of a cellulosic and glass fiber matrix bonded with organic polymer binders."

Paragraph 3.1.1.3, delete and replace with the following:

"3.1.1.3 Asphalt/glass fiber felt. The asphalt/glass fiber felt shall consist of fibrous glass mats coated with asphalt or asphalt emulsion."

Delete:

"3.1.1.4 Polymer/glass fiber mat. The polymer/glass fiber mat shall consist of fibrous glass mats bonded with organic polymer binders."

Table 1, delete and replace with the following:

"TABLE 1. Physical properties.

Property	Class 1	Test reqmt. para.
Compressive strength (psi) min.	16.0	4.5.3
Dimensional stability (L)	2.0	4.5.4
at -40°F/ambient RH, (W)	2.0	
(percent change) max.		
Dimensional stability (L)	4.0	4.5.4
at 158°F/94 percent RH, (W)	4.0	
(percent change) max.		
Dimensional stability (L)	4.0	4.5.4
at 200°F/ambient RH, (W)	4.0	
(percent change) max.		

"

Custodians

Navy - YD
Air Force - 99

CIVIL AGENCY COORDINATNG ACTIVITIES:

COM-NBS
GSA PCD
GSA-FSS

Review Activity

Air Force - 84

Preparing Activity

Navy - YD

DoD Project 5640-0105

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:56Z
Check the source to verify that this is the current version before use.