JJ-H-571b
April 12, 1967

SUPERSEDING
Int. Fed Spec., JJ-H-00571a (GSA-FSS)
May 13, 1964 and
Fed. Spec. JJ-H-571
September 5, 1933

FEDERAL SPECIFICATION

# HOSE, FIRE, LINEN, UNLINED (WITH OR WITHOUT COUPLINGS)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

## 1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers one type of unlined linen fire hose with or without couplings, suitable for fire protection purposes only.

1.1.1 Federal specification coverage. Federal specifications do not include all varieties of the commodity as indicated by the title of the specification, or which are commercially available, but are intended to cover only those generally used by the Federal Government.

1.2 Classification.

1.2.1 Type, styles, and sizes. Fire hose covered by this specification shall be of one type and of the following styles, and sizes, as specified (see 6.2):

Style A—Without couplings.
Style B—With expansion ring type couplings.
Style C—With screw-in expander type couplings.
Size 1½—1½ inch internal diameter.
Size 2—2 inch internal diameter.
Size 2½—2½ inch internal diameter.

## 2. APPLICABLE DOCUMENTS

2.1 Specifications and standards. The following specifications and standards, of the issues in effect on date of invitations for bids, or request for proposal, form a part of this specification to the extent specified herein:

Federal Specification:

WW-C-621—Coupling Assembly, Hose, (Fire, Woven-Jacketed, Rubber or Cambric-Lined and Unlined Lien).

Federal Standard:

Fed. Std. No. 123—Marking for Domestic Shipment (Civilian Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington D.C. 20402.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston,



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:56Z
Check the source to verify that this is the current version before use.

New York, Washington, D.C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, Los Angeles, and Seattle, Wash.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Specification:

MIL-H-775—Hose, Rubber or Fabric, (Including Tubing), and Fittings, Nozzles and Strainers, Packaging of.

Military Standards:

MIL-STD-129—Marking for Shipment and Storage
MIL-STD-130—Identification Marking of U. S. Military Property.

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

Underwriters' Laboratories Inc., Standards:

UL 18—Standard for Unlined Fire Hose.

(Copies may be obtained from the Underwriters' Laboratories, Inc., 207 East Ohio Street, Chicago, Illinois, 60611.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

## 3. REQUIREMENTS

3.1 Label of Underwriters' Laboratories, (UL) Inc. Each contractor shall submit to the contracting agency proof that the fire hose he proposes to supply under this specification conforms to the requirements of UL 18. The label of the UL, Inc., may be accepted as evidence that the fire hose conforms to this requirement. In lieu of the label the contractor may submit independent proof, satisfactory to the contracting agency, that the fire hose conforms to the applicable requirements of the published standards including methods of tests of UL 18.

3.1.1 Compliance. Compliance with the above requirements does not absolve the contractor from complete compliance with the other requirements of this specification in order to secure acceptance of his material.

3.2 Materials. Materials shall be as specified herein.

3.2.1 Fabric. The hose shall be woven from threads spun from first quality flax line and shall be free from knots and shives.

3.2.2 Couplings. Style A hose shall be furnished without couplings. Style B hose shall be assembled to rocker-lug, expansion couplings conforming to type C1 of WW-C-621. Style C hose shall be assembled to rocker-lug, screw-in expansion couplings conforming to type D1 of WW-C-621.

3.3 Construction. The hose shall be seamless and have the filler threads woven around the hose throughout its length and the warp threads interwoven with the filler threads.

3.4 Diameter. The internal diameter of size 1½, 2, and 2½ inch hose shall be not less than the nominal trade size and not more than ⅛ inch in excess thereof.

3.5 Length. Hose shall be furnished in 25, 50, 75, or 100 foot lengths, as specified (see 6.2). The length shall be measured from end to end with the hose laid out straight. This measured length shall not be less than that specified. Styles B and C hose from which samples were cut for testing shall be re-



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:56Z
Check the source to verify that this is the current version before use.

coupled by the contractor and accepted as full lengths. The length of styles B and C hose shall be measured between the back edge of the couplings and shall not be more than 4 inches shorter than the length specified.

3.6 Workmanship. The hose shall be even and firm in texture throughout, have a smooth interior, and the material shall be free from the defects as defined in UL 18.

3.7 Military agencies. Identification marking for Military agencies shall be in accordance with MIL-STD-130.

## 4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified, the supplier may utilize his own facilities or any commercial laboratory acceptable to the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Acceptance tests. The contractor shall furnish all samples and shall be responsible for accomplishing the tests specified herein. The contractor shall furnish test reports, in duplicate, showing quantitative results for all tests and analyses required by this specification, and signed by an authorized representative of the contractor or laboratory, as applicable. Acceptance or approval of material during the course of manufacture shall in no case be construed as a guaranty of the acceptance of the finished product.

4.2.1 Visual examination and tests. Visual examination and tests of the fire hose shall consist of the sampling and test requirements of UL 18.

4.2.1.1 Inspection of preparation for delivery. An inspection shall be made to determine that the packaging, packing, and marking comply with the requirements of section 5 of this specification. The quality assurance provisions of MIL-H-775 shall apply.

## 5. PREPARATION FOR DELIVERY

5.1 Packaging and packing. Hose of the style, size, and length specified (see 6.2) shall be packaged and packed in accordance with MIL-H-775 as specified for the applicable level.

5.2 Marking.

5.2.1 Civil agencies. In addition to markings required by the contract or order, (see 6.2), the interior packages and shipping containers shall be marked in accordance with Fed. Std. No. 123.

5.2.2 Military agencies. In addition to markings required by the contract or order (see 6.2), the interior packages and shipping containers shall be marked in accordance with MIL-STD-129.

## 6. NOTES

6.1 Intended use. Unlined linen hose is designed for fire protection use only and for installation at inside standpipes and similar places where it can be kept dry. It should never be wet except for use at a fire. It should be stretched out or hung up at intervals so that dampness between folds may be dispelled.

6.2 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Style, size, and length of hose required (see 3.2.2 and 3.5).
(c) Selection of applicable level of preservation, packaging, and packing required (see 5.1).
(d) Special marking if required (see 5.2).



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:56Z
Check the source to verify that this is the current version before use.

MILITARY INTEREST:

Custodians:
Air Force—AFLC
Army—MO(ERDL)
Navy—YD
DSA—CS

Review activities:
Air Force—11, 81
Navy—YD

User activities:
Army—CE, MO

Preparing activity:
GSA—FSS

CIVIL AGENCY INTEREST:
GSA—FSS
VA—DMS
PO—ORE



Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein. Price 5 cents each.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:56Z
Check the source to verify that this is the current version before use.