WW-P-541/6B
August 1, 1980
SUPERSEDING
Fed. Spec. WW-P-541/6A
October 12, 1971

FEDERAL SPECIFICATION SHEET

PLUMBING FIXTURES (DRINKING FOUNTAINS) (DETAIL SPECIFICATION)

This specification forms a part of the latest issue of Federal Specification WW-P-541/GEN.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers specific requirements for drinking fountains, fittings, and trim for drinking fountains (see 6.2).

1.2 Classification.

1.2.1 Type of fountains furnished under this specification sheet shall be of the types indicated in table I.

1.2.2 Definitive part number (DPN). Fountains covered by this specification shall be identified by a DPN. This part number is intended for cataloging and ordering purposes; it is not intended for surface printing on the fountains. The DPN shall consist of the Federal specification symbol plus the specification part number (SPN) (see table I). The DPN shall be written as indicated below (see 6.1 and 6.4).

DPN WWP541/6 XXXXXXX

Specification sheet identification for fixture required

SPN

TABLE I. SPN numbering system.

First character denotes mounting type.
- (A) Surface wall mounted
- (B) Semi-recessed wall mounted.
- (C) Recessed wall mounted.
- (D) Pedestal mounted.

Second and third number character material.
- 01 - Vitreous china (mounting types A, B, and C only).
- 02 - Stainless steel (mounting types A, B, and C only).
- 03 - Enameled cast iron (mounting types A, B, and C only).

Source: https://assist.dla.mil -- Downloaded: 202610-26T12:23Z
Check the source to verify that this is the currentversion before use.

TABLE I. SPN numbering system - cont'd.

04 - Aluminum alloy (mounting types A, B, and C only).
05 - Polyester plastic and aggregate (mounting types A, B, and C only).
06 - Polyester plastic and fiber glass (mounting types A, B, and C only).
07 - Terrazzo (mounting types A, B, and C only).
08 - Vitreous china bowl, column, and base (mounting type D only).
09 - Stainless steel bowl, carbon steel column, and cast iron base (mounting type D only).
10 - Stainless steel bowl and self-supporting masonry column (mounting type D only).
11 - Stainless steel bowl, and self-supporting stainless steel column (mounting type D only).
12 - Aluminum alloy bowl, and self-supporting aluminum alloy column (mounting type D only).
13 - Aluminum alloy bowl, column and base (mounting type D only).
14 - Copper-alloy bowl, column and base (mounting type D only).

Fourth character denotes control valve.
1 - Push button.
2 - Lever or 4-arm handle.
3 - Foot pedal (mounting type D only).

Fifth character denotes height of fountain.
1 - High back 13 to 22 inches (types A, B, and C).
2 - Medium back 6 to 8 inches (types A, B, and C).
3 - Low back 3/4 to 2 inches (types A, B, and C).
4 - Back level with rim (types A, B, and).
5 - Pedestal fountain height (type D) 32 ±2 inches.
6 - Pedestal fountain height (type D) 36 ±2 inches.
7 - Pedestal fountain height (type D) 38 ±2 inches.
8 - Pedestal fountain height (type D) 40 ±2 inches.

Six character denotes finish.
(a) Stainless steel bowl; number 4 general polish (see 3.7.1a).
(b) Stainless steel bowl; number 6 soft satin finish (see 3.7.1b)
(c) Stainless steel bowl; number 7 highly reflective finish (see 3.7.1 (c) and (d)).
(d) Aluminum alloys; clear natural color.
(e) Aluminum alloy; anodized gold color.
(f) Cast iron and carbon steel; 2 inch coated (see 3.7.3).
(g) Cast iron and carbon steel; painted (see 3.7.3).

2. APPLICABLE DOCUMENTS

2.1 Latest issue of WW-P-541/GEN and documents referenced therein.

3. REQUIREMENTS

3.1 General. Water fountains furnished under this specification shall be complete operational outfits.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

3.2 Materials.

3.2.1 Mounting types, A, B, and C fountains. Fountain material shall be selected from table I.

3.2.2 Terrazzo. Terrazzo fountains shall consist of stone chips and masonry. Bowl shall be stainless steel.

3.2.3 Masonry. Masonry fountains shall be precast reinforced concrete.

3.3 Bubbler.

3.3.1 Water stream. The angle of the jet shall be such as to prevent the return of water to the orifices, and shall not wet the guard.

3.3.2 Water regulator. The automatic stream regulator or flow control shall be incorporated in the bubbler.

3.3.3 Orifice.

3.3.3.1 Height. Orifices of bubblers shall be a minimum of 1/2 inch above the overflow rim of the bowl to prevent contact with water when the drain is clogged (see 4.4.1).

3.3.3.2 Number of orifices. Bubblers shall have one or two orifices at the manufacturer's option.

3.3.4 Guard. Bubblers shall include a guard to prevent the mouth and nose of persons using the fountain from coming into contact with orifices, and to prevent foreign material from dropping vertically into the nozzle.

3.4 Fittings and trim.

3.4.1 Brackets. Brackets for wall mounted fountains shall be of metal.

3.4.2 Control valves. Control valves shall be self-closing. Operation of valves shall be pushbutton, knob, or foot pedal as selected from table I.

3.5 Dimensional requirements.

3.5.1 Mounting types A, B, and C.

3.5.1.1 Back of fountains. Back of fountain heights above the rim shall be as selected from table I.

3.5.2 Pedestal fountain height (mounting type D). The height from the bottom of the base to the top of the rim of pedestal fountains shall be from 30 through 42 inches as selected from table I. Tolerance for height of all pedestal fountains shall be ±1/4 inch.

3.6 Bowl shape. Vitreous china and stainless steel bowls shall be circular or rectangular in shape. Enamel cast iron bowls shall be circular, rectangular, or any other suitable shape. The design of outside surface of bowls shall be in accordance with the manufacturer's standard commercial product.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

3.7 Finish.

3.7.1 Stainless steels. Unexposed surfaces of stainless steel may have a mill finish and exposed surfaces shall have one of the following finishes, as selected from table I:

(a) Bowl and fountains with metal sides, No. 4 general polished finish.
(b) Bowl and fountains with metal sides, No. 6 soft satin finish.
(c) Bowl with No. 7 highly reflective finish and sides with baked-on enamel.
(d) Bowl, No. 7 finish, fountains with sides clad with polyvinyl chloride.

3.7.2 Aluminum alloys, plastics, and masonry. Aluminum shall have a clear or colored anodic coat, as selected from table I. Finish of plastic and masonry fountains shall be at the manufacturer's option.

3.7.3 Cast iron and carbon steel, pedestal fountains. Cast iron and carbon steel shall be painted, or zinc coated, as selected from table I. Paint shall include a primer and baked on enamel. Total thickness of paint shall be 1 mil (0.001 inch) or greater (see 4.4.2). Weight of zinc coat shall be 1/2 ounce per square foot or greater (see 4.4.3).

3.7.4 Supply. Exposed metallic supply shall be chromium plated with a bright finish. Exposed plastic supply shall be chromium plated with a bright or satin finish. Concealed supply shall be chromium plated, or uncoated at the manufacturer's option.

3.7.5 Metallic drain and trap. Exposed drain and trap shall be chromium plated. Concealed drain and trap shall be chromium plated or uncoated at the manufacturer's option.

3.7.6 Plastic drain and trap. Exposed drain and trap shall be chromium plated with a bright or satin finish. Concealed drain and trap shall be chromium plated, or uncoated at the manufacturer's option.

3.8 Performance.

3.8.1 Endurance, bubblers. Bubblers shall operate satisfactorily and shall not leak in the off position when tested in accordance with 4.4.4.

3.9 Workmanship. All components and surfaces shall be free of chips, cracks, laminations, burrs, and sharp edges. There shall be no cavities in fountains containing aggregate.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection (see WW-P-541/GEN.)

4.2 Sampling for examination and tests. In accordance with WW-P-541/GEN, and as specified herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

4.3 Examination and tests.

4.3.1 Examination. Examine drinking fountains selected in accordance with 4.2 for the defects listed in table II. Inspection level shall be as specified in WW-P-541/GEN. The Acceptable Quality Level (AQL) shall be 2.5 percent defective for major defects and 4.0 for minor defects.

TABLE II. Classification of defects, end item.

Defects	Major	Minor
Type not as specified.	X	
Material not as specified.	X	
Valve control not as specified.		X
Glass filler not included when required.		X
Dimensions not as specified.	X	
Finish of fountains not as specified.	X	
Columns of steel and cast iron pedestal fountains not painted or zinc coated.		X
Chips and cracks in vitreous china and enameled cast iron fountains.	X	
Cavities or loose aggregate in masonry fountains and plastic fountains containing aggregate.		X
Cracks in cast iron columns and pedestals.	X	
Cracks and laminations in steel columns of pedestal fountains and stainless steel parts of fountains.	X	
Cracks in plastic fountains.	X	
Damage or defects affecting function or serviceability.	X	
Damage or defects not affecting function or serviceability.		X

4.3.2 Tests. Samples selected in accordance with 4.2 shall be tested as specified in WW-P-541/GEN and as specified herein. The inspection level and AQL for tests shall be as specified in WW-P-541/GEN.

4.4 Test methods.

4.4.1 Orifice height. Place straight edge across flood rim of bowl or flood bowl. Measure height of orifice above bottom of straight edge or flood plane for conformance to 3.3.3.1.

4.4.2 Thickness of paint. Determine total thickness of paint in accordance with ASTM E376 (see 3.7.3).

4.4.3 Weight of zinc coat. Determine weight of zinc coat on the column in ASTM A90 or E376 (see 3.7.3).

4.4.4 Endurance test.

4.4.4.1 Frequency of test. Unless otherwise specified (see 6.1), tests shall be performed on the initial inspection, and thereafter only when changes are made in the material.

4.4.4.2 Test. Open bubblers at a rate of 1100 to 1500 cycles per hour for a period of 24 hours with water at 20 to 30 pounds per square inch gage pressure. Regulate water temperature 60° to 70°F. After completion of the test determine whether the bubbler operates satisfactorily (see 3.8.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.

5. PREPARATION FOR DELIVERY (see WW-P-541/GEN).

6. NOTES

6.1 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Definitive part number (see 1.2.2).
(c) Frequency of test, if different (see 4.4.4.1).

6.2 Color. Color of fountains may vary from one manufacturer to another. Purchasers shall specify desired color in the contract document.

6.3 Installation. Vandal-resistant, handicapped, and freeze-resistant installations are controlled by the installer and shall be as specified in the contract document.

6.4 Example of DPN:

DPN characteristics WWP541/6 D08315c

Plumbing fixture (fountains)

SPN - type, style, and class of fountain (see table I)

MILITARY CUSTODIANS:

Army - ME
Navy - YD
Air Force - 99

Review activity:

DLA - CS

User activities:

Army - CE
Navy - MC, MS

CIVIL AGENCY COORDINATING ACTIVITIES:

DOE - AEC
GSA - FSS
HUD - TCS

Preparing activity:

Navy - YD

Project No. 4510-0171-6

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:23Z
Check the source to verify that this is the current version before use.