A-A-2245
July 25, 1984

COMMERCIAL ITEM DESCRIPTION

HOSE ASSEMBLY, NONMETALLIC (Standpipes; Rack & Reel)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification JJ-H-571, Style B.

This description covers coupled fire hoses, with or without nozzles, for fire protection use only. It is for installation at inside standpipes and rack and reel applications only. Hoses shall be furnished in the following types, as specified.

Type	Inside Hose Diameter (Minimum) (inches)	Thread Size and Series	Length (feet)	Nozzle
A	1-1/2	1-1/2 x 9 NH	50	No
B	1-1/2	1-1/2 x 9 NH	75	Yes
C	1-1/2	1-1/2 x 9 NH	100	Yes
D	1-1/2	1-1/2 x 11-1/2 NPSH	50	No

Salient characteristics.

Configuration - The hose assembly shall consist of a hose section fitted with one male coupling, one female coupling, and if specified, one nozzle.

Hose - The hose shall be single-jacketed and made from cotton threads, synthetic threads, or a combination of both. The lining shall be made of rubber, plastic, or rubber/plastic compounds of uniform thickness. The hose shall replace linen hoses on a foot for foot basis.

Coupling - One threaded male piece with expansion ring and one female piece with swivel section and expansion ring shall be provided. Couplings shall be furnished with rocker lugs. Couplings shall be made of either brass or hardcoated aluminum, as specified.

Nozzle - The nozzle shall produce a variable water pattern from shut-off to straight stream through fog to a heat shield and shall meet the requirements of UL Standard 401.

Proof (test) Pressure - 500 psi

FSC 4210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

Kink Test Pressure - 400 psi

Burst Pressure - 750 psi

Conformance. Hose shall meet or exceed the requirements of Underwriters Laboratories (UL) Standard 219. The issue in effect on the date of the solicitation shall be used to determine compliance with this requirement.

Workmanship. Hose assembly shall be free from the defects defined in UL 219 and shall also be free of those defects which may affect the durability, appearance, or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking (GSA). The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preservation, packaging, packing, labeling, and marking (DoD). Military packaging shall be as specified when shipments are to be overseas Department of Defense (DoD) consignees. Commerical packaging may be specified for shipments to DoD consignees within the continental United States and to non-DoD consignees worldwide. When a supplier's normal packaging will satisfy the requirements for military packaging, it may be used.

Military packaging. Each hose shall be preserved and packed to protect it against physical damage and deterioration in a logistic environment characterized by the following:

1. Multiple handling during transportation and intransit storage.
2. Shock, vibration, and static loading forces during worldwide shipment by all transport modes.
3. Uncontrolled warehouse storage for extended periods.
4. Weather exposure during shipment and intransit transfers.
5. Stacking loads during shipment and storage.

Quantities of hose destined for a single addressee may be unitized into one or more loads.

Commercial. Each hose shall be packaged in accordance with the supplier's normal method of retail distribution. Hoses shipped to a single destination may be unitized to handling as a single unit.

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:20Z
Check the source to verify that this is the current version before use.

Shipping containers shall comply with Uniform Freight Classification or National Motor Freight Classification rules.

Marking. Unit, intermediate (when provided), and exterior packs shall be marked with the item nomenclature, stock or part number, quantity per pack, and contract number as a minimum; additional marking shall be as specified in the contract or order. Exterior packs shall have in addition the complete consignee's address. Markings shall be applied in a legible manner, in a contrasting color, of an appropriate size and of waterproof materials.

Notes. Users should select the options permitted by this document and should specify the following in the contract or purchase documents:

a) Type hose assembly required.
b) If specific coupling material is required.

When this commercial item description is used for procurement the commerical item certification clause must appear in the solicitation.

UL Standards are available from Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062.

MILITARY INTERESTS:

Review Activity
Army - MI

Custodian
Air Force - 99

PREPARING ACTIVITY:
GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.