NOTICE OF VALIDATION

INCH-POUND

MIL-P-24395/1B
NOTICE 3
23-Feb-2021

DETAIL SPECIFICATION

Panel, Ground ANEL, GROUND DETECTOR, 120 VOLTDetector, 120 Volts (Symbol 1005.1) and 450 Volts (Symbol 1005.2) Alternating Current, Three Phase, 60 or 400 Hertz, Dripproof

MIL-P-24395/1B, dated 10-May-2005, has been reviewed and determined to be valid for use in acquisition.

Custodians:
Navy - SH
Air Force - 99

Preparing Activity:
Navy - SH

Reviewer Activities:
DLA - GS

NOTE: The activities above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil.

AMSC N/A **FSC 6110**

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T21:45Z
Check the source to verify that this is the current version before use.