MILITARY SPECIFICATION

GENERATOR SET, DIESEL ENGINE DRIVEN
200 KILOWATT, 50/60 HERTZ, PRECISE, (TACTICAL)

This amendment forms a part of Military Specification MIL-G-52884/13, dated 10 December 1975, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 2

Delete paragraph 3.6.4 as written, and substitute:

"3.6.4 Transient performance. Following a sudden increase or decrease in load up to and including 50 percent rated load, the governing system shall re-establish stable engine operating conditions in 1 second. The maximum transient frequency change above or below the new steady state frequency shall be not more than 1.5 percent of rated frequency for any such load change. In addition, the circuit interrupter shall not trip when going from no load to rated load or rated load to no load with the Battle Short Switch in the normal (OFF) position."

Custodians:
Army - ME
Navy - YD
Air Force - 99

Review activity:
DLA - GS

Preparing activity:
Army - ME

Project 6115-0211

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:38Z
Check the source to verify that this is the current version before use.