INCH-POUND
MIL-P-23928/1B(SH)
5 December 1988
SUPERSEDING
MIL-P-23928/1A(SHIPS)
11 May 1979

MILITARY SPECIFICATION SHEET

PANEL, ELECTRICAL, 125 VOLTS, POWER DISTRIBUTION FOR ALB-1 AND NLB-1 CIRCUIT BREAKERS, 4-20 CIRCUITS, DRIPPROOF, TOTALLY ENCLOSED AND WATERTIGHT

This specification sheet is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and the issue of the following specification listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation: MIL-P-23928(SH).




FIGURE 1. Distribution panel for ALB-1 and NLB-1 circuit breakers, totally enclosed and dripproof enclosure (typical).

AMSC N/A FSC 5925

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:19Z
Check the source to verify that this is the current version before use.





FIGURE 2. Distribution panel for ALB-1 and NLB-1 circuit breakers watertight enclosure (typical).


Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:19Z
Check the source to verify that this is the current version before use.



NO. OF CIRCUITS	DIMENSIONS (INCHES)					MOUNTING HOLES PER SIDE
	A	B	C	D	E	
4–16 OR 2–36	18.00	–	9.25	4.86	–	2
6–16 OR 4–36	22.50	4.63	9.25	6.63	–	3
8–16 OR 6–36	25.50	4.63	9.25	8.13	–	
12–16 OR 8–36	28.50	6.00	12.00	8.25	–	
14–16 OR 10–36	31.50	6.50	13.00	6.00	19.50	4
18–16 OR 12–36	34.50	6.50	13.00	7.50	19.50	
20–16 OR 14–36	37.50	6.50	13.00	9.00	19.50	
24–16 OR 16–36	40.50	11.25	22.50	9.00	33.75	

FIGURE 3. Panel and mounting dimensions.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:19Z
Check the source to verify that this is the current version before use.



SH13231810


FIGURE 4. Wiring diagrams, front view (typical).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:19Z
Check the source to verify that this is the current version before use.

TABLE I. Part or identifying numbers (PIN's).

Dash number	Number of circuits		Symbol number and enclosure type			Current rating (amperes)
	1ø	3ø	Dripproof (DP)	Totally enclosed (TE)	Watertight (WT)	
01	6		994.4	994.5	994.6	200
02	8		995.4	995.5	995.6	300
03	12		999.4	999.5	999.6	400
04	14		1006	1006.1	1006.2	400
05	18		1007	1007.1	1007.2	400
06	26		1008	1008.1	1008.2	400
11		4	1009	1009.1	1009.2	200
12		6	1010	1010.1	1010.2	300
13		8	1011	1011.1	1011.2	400
14		10	1012	1012.1	1012.2	400
15		12	1013	1013.1	1013.2	400
16		14	1014	1014.1	1014.2	400

Example: The full PIN for a watertight, 9-circuit, single phase panel is:



REQUIREMENTS:

Class: 1 - Dripproof (see note 1).
Class: 2 - Totally enclosed (see note 2).
Class: 3 - Watertight (see note 3).
Dimensions and configuration: See figures.
Composition: See table I.
Current rating: See table I.
Voltage rating: 125 Vac and Vdc.
Short circuit capacity: 50,000 amperes.
Bus bar size: 1 x 0.250 inch.
Bus bar feeder connection: Top and bottom.
Circuit breakers: ALB-1 and NLB-1 (see MIL-C-17588).

Source: https://assist.dla.mil -- Downloaded: 202610-19T18:19Z
Check the source to verify that this is the current version before use.

NOTES:

1. Class 1 panels with doors shall meet the 45 degree dripproof requirements, and panels without doors shall meet the 15 degree dripproof requirements in accordance with MIL-STD-108. When used, drip shield dimensions shall be as required to provide the specified degree of enclosure. Panels shall be furnished without doors only when specified in acquisition documents.
2. Class 2 panels shall meet the totally enclosed requirements in accordance with MIL-STD-108. Panels shall be furnished without doors only when specified in acquisition documents.
3. Class 3 panels, with doors, gaskets, and drain opening, shall meet the watertight requirements in accordance with MIL-STD-108.
4. The following types of circuit breaker mounting bases may be installed:
   (a) Single phase (1ø):
   Type A (see MIL-C-17588)-four breakers, 2 circuit base, ØAB or ØBC.
   Type B (see MIL-C-17588)-four breakers, 2 circuit base, ØAC.
   Type 3ø mounting base-six breakers.
   (b) Three phase (3ø):
   Type 3ø mounting base-six breakers.
5. When a combination of 1ø and 3ø circuits are required, the number of each type circuit shall be specified in the acquisition document.
6. Panels shall be provided with a retaining device to hold all circuit breakers in place when the shield is removed.
7. Panels shall be of aluminum construction unless steel is specified in the acquisition documents.
8. Panels shall be furnished with mounting blocks.

Revision letters are not used to denote changes due to the extensiveness of the changes.

Preparing activity:
Navy - SH
(Project 5925-N118-01)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T18:19Z
Check the source to verify that this is the current version before use.