INCH-POUND

A-A-59417
15 December 2003

COMMERCIAL ITEM DESCRIPTION
THERMAL IMAGING SYSTEM

The General Services Administration has authorized the use of the Commercial Item Description (CID) for all federal agencies.

1. SCOPE. This Commercial Item Description (CID), describes a portable Thermal Imaging System (TIS). This CID is intended as a minimum requirement for the Thermal Imaging System in which only those manufacturers that meet or surpass the following requirements are supplied per this CID.

2. SALIENT CHARACTERISTICS

2.1 Performance. The TIS shall be waterproof and must be capable of operating in temperatures up to 625 degrees Fahrenheit for short periods of time (5 minutes minimum). The TIS shall have a liquid crystal display (LCD) for easy viewing. The TIS shall be capable of detecting individuals, hot spots, and electrical systems. The TIS shall allow personnel using it the ability to see through smoke, fog, or any other low visibility condition. The TIS shall have the capability of transmitting information to a remote location. The TIS shall have an ergonomic and durable design. A waterproof carrying case that can also withstand 625 degrees Fahrenheit temperatures shall be included with the TIS. The TIS shall capture a field of view of not less than 50 degrees. The TIS must remain fully operational if it is immersed in water (3 feet of water minimum) or is exposed to high temperatures (Up to 625 degrees Fahrenheit for a minimum of 5 minutes). The LCD should maintain a clear resolution when subjected to the aforementioned circumstances.

2.2 Operation. The control buttons on the TIS should be easy to access. All features necessary for operation should be clearly marked. The TIS should not require more than one person for operation.

2.3 Electrical Power Source. The TIS shall operate off of a rechargeable battery. The rechargeable battery needs to supply the TIS power for a minimum operating time of 1 hour.

2.4 Temperature Sensitivity. The TIS shall be capable of detecting variances in temperature in increments of 0.4 degrees Fahrenheit maximum.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data that may improve this document should be sent to: WR-ALC/LEEE, 420 Second Street, Suite 100, Robins AFB, GA 31098-1640.

AMSC N/A FSC 5855

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:13Z
Check the source to verify that this is the current version before use.

2.5 Dimensions and Weight. The size and weight of the equipment shall be consistent with current commercial capabilities.

2.6 Durability. The TIS shall have a sturdy design. The TIS shall meet all operational requirements if it is exposed to water or if it is dropped from waist level (approximately 3.5 feet).

3. REGULATORY REQUIREMENTS. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

4. PRODUCT CONFORMANCE. The products provided shall meet the salient characteristics of this CID, conform to the producer's own drawings, specifications, standards and quality assurance practices, and be the same product offered for sale in the commercial marketplace. Small businesses that cannot offer products with established commercial market acceptability may compete by submission of bid samples. The government reserves the right to require proof of such conformance.

5. PACKAGING. Preservation, packing, and marking shall be as specified in the contract or order.

6. NOTES.

6.1 Sources of documents.

6.1.1 Federal Acquisition Regulations (FAR). FAR. para. 23.403-Federal Acquisition Regulation (Application for copies should be addressed to the U.S. Government Printing Office, North Capitol and H streets NW, Washington. DC 20402.)

6.2 Known NSNs. NSN 5855-01-485-3429

MILITARY INTEREST

Custodian:
Air Force – 99

Preparing activity:
Air Force - 84

Agent:
Air Force – 99

Project Number - 5855-0228

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:13Z
Check the source to verify that this is the current version before use.