W-F-1726/GEN
June 11, 1973
SUPERSEDING
W-F-791d (IN PART)
November 27, 1963
(See 6.5)

FEDERAL SPECIFICATION

FUSE, CARTRIDGE, CLASS H

(GENERAL SPECIFICATION)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers class H, cartridge enclosed, renewable (see 6.3.5) and nonrenewable (see 6.3.4) fuses rated at 250 and 600 volts, 600 amperes or less. These fuses are not current-limiting (see 6.3.1) and do not have a specified interrupt rating.

1.2 Classification. Fuses furnished under this specification shall be of the following types, as specified (see 3.1):

Nonrenewable, 250 volt, 0-600 amperes.
Nonrenewable, 600 volt, 0-600 amperes.
Renewable, 250 volt, 0-600 amperes.
Renewable, 600 volt, 0-600 amperes.

2. APPLICABLE DOCUMENTS

2.1 Specifications and standards. The following documents, of the issue in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein.

Federal Specifications:

J-C-30	- Cable and Wire, Electrical (Power, Fixed Installation).
L-P-513	- Plastic Sheet, Laminated, Thermosetting, Paper-base, Phenolic-resin.
W-F-870	- Fuseholder (For Plug and Enclosed Cartridge Fuses).
NN-P-71	- Pallet, Materials-handling, Wood Double Faced, Stringer Construction.
QQ-B-613	- Brass, Leaded and Non-Leaded; Flat Products (Plate, Bar, Sheet, and Strip).
QQ-B-626	- Brass, Leaded and Non-Leaded; Rod, Shapes, Forgings, and Flat Products with Finished Edges (Bar and Strip).
QQ-B-750	- Bronze, Phosphor, Bar, Plate, Rod, Sheet, Strip, Flat Wire, and Structural and Special Shaped Sections.
QQ-C-576	- Copper Flat Products with Slit, Slit and Edge-Rolled, Sheared, Sawed, or Machined Edges, (Plate, Bar, Sheet, and Strip).
QQ-S-781	- Strapping, Steel, Flat and Seals.
PPP-B-566	- Boxes, Folding, Paperboard.
PPP-B-585	- Boxes, Wood, Wirebound.
PPP-B-601	- Boxes, Wood, Cleated-Plywood.
PPP-B-621	- Boxes, Wood, Nailed and Lock-Corner.
PPP-B-636	- Boxes, Shipping, Fiberboard.
PPP-B-676	- Boxes, Setup.
PPP-T-60	- Tape; Pressure-Sensitive Adhesive, Waterproof, for Packaging.
PPP-T-76	- Tape, Pressure-Sensitive Adhesive Paper (For Carton Sealing).

(See supplement 1 for list of applicable detail specifications.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

Federal Standard:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U. S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal Specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Washington, DC, Atlanta, Chicago, Kansas City, MO, Fort Worth, Denver, San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Specifications:

MIL-I-10	- Insulating Materials, Electrical, Ceramic, Class L.
MIL-P-79	- Plastic Rod and Tube, Thermosetting, Laminated.
MIL-P-116	- Preservation, Methods of.
MIL-F-1148	- Fiber, Vulcanized, Electrical and Mechanical Grades.
MIL-F-14256	- Flux, Soldering, Liquid (Rosin Base).
MIL-P-15037	- Plastic Sheet, Laminated, Thermosetting, Glass-Cloth, Melamine-Resin.
MIL-I-16923	- Insulating Compound, Electrical, Embedding.
MIL-C-21768	- Copper Alloys Numbers 210 (Gilding, 95%) and 220 (Commercial Bronze, 90%) Sheet and Strip.
MIL-B-43014	- Boxes: Water Resistant Paperboard, Folding, Set-up, and Metal-stayed.
MIL-C-45662	- Calibration System Requirements.

Military Standards:

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-147	- Palletized Unit Loads on 40" x 48" Pallets.
MIL-STD-202	- Test Methods for Electronic and Electrical Component Parts.

(Copies of Military Specifications and Standards, required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following document forms a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

Underwriters' Laboratories, Inc. (UL) Standard:

UL198	- Standard for Fuses.

(Applications for copies should be addressed to the Underwriters' Laboratories, Inc., Walt Whitman Road, Melville, NY 11746; 207 E. Ohio Street, Chicago, IL 60611; and 1655 Scott Blvd., Santa Clara, CA 95050).

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

3. REQUIREMENTS

3.1 Specification sheets. The individual item requirements shall be as specified herein and in accordance with the applicable specification sheet. In the event of any conflict between this specification and the specification sheet, the latter shall govern.

3.1.1 Fuse ratings not listed in specification sheets. This specification shall be applicable to other fuse ratings, provided the desired ratings fall within the maximum and minimum current and voltage ratings specified by the applicable specification sheet.

3.2 Qualification. Fuses furnished under this specification shall be products which are qualified for listing on the applicable qualified products list at the time set for opening of bids (see 4.5 and 6.4).

3.3 Material. The material for each part shall be as specified herein. However, when a definite material is not specified, a material shall be used which will enable the fuses to meet the performance requirements of this specification. Acceptance or approval of any constituent material shall not be construed as a guaranty of the acceptance of the finished product.

3.3.1 Restricted material. Flammable or explosive material, or material which can produce toxic or suffocating fumes when the fuses are in service shall not be used in construction of the fuses.

3.3.2 Enclosure. Fuses shall have a suitable enclosure which shall prevent lint and dust collecting near the fusible link and thus becoming ignited during overload and short circuit interrupt tests.

3.3.3 Soldering fluxes. When soldering fluxes are used, they shall conform to the requirements of MIL-F-14256.

3.3.4 Case or body. The tube shall be of glass, hard fiber, ceramic, or melamine-impregnated glass fiber as specified (see 3.1). Other material may be used provided the fuse is capable of meeting the requirements of 3.7.

3.3.4.1 Glass. Glass shall be of high quality, free from strain, and sufficiently clear to permit the enclosed fuse element to be readily seen.

3.3.4.2 Fiber. Fiber shall conform to grade CH, form T, of MIL-F-1148.

3.3.4.3 Plastic. Unless otherwise specified (see 3.1), any plastic insulation may be used, except that cotton-base or cotton- or cellulose-filled molding material shall not be used. Laminated plastic sheets, type PBE-P or GMG, conforming to L-P-513 and MIL-P-15037, respectively and laminated tubes, type PBE, PBG, or GMG, form Tr, conforming to MIL-P-79 shall be acceptable.

3.3.4.4 Ceramic. Ceramic insulation shall be grade L311 or higher grade, in accordance with MIL-I-10.

3.3.4.5 Epoxy. Epoxy encapsulant compound shall conform to type B of MIL-I-16923.

3.3.4.6 Current-carrying parts (except fuse element). Current carrying parts shall be of brass, copper, phosphor bronze, or copper alloy conforming to QQ-B-613 or QQ-B-626, QQ-C-576, QQ-B-750, and MIL-C-21768, respectively.

3.3.4.7 Noncurrent-carrying parts. All metal noncurrent-carrying parts shall be corrosion resistant material or of material adequately protected against corrosion.

3.4 Design and construction. Fuses shall be of a design, construction, and physical dimensions as specified (see 3.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

3.4.1 Mounting. Unless otherwise specified (see 3.1) the fuse shall be designed to permit convenient insertion and removal from the fuseholders without the use of special tools.

3.4.2 Terminals. Terminals shall be secured to the fuse body so that they shall not loosen. The fuse element shall be so attached to the terminals that there shall be no danger of breaking the fuse element or connections when installing the fuse. Fuses with knife blade terminals shall be aligned so that their planes are within 4° of each other. The alignment shall be ensured by means other than friction.

3.4.3 Ferrule alignment. Fuses with ferrule terminals shall pass through a tubular gage having a length equal to that of the fuse. The tubular gage shall have an internal diameter as specified (see 3.1).

3.4.4 Terminal strength. Fuse terminals shall not loosen or become damaged when tested as specified in 4.7.2.

3.5 Current carrying capacity. Fuses shall carry the specified percentage of current indefinitely (see 3.1) when tested as specified in 4.7.3. The temperature of the body shall at no point rise more than the amount specified (see 3.1).

3.6 Overload interrupt (see 6.3.3). Fuses shall open the circuit within the time as specified (see 3.1) without causing the case or body to char, fracture, or otherwise sustain physical damage when tested as specified in 4.7.4. Time delay (see 6.3.2) or dual element fuses shall not open the circuit faster than specified (see 3.1).

3.7 Short circuit interrupt. Fuses shall remain intact and shall open the circuit without excessive arcing when tested as specified in 4.7.5. Expulsion of molten metal or emission of sufficient flame to ignite surgical cotton surrounding the case is not acceptable.

3.8 Marking. Fuses shall be marked in a manner which will be plainly visible after the fuse has been installed in a standard fuseholder. The marking shall include the following:

(a) Manufacturer's part number, government part number, or both.
(b) Manufacturer's name, code, or trademark.
(c) Current rating in amperes.
(d) Voltage rating - followed by the words "or less".
(e) If a label type of marking is utilized, the current rating shall be permanently marked on the body or ferrules. (This applies to nonrenewable fuses only).
(f) Renewable fuses shall include the word "Renewable" in the marking.
(g) Dual element or time delay fuses shall be marked with the words "Time delay" or the symbol "D".

The voltage and current ratings shall be in bold face numerals not less than 3/32 inch high.

3.8.1 Underwriters' Listing Mark. Fuses which conform to UL198 (see 4.5(b)) shall have the listing mark on each fuse such that it is visible after the fuse is installed in a fuseholder.

3.9 Workmanship. Fuses shall be manufactured and processed in such a manner as to be uniform in quality and shall be free from loose terminals, cracked, or displaced parts, sharp edges, burrs, and other defects that will affect life, serviceability, or appearance.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of the inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

4.1.1 Test equipment and inspection facilities. The manufacturer shall provide the required test equipment and facilities for conducting all tests which are to be made at the factory. Meters shall be of 1-percent accuracy and regularly calibrated (see UL198). Compliance with the requirements of MIL-C-45662 shall be acceptable.

4.2 Classification of inspection. The inspections specified herein are classified as follows:

(a) Qualification inspection (see 4.5).
(b) Quality conformance inspection (see 4.6).

4.3 Inspection of materials and components. In accordance with 4.1, the supplier is responsible for insuring that materials and components used were manufactured, tested, and inspected in accordance with the requirements of this specification and of referenced subsidiary specifications and standards to the extent specified, or if none, in accordance with this specification (see 3.3).

4.4 Inspection conditions. All inspections, examinations, and tests shall be performed in accordance with the applicable conditions specified in UL198 which pertain to cartridge fuses.

4.5 Qualification inspection. Qualification may be obtained by either of the following:

(a) By testing the fuses in accordance with paragraph 4.5.1.
(b) By having Underwriters' Laboratories listing, per UL198. Manufacturers electing this option shall submit a letter of certification to the qualifying activity listing the Underwriters' file number, the government part number, and the manufacturers part for each fuse rating for which qualification is desired.

4.5.1 Inspection routine (applicable to 4.5 (a) only). Fuses shall be subjected to the inspection specified in table I, in the order shown. Sample size, character of failures and number of failures permitted shall be as specified for cartridge fuses in UL198.

TABLE I. Qualification inspection

Examination or test	Requirement paragraph	Method paragraph
Group I		
Visual and mechanical examination - -	3.1 thru 3.4.3, 3.8 and 3.9	4.7.1
Terminal strength - - - - - - - - - - -	3.4.4	4.7.2
Current carrying capacity- - - - - - -	3.5	4.7.3
Overload interrupt- - - - - - - - - - -	3.6	4.7.4
Group II		
Short circuit interrupt- - - - - - - -	3.7	4.7.5

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

4.5.2 Retention of qualification. To retain qualification, the supplier shall utilize the applicable procedures as follows:

(a) Those suppliers that used the inspection requirements of 4.5.1 to obtain qualification shall forward a report at 12-month intervals to the qualifying activity. The qualifying activity shall establish the initial reporting date. The report shall consist of:

(1) A summary of the results of tests performed for inspection of product for delivery, groups A and B, indicating as a minimum the number of lots that have passed and the number that have failed. The results of tests of all reworked lots shall be identified and accounted for.
(2) A summary of the results of tests performed for qualification verification inspection, group C, including the number and mode of failures. The summary shall include results of all qualification verification inspection tests performed and completed during the 12-month period. If the summary of the test results indicates nonconformance with specification requirements, and corrective action acceptable to the qualifying activity has not been taken, action may be taken to remove the failing product from the qualified products list.

Failure to submit the report within 30 days after the end of each 12-month period may result in loss of qualification for the product. In addition to the periodic submission of inspection data, the supplier shall immediately notify the qualifying activity at any time during the 12-month period that the inspection data indicates failure of the qualified products to meet the requirements of this specification.

In the event that no production occurred during the reporting period, a report shall be submitted certifying that the company still has the capabilities and facilities necessary to produce the items. If during two consecutive reporting periods there has been no production, the manufacturer may be required, at the discretion of the qualifying activity, to submit a representative product of each style, voltage rating, and current rating to testing in accordance with the qualification inspection requirements.

(b) Those suppliers that used the Underwriters' Laboratories Listing Mark to obtain qualification shall submit certification that the qualified fuses retain the UL Listing Mark, at 12-month intervals, to the qualifying activity. The initial reporting date shall be established by the qualifying activity.

Failure to submit the above within 30 days after the end of each 12-month period may result in loss of qualification for the product. Suppliers shall notify the qualifying activity immediately of inspection data that indicates failure of the product to meet the requirements of UL198.

4.6 Quality conformance inspection. Quality conformance inspection shall consist of groups A, B, and C inspections as specified herein, or certification of compliance with the Follow-up Service of Underwriters' Laboratories, Inc. (see 4.5.2).

4.6.1 Inspection of product for delivery. Inspection of product for delivery shall consist of groups A and B inspections.

4.6.1.1 Inspection lot. An inspection lot shall consist of all fuses of the same style and current rating produced under essentially the same conditions, and offered for inspection at one time.

4.6.1.2 Group A inspection. Group A inspection shall consist of the visual and mechanical examination (see 3.4, 3.8, 3.9, and 4.7.1).

4.6.1.2.1 Sampling plan. Statistical sampling and inspection shall be in accordance with MIL-STD-105 for general inspection level II. The acceptable quality level (AQL) shall be 2.5 and 4.0 percent defective for major and minor defects, respectively. Major and minor defects shall be as defined in MIL-STD-105.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

4.6.1.2.2 Rejected lots. If an inspection lot is rejected, the supplier may rework it to correct the defects, or screen out the defective units, and resubmit for reinspection. Resubmitted lots shall be inspected using tightened inspection. Such lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.6.1.3 Group B inspection. Group B inspection shall consist of the tests specified in table II, in the order shown and shall be made on sample units which have been subjected to and have passed the group A inspection.

4.6.1.3.1 Sampling plan. Sampling for group B inspection shall be in accordance with MIL-STD-105, inspection level S-4. The AQL shall be 6.5 percent defective.

4.6.1.3.2 Rejected lots. If an inspection lot is rejected, the supplier may rework it to correct the defects, or screen out the defective units, and resubmit for reinspection. Resubmitted lots shall be inspected using tightened inspection. Such lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.6.1.3.3 Disposition of sample units. Sample units subjected to group B inspection shall not be delivered on the contract or order.

TABLE II. Group B inspection

Test	Requirement paragraph	Method paragraph
Terminal strength - - - - - - - - - -	3.4.4	4.7.2
Current-carrying capacity - - - - - -	3.5	4.7.3
Overload interrupt - - - - - - - - - -	3.6	4.7.4

4.6.2 Qualification verification inspection. Qualification verification inspection shall consist of group C. Except where the results of this inspection show noncompliance with the applicable requirement (see 4.6.2.1.4), delivery of products which have passed groups A and B shall not be delayed pending the results of this qualification verification inspection.

4.6.2.1 Group C inspection. Group C inspection shall consist of the short circuit interrupt test (see 3.7 and 4.7.5). Group C inspection shall be made on sample units selected from lots which have passed the groups A and B inspections, unless the Government considers it more practical to select a sample from current production. A manufacturer's normal quality control and production tests may be used to fulfill group C inspection.

4.6.2.1.1 Sampling plan. Samples shall be selected at random. Fifteen each of the maximum and minimum ratings shall be selected from those covered on a single specification sheet, 12 months after the date of notification of qualification and after each subsequent 12-month period.

4.6.2.1.2 Failures. If one or more sample units fail to pass group C inspection, the sample shall be considered to have failed.

4.6.2.1.3 Disposition of sample units. Sample units which have been subjected to group C inspection shall not be delivered on the contract or order.

4.6.2.1.4 Noncompliance. If a sample fails to pass group C inspection, the supplier shall take corrective action on the materials or processes, or both, as warranted, and on all units of product which can be corrected and which were manufactured under essentially the same conditions with essentially the same materials, processes, etc., and which are considered subject to the same failure. Acceptance of the product shall be discontinued until corrective action, acceptable to the Government, has been taken. After the corrective action has been taken, group C inspection shall be repeated on additional sample units (all inspection, or the inspection which the original sample failed at the option of the Government). Groups A and B inspections may be reinstituted, however, final acceptance shall be withheld until group C reinspection has shown that the corrective action

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

was successful. In the event of failure after reinspection, information concerning the failure and the corrective action taken shall be furnished to the cognizant inspection activity and the qualifying activity.

4.6.3 Inspection of preparation for delivery. The sampling and inspection of the preservation-packaging and interior package marking shall be in accordance with the groups A and B quality conformance inspection requirements of MIL-P-116. The sampling and inspection of the packing and marking for shipment and storage shall be in accordance with the quality assurance provisions of the applicable container specification and the marking requirements of MIL-STD-129.

4.7 Methods of examination and test.

4.7.1 Visual and mechanical examination. Fuses shall be examined to verify that the material, design and construction, physical dimensions, marking, and workmanship are in accordance with applicable requirements (see 3.1 through 3.4.3 and 3.8 through 3.9).

4.7.2 Terminal strength (see 3.4.4). Terminals shall be tested in accordance with method 211, of MIL-STD-202, test condition E. Torque shall be as specified (see 3.1).

4.7.3 Current carrying capacity (see 3.5). Fuses shall be subjected to an alternating current at the specified percentage of rated current (see 3.1). The power supply shall be capable of delivering a current of no less than 200 percent of the specified rating of the fuse being tested. The current shall be maintained until the temperature has stabilized. It may be assumed that the temperature has stabilized when three successive temperature readings, taken at 5-minute intervals, indicate no increased rise above the temperature of the ambient air. The temperature of the fuse case or body and of the terminals shall be measured by thermocouples (wire size 28 to 32 AWG) or by using the standard thermometer method. The test shall be conducted with the ambient temperature within 18° to 32°C (65° to 90°F) provided the air temperature does not vary more than 5°C (9°F) during the test. Each fuse shall be mounted in a single pole fuseholder in accordance with W-F-870. When two or more fuses are tested in series, the fuseholders shall be located so that there will be a spacing of not less than 6 inches between any two fuses, and there shall be 2 feet of wire between each fuse. The wire connecting the fuseholders, ammeter, and the source of supply shall be in accordance with J-C-30 and shall be the size specified in table III. For a fuse rated at more than 60 amperes, "C" clamps or suitable clip clamps shall be used to insure adequate contact. "C" clamps shall be of iron or steel, weighing not more than 3 ounces. Neither face of the clamp in contact with the fuseholder terminals shall have an area exceeding 1/2 square inch. For fuses rated at less than 60 amperes, a pressure-type fuseholder shall be used to insure adequate contact between the clips and the ferrules of the fuse.

TABLE III. Wire test leads

Fuse rating in amperes	Wire	
	Length in feet 1/	Size 2/
0-30	2	8 AWG
31-60	2	4
61-100	2	1
101-200	2	4/0
201-400	4	500 MCM
401-600	4	1,000

1/ Any connection to the source of supply shall be not less than 4 feet.

2/ Connections larger than 8 AWG shall employ a suitable soldering lug or pressure wire connector.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

4.7.4 Overload interrupt (see 3.6). Single element fuses (see 6.3.7) shall be subjected to the overloads and open the circuit as specified (see 3.1) using the power supply and test procedures defined in 4.7.3. Dual-element fuses (see 6.3.2) shall be subjected to a 500-percent overload and open the circuit as specified (see 3.1) using a suitable power supply and using the procedures defined in 4.7.3.

4.7.5 Short circuit interrupt (see 3.7). Fuses shall be subjected to an ac short circuit test using a power supply capable of delivering 10,000 amperes (rms symetrical) under short circuit conditions. The open circuit voltage shall be not less than 100 percent of the rated voltage (see 3.1). The power factor of the test circuit shall be 0.85 to 0.95 for fuses rated at 100 amperes or less and 0.45 to 0.50 for fuses rated at more than 100 amperes. The instant of closure shall be at random to the voltage wave. The fuseholder shall be mounted so that the major plane of the fuse is horizontal. When material other than that specified in 3.3.4 is used, the sample group shall be preconditioned in an oven at a temperature of not less than 90°C for not less than 24 hours prior to the short circuit test. A second group of samples shall be preconditioned in still air for 5 days at approximately 25°C and a relative humidity of 95 ±5 percent prior to the short circuit test.

5. PREPARATION FOR DELIVERY

5.1 Preservation-packaging. Preservation-packaging shall be level A or C, as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Cleaning. Fuses shall be cleaned in accordance with MIL-P-116, process C-1.

5.1.1.2 Drying. Fuses shall be dried in accordance with MIL-P-116.

5.1.1.3 Preservative application. Preservatives shall not be used.

5.1.1.4 Unit packaging. Fuses shall be packaged in accordance with MIL-P-116, method III insuring compliance with the general requirements paragraph under methods of preservation (unit protection) and the physical protection requirements paragraph therein. Unless otherwise specified (see 6.2), the quantity per unit package (QUP) shall be five each for fuses with ferrule terminals (0-60 amps.) and one each for fuses with knife blade terminals (61-600 amps.). The unit container shall conform to PPP-B-566 or PPP-B-676.

5.1.1.5 Intermediate packaging. Fuses with ferrule terminals, packaged as described in 5.1.1.4, shall be placed in intermediate containers conforming to PPP-B-566 or PPP-B-676. Intermediate containers shall be uniform in size, shape and quantities, shall be of minimum tare and cube and shall contain multiples of five unit packages, not to exceed 50 unit packages. No intermediate packaging is required for fuses with knife blade terminals or when the total quantity shipped to a single destination is less than 50 unit packages.

5.1.2 Level C. Fuses shall be clean, dry and packaged in a manner that will afford adequate protection against corrosion, deterioration and physical damage during shipment from supply source to the first receiving activity.

5.2 Packing. Packing shall be level A, B or C, as specified (see 6.2).

5.2.1 Level A. The packaged fuses shall be packed in fiberboard containers conforming to PPP-B-636, class weather resistant, style optional, special requirements. In lieu of the closure and waterproofing requirement in the appendix of PPP-B-636, closure and waterproofing shall be accomplished by sealing all seams, corners and manufacturer's joint with tape, two inches minimum width, conforming to PPP-T-60, class 1 or PPP-T-76. Banding (reinforcement requirements) shall be applied in accordance with the appendix to PPP-B-636 using non-metallic or tape banding only.

5.2.2 Level B. The packaged fuses shall be packed in fiberboard containers conforming to PPP-B-636, class domestic, style optional, special requirements. Closures shall be in accordance with method II of the appendix thereto.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

5.2.3 Level C. The packaged fuses shall be packed in shipping containers in a manner that will afford adequate protection against damage during direct shipment from the supply source to the first receiving activity. These packs shall conform to the applicable carrier rules and regulations.

5.2.4 Unitized loads. Unitized loads, commensurate with the level of packing specified in the contract or order, shall be used whenever total quantities for shipment to one destination equal 40 cubic feet or more. Quantities less than 40 cubic feet need not be unitized. Unitized loads shall be uniform in size and quantities to the greatest extent practicable.

5.2.4.1 Level A. Fuses, packed as specified in 5.2.1, shall be unitized on pallets in conformance with MIL-STD-147, load type I, with a fiberboard cap (storage aid 4) positioned over the load.

5.2.4.2 Level B. Fuses, packed as specified in 5.2.2, shall be unitized as specified in 5.2.4.1 except that the fiberboard caps shall be class domestic.

5.2.4.3 Level C. Fuses, packed as specified in 5.2.3, shall be unitized with pallets and caps of the type, size, and kind commonly used for the purpose and shall conform to the applicable carrier rules and regulations.

5.3 Marking. In addition to any special marking required by the contract or purchase order (see 6.2), each unit package, intermediate and exterior container and unitized load shall be marked in accordance with Fed. Std. No. 123 for civil agency procurements and in accordance with MIL-STD-129 for military (DOD) procurements.

5.4 General. Special requirements for Army and Navy procurements are specified in 5.4.2 and 5.4.3, respectively.

5.4.1 Exterior containers. Exterior containers (see 5.2.1, 5.2.2 and 5.2.3) shall be of a minimum tare and cube consistant with the protection required and shall contain equal quantities of identical stock numbered items to the greatest extent practicable.

5.4.2 Army procurements.

5.4.2.1 Level A unit and intermediate packaging. All unit and intermediate containers shall either be weather (or water) resistant or overwrapped with waterproof barrier materials. Containers conforming to PPP-B-566 or PPP-B-676 shall be overwrapped with waterproof barrier materials or shall conform to MIL-B-43014 (see 5.1.1.4 and 5.1.1.5).

5.4.2.2 Level A and B packing. For level A packing when quantities per destination are less than a unitized load, the fiberboard containers shall not be banded but shall be placed in a close fitting box conforming to PPP-B-601, overseas type PPP-B-621, class 2 style 4 or PPP-B-585, class 3, style 2 or 3. Closure and strapping shall be in accordance with applicable container specification except that metal strapping shall conform to QQ-S-781, type I, class B. When the gross weight exceeds 200 pounds or the container length and width is 48 x 24 inches or more and the weight exceeds 100 pounds, 3 x 4 inch skids (laid flat) shall be applied in accordance with the requirements of the container specification. If not described in the container specification, the skids shall be applied in a manner which will adequately support the item and facilitate the use of material handling equipment. For level B packing, fiberboard boxes shall be weather resistant as specified in level A and the containers shall be banded (see 5.2.1 and 5.2.2).

5.4.2.3 Level A and B unitization. For level A and B unitization, the fiberboard caps shall be weather resistant and softwood pallets conforming to NN-P-71, type IV, size 2 shall be used (see 5.2.4.1 and 5.2.4.2).

5.4.3 Navy requirements. For Navy requirements the use of polystyrene loose fill material (such as strips, strands and beads) is prohibited for packaging and packing applications.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use. Class H cartridge fuses furnished to this specification and listed by Underwriters' Laboratories, Inc., are intended for overcurrent protection on circuits not exceeding an available short circuit current of 10, 000 amperes when used with type II fuseholders as specified in W-F-870. These fuses are available with instantaneous, time delay, or motor start characteristics (see 6.3.3). Class H fuses are not current-limiting (see 6.3.1) and do not have a specified interrupting rating.

6.2 Ordering data. Purchasers should select the preferred options permitted herein and include the following information in procurement documents:

(a) Title, number, and date of this specification.
(b) Title, number, and date of the applicable specification sheet.
(c) Government fuse part number (see 3.1) (not applicable to fuses with ratings not listed in applicable specification sheets).
(d) Fuse ratings not listed in applicable specification sheets (see 3.1.1).
(e) Levels of preservation-packaging and packing required (see 5.1 and 5.2).
(f) Quantity of fuses per unit package, if other than specified (see 5.1.1.4).
(g) Special marking, if required (see 5.3).

6.3 Definitions.

6.3.1 Current-limiting fuse. A fuse which safely interrupts all available currents within its interrupting rating and, within its current-limiting range, limits the clearing time at rated voltage to an interval equal to or less than the first major or symmetrical current loop duration and limits peak let-through current to a value less than the peak current that would be possible with the fuse replaced by a solid conductor of the same impedance.

6.3.2 Dual-element fuse (time delay). A fuse having current-responsive elements of two different fusing characteristics.

6.3.3 Overload interrupt. The term overload interrupt used throughout this specification is used in place of the term "overload blowing" as contained in UL198 and refers to the time-current characteristics of a fuse.

(a) The characteristics covered by this specification for nonrenewable fuses are:

Instantaneous - A single element fuse with no intentional time delay designed into the element, only maximum interrupt time is specified at 135 percent and 200 percent overload conditions.

Time delay - A dual element fuse, each element with a different time-current characteristic; maximum interrupt time is specified at 135 percent and 200 percent overload conditions; a minimum time limit is specified at 500 percent overload condition.

Motor start - A 600-volt fuse rated at 100 amperes or less which is designed to interrupt within 1 hour at 135 percent of rated current and within 8 minutes at 200 percent of rated current.

(b) Renewable fuses covered by this specification are designed to have an intentional lag or delay in opening the circuit but do not meet the requirements of UL198 for time delay nonrenewable fuses. Since Underwriters' Laboratories have no time delay requirements for renewable fuses, the following time-current values at 250 percent of rated current are supplied for informational purposes:

250 volt, 15 to 60 amperes shall open in not less than 3 seconds.
250 volt, 70 to 600 amperes shall open in not less than 15 seconds.
600 volt, 15 to 60 amperes shall open in not less than 6 seconds.
600 volt, 70 to 600 amperes shall open in not less than 25 seconds.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

6.3.4 Nonrenewable fuse. A fuse not intended to be restored for service after circuit interruption.

6.3.5 Renewable fuse. A fuse which may be readily restored for service after operation by the replacement of the renewal element.

6.3.6 Renewal element. That part of a renewable fuse which is replaced after each interruption to restore the fuse to operating condition.

6.3.7 Single-element fuse. A fuse having a current-responsive element with a single fusing characteristic.

6.4 Qualification. With respect to products requiring qualification, awards will be made only for products which are at the time set for opening of bids, qualified for inclusion in the applicable qualified products list whether or not such products have actually been so listed by that date. The attention of the suppliers is called to this requirement, and manufacturers are urged to arrange to have the products that they propose to offer to the Federal Government tested for qualification, in order that they may be eligible to be awarded contracts or orders for the products covered by this specification. The activity responsible for the qualified products list is the Defense Electronics Supply Center, ATTN: DESC-E, Dayton, OH 45444, and information pertaining to qualification of products may be obtained from that activity.

6.4.1 Application for qualification. Application for qualification tests shall be made in accordance with "Provisions Governing Qualification" which may be obtained upon application to Commanding Officer, Naval Publications and Forms Center, 5801 Tabor Avenue, Philadelphia, PA 19120.

6.5 Supersession data. This specification includes the requirements for class H cartridge fuses and supersedes that part pertaining to type I, style B, classes 1 and 2 fuses, and a portion of the type I, style A, classes 1 and 2, of W-F-791d, dated November 27, 1963 and Interim Amendment 1, dated February 18, 1966. (Additional type I, style A, classes 1 and 2 fuses of W-F-791d will be included in the proposed W-F-1814, "Fuse, Cartridge (High Interrupting Capacity).")

6.5.1 Background. Previous designations of type, style and class were nondefinitive since precise information was lacking to insure uniformity in part number construction. A major part numbering change was devised and utilized in W-F-791E. The same system is also used in W-F-1726. This method of numbering will insure uniformity and aid in prevention of duplicate items entering the supply system.

6.5.2 Cross reference. The types, styles and classes of cartridge fuses which were covered by W-F-791d are superseded and replaced by W-F-1726. The following table provides cross reference data:

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

TABLE IV. Cross references

Superseded W-F-791d designator	Voltage rating	Current range (amperes)	New government p/n W-F-1726
Type I Style A Class 1	250	0-30	WF1726/ 1-001 thru -008
2	↑	0-30	/ 1-009 thru -023
1		31-60	/ 2-001 thru -005
2		31-60	/ 2-006 thru -010
1		61-100	/ 3-001 thru -004
2		61-100	/ 3-005 thru -008
1		101-200	/ 4-001 thru -005
2		101-200	/ 4-006 thru -010
1		201-400	/ 5-001 thru -005
2		201-400	/ 5-006 thru -010
1	↓	401-600	/ 6-001 thru -003
2	250	401-600	/ 6-004 thru -006
1	600	0-30	/ 7-001 thru -008
2	↑	0-30	1/ / 7-009 thru -024
1		31-60	/ 8-001 thru -005
2		31-60	1/ / 8-006 thru -015
1		61-100	/ 9-001 thru -004
2		61-100	1/ / 9-005 thru -012
1		101-200	/10-001 thru -005
2		101-200	/10-006 thru -010
1		201-400	/11-001 thru -005
2		201-400	/11-006 thru -010
1	↓	401-600	/12-001 thru -003
2	600	401-600	/12-004 thru -006
Type I Style B Class 1 or 2	250	0-30	/13-001 thru -011
	↑	31-60	/14-001 thru -005
		61-100	/15-001 thru -004
		101-200	/16-001 thru -005
		201-400	/17-001 thru -005
	↓	401-600	/18-001 thru -003
	600	0-30	/19-001 thru -008
	↑	31-60	/20-001 thru -005
		61-100	/21-001 thru -004
		101-200	/22-001 thru -005
		201-400	/23-001 thru -005
	↓	401-600	/24-001 thru -003

1/ W-F-791d did not provide separate designations for time delay and motor start fuses.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.

MILITARY CUSTODIANS:

Army - EL
Navy - YD
Air Force - 80

Review activities:

Army - EL, ME, MI, MU
Navy - SH, MC
Air Force - 80
DSA - ES
NS

User activities:

Army - WC, AT
Navy - AS, OS
Air Force - 11

Preparing activity:

DSA - ES

Civil Agency Coordinating Activities:

AEC - AEC
DOT - FIS
GSA - FSS, PBO
NASA - JFK, MSF
HEW - NIH
USDA - AFS

(Project 5920-0328)

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies and other documents referenced herein. Price 15 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:34Z
Check the source to verify that this is the current version before use.