NOT MEASUREMENT SENSITIVE

MIL-DTL-2/14E
w/Amendment 1
29 September 2006
SUPERSEDING
MIL-DTL-2/14E
25 September 2002

DETAIL SPECIFICATION SHEET

VALVE, CYLINDER, GAS: BUTANE, PROPANE, BUTANE-PROPANE MIXTURE, MAPP GAS, AND PROPYLENE (MAXIMUM 100 POUND NOMINAL CAPACITY CYLINDER), OUTLET 510 (PRESSURES THROUGH 500 psig (3450 kPa) AT 70 ºF (21.1 ºC))

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet, MIL-DTL-2, and QPL-2.

REQUIREMENTS:

TYPE DESIGNATION	CYLINDER SERVICE PRESSURE psig	TYPE PRESSURE RELIEF DEVICE (PRD)
V14-510-14	240	7
V14-510-15	260	7

TABLE I. Valve requirements.

Style	Class	Composition	Inlet size	Outlet application	Handwheel	PRD
IIA	05	A	6	510	Yes	7
IV	05	A	6	510	Yes	7

Source: https://assist.dla.mil -- Downloaded: 2026-10-15T15:37Z
Check the source to verify that this is the current version before use.

SPECIAL REQUIREMENTS:

1. Diaphragms in style IV valves shall be made of metal or from a plastic with a low modulus of elasticity.
2. Mark the valve body: LPG.
3. Markings shall be in accordance with CGA S-1.1.
4. Start to discharge pressure shall be 375 psig.
5. Flow rating pressure shall be 480 psig.
6. Flow capacity shall not be less than 360 cfm.
7. The valve components shall contain less than 67 percent copper.

OPTIONAL REQUIREMENTS:

1. Outlet cap or plug (required) (not required).
2. Dip tube assembled to valve (required) (not required).

INTENDED USE: The valves covered by this specification sheet are intended for use with cylinders for butane, propane, butane and propane mixtures, MAPP gas, and propylene with nominal capacities to 100 pounds LPG (240 pounds H_20 capacity maximum).

NOTES:

1. Type designation will include any style valve from table I.
2. Special requirements will be mandatory for all valve procurements.
3. Optional requirements will be specified for each valve procurement.

AMENDMENT NOTATIONS: The margins of this specification are marked with vertical lines to indicate where modifications from this amendment were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations.

Custodians:
Army - AT
Navy - SH
Air Force - 68

Preparing Activity:
DLA - GS7

(Project 8120-2006-028)

Review Activities:
Army - AV
Navy - AS, MC

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST database at http://assist.daps.dla.mil/.

Source: https://assist.dla.mil -- Downloaded: 2026-10-15T15:37Z
Check the source to verify that this is the current version before use.