NOT MEASUREMENT SENSITIVE

MIL-DTL-2/22E
w/Amendment 1
29 September 2006
SUPERSEDING
MIL-DTL-2/22E
25 September 2002

DETAIL SPECIFICATION SHEET

VALVE, CYLINDER, GAS: REFRIGERANTS, OUTLET 660 (PRESSURES THROUGH 500 psig (3450 kPa) AT 70 ºF (21.1 ºC))

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet, MIL-DTL-2, and QPL-2.

REQUIREMENTS:

TYPE DESIGNATION	CYLINDER SERVICE PRESSURE psig	FLOW CONTROLS	OUTLET PORTS
V22-660-13	225	Single	Single
V22-660-14	240	Single	Single
V22-660-15	260	Single	Single
V22-660-16	300	Single	Single
V22-660-17	400	Single	Single
V22-660-18	300	Dual	Single
V22-660-19	400	Dual	Single
V22-660-20	240	Dual	Dual
V22-660-21	300	Dual	Dual
V22-660-22	400	Dual	Dual

TABLE I. Valve requirements.

Style	Class	Composition	Inlet size	Outlet application	Handwheel	PRD[1]
I	05	A	6	660	Yes	7
IIA	05	A	6	660	Yes	7

[1] Pressure Relief Device

Source: https://assist.dla.mil -- Downloaded: 2026-10-15T15:38Z
Check the source to verify that this is the current version before use.

SPECIAL REQUIREMENTS:

1. Mark the valve body: REFRIG.

OPTIONAL REQUIREMENTS:

1. Outlet cap or plug (required) (not required).
2. Disposable outlet cap or plug (required) (not required).
3. Wrench or key (required) (not required).
4. Dip tube assembled to valve (required) (not required).

INTENDED USE: The valves covered by this specification sheet are intended for use with cylinders for the following refrigerant gases:

TABLE II. Refrigerant gasses.

Refrigerant	Chemical name	Refrigerant	Chemical name
R-11	Trichlorofluoromethane	R-152a	Difluoroethane
R-12	Dichlorodifluoromethane	R-290	Propane
R-13	Chlorotrifluoromethane	R-401A	(R-22/R-125/R-124)(53/13/34)
R-22	Chlorodifluoromethane	R-401B	(R-22/R-152a/R-124)(61/28/11)
R-23	Trifluoromethane	R-402A	(R-22/R-125/R-290)(38/60/2)
R-31	Chlorofluoromethane	R-402B	(R-22/R-125/R-290)(60/38/2)
R-32	Difluoromethane	R-404A	(R-125/R-143a/R-134a)(44/52/4)
R-113	Trichlorotrifluoroethane	R-500	(R-12/R-152a)(73.8/26.2)
R-114	Dichlorotetrafluoroethane	R-501	(R-22/R-12)(75.0/25.0)
R-115	Chloropentafluoroethane	R-502	(R-22/R-115)(48.8/51.2)
R-123	Dichlorotrifluoroethane	R-503	(R-23/R-13)(40.1/59.9)
R-124	Chlorotetrafluoroethane	R-504	(R-32/R-115)(48.2/51.8)
R-125	Pentafluoroethane	R-505	(R-12/R-31)(78.0/22.0)
R-134a	Tetrafluoroethane	R-506	(R-31/R-114)(55.1/44.9)
R-143a	Trifluoroethane		

NOTES:

1. Type designation will be the style valve from table I.
2. Special requirements will be mandatory for all valve procurements.
3. Optional requirements will be specified for each valve procurement.

AMENDMENT NOTATIONS: The margins of this specification are marked with vertical lines to indicate where modifications from this amendment were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal.

Source: https://assist.dla.mil -- Downloaded: 2026-10-15T15:38Z
Check the source to verify that this is the current version before use.

Custodians:
Army - AT
Navy - SH
Air Force - 68

Preparing Activity:
DLA - GS7

(Project 8120-2006-029)

Review Activities:
Army - AV
Navy - AS, MC

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST database at http://assist.daps.dla.mil/.

Source: https://assist.dla.mil -- Downloaded: 2026-10-15T15:38Z
Check the source to verify that this is the current version before use.