MIL-A-10957G
9 December 1986
SUPERSEDING
MIL-A-10957F
1 May 1981

MILITARY SPECIFICATION

ADAPTER KIT, GRAVITY FEED, FOR 5 GALLON MILITARY GASOLINE CAN AND 55 GALLON DRUM

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This document covers one type and size gravity feed adapter kit for the 5-gallon Military gasoline can and 55 gallon drum (see 6.1).

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Documents. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

FEDERAL

QQ-A-591 - Aluminum Alloy Die Castings
QQ-B-626 - Brass, Leaded and Nonleaded; Rod, Shapes, Forgings, and Flat Products with finished Edges (Bar and Strip)

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: U.S. Army Natick Research, Development and Engineering Center, Natick, MA 01760-5014 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 7240

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

QQ-S-700	-	Steel, Sheet and Strip, Medium and High Carbon
UU-T-81	-	Tags, Shipping and Stock
WW-C-440	-	Clamps, Hose (Low-Pressure)
PPP-B-566	-	Boxes, Folding, Paperboard
PPP-B-636	-	Boxes, Shipping, Fiberboard
PPP-B-676	-	Boxes, Setup
PPP-C-843	-	Cushioning Material, Cellulosic
PPP-P-291	-	Paperboard, Wrapping and Cushioning

MILITARY

MIL-G-432	-	Gaskets - Nonmetallic, Synthetic Rubber
MIL-R-7362	-	Rubber, Synthetic, Solid, Sheet, Strip and and Fabricated Parts, Synthetic Oil Resistant
MIL-B-7883	-	Brazing of Steels, Copper, Copper Alloys, Nickel Alloys, Aluminum and Aluminum Alloys
MIL-A-8625	-	Anodic Coatings, for Aluminum and Aluminum Alloys
MIL-H-10868	-	Hose Assembly, Rubber, Utility, Gasoline (1/4-Inch Inside Diameter)
MIL-L-35078	-	Loads, Unit: Preparation of Semiperishable Subsistance Items; Clothing, Personal Equipment and Equipage; General Specification For

STANDARDS

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	-	Marking for Shipment and Storage
MIL-STD-130	-	Identification Marking of US Military Property
MIL-STD-147	-	Palletized Unit Loads

DRAWINGS

U.S. ARMY NATICK RESEARCH, DEVELOPMENT AND ENGINEERING CENTER

3-3-48	-	Adapter Kit, Gravity Feed, Military Gasoline Can and 55 Gallon Drum: Assembly and Details
3-3-49	-	Adapter Kit, Gravity Feed, Military Gasoline Can and 55 Gallon Drum: Details
3-3-50	-	Adapter Kit, Gravity Feed, Military Gasoline Can and 55 Gallon Drum: Instruction Tag

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

(Copies of documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

* 2.2 Other publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are a DOD adopted shall be those listed in the issues of the DODISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS shall be the issue of the nongovernment documents which is current on the date of solicitation.

* AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

A 108 - Steel Bars, Carbon, Cold Finished, Standard Quality
A 366 - Steel, Carbon, Cold Rolled Sheet, Commercial Quality
A 569 - Steel, Carbon, Hot-Rolled Sheet and Strip, Commercial Quality
B 633 - Electrodeposited Coatings of Zinc on Iron and Steel
D 3951 - Standard Practice for Commercial Packaging
E 18 - Rockwell Hardness and Rockwell Superficial Hardness of Metallic Materials

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

SOCIETY OF AUTOMOTIVE ENGINEERS, INC. (SAE)

J 423 - Methods of Measuring Case Depth

(Application for copies should be addressed to Society of Automotive Engineers, Inc., 400 Commonwealth Drive, Warrendale, PA 15096.)

(Technical society and technical association documents are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

* 2.3 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document shall take precedence. Nothing in this document, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

* 3.1 First article. When specified in the contract or purchase order, a sample shall be subjected to first article inspection (see 4.3, 6.2, and 6.3).

3.2 Materials and components. The materials and components shall be as specified herein and as shown on the applicable drawings. Materials and components not definitely specified shall be of the quality normally used by the manufacturer provided the completed item complies with all the provisions of this document (see 6.4).

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

* 3.2.1 Steel. The steel sheet and strip shall conform to ASTM A 366 or A 569 or QQ-S-700, as applicable. The cold rolled steel rod shall conform to ASTM A 108. The steel tube shall be commercial seamless or copper brazed double, triple or quadruple wrapped.

3.2.2 Brass. The brass bar shall conform to copper alloy number 360 of QQ-B-626.

3.2.3 Aluminum die casting. The aluminum die casting shall conform to alloy Number 413.0 of QQ-A-591.

* 3.3 Alternate components. Components offered as equivalent to components specified in this document and on the reference drawings as a specific manufacturer's part number or equal shall be functionally equal to the manufacturer's part number identified and of equal or better quality. The incorporation and inclusion of such a component in the design of the specified end product shall not require modification or change to any other specified component, and shall not reduce ease of maintenance to it or any other components, unless such modification or change is specifically approved by the contracting officer. Prior to manufacture of the first article or if none is required, prior to commencing production, the contractor shall submit for the contracting officers' approval, a list identifying each proposed alternate component, together with proof that each listed component complies with requirements specified herein. The contracting officer, at his option, may require a physical sample of the proposed substitution. Approval of the submitted listing, together with necessary supporting data, authorizes the commencement of the first article or production manufacture, as applicable, and does not relieve the contractor of responsibility that these components perform in accordance with specified requirements when incorporated into the end product.

3.4 Design and construction. The design and construction of the adapter kit shall be as specified herein and as shown on the drawings referenced in 2.1. Brazing shall conform to MIL-B-7883.

3.4.1 Adapter hose connector. The adapter hose male threads shall be coated with an air drying, hard setting oil and gasoline resistant cement and when screwed into the adapter body with a torque of 150 to 160 inch-pounds there shall be no evidence of deformation or cracking of the assembly (see 4.4.2).

* 3.4.2 Drip interceptor. The synthetic rubber drip interceptor shall conform to the design and dimensions as shown on Drawing 3-3-49 and shall be made from synthetic rubber material type II of MIL-G-432 with a durometer range as specified for type II in MIL-G-432. The drip interceptor shall conform to the test requirements specified in MIL-G-432 except that tests for compression set, endurance, leakage and strength need not be performed.

* 3.4.3 Cam and washer. The cam and washer shall be hardened to a surface hardness of Rockwell 85 to 88 on the 15N scale with an effective case depth of 0.0101 inch (see 4.4.2). The cam and washer, within four hours after zinc

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

plating and prior to the supplementary chromate treatment, shall be relieved of hydrogen embrittlement in accordance with ASTM B 633.

3.4.4 Plug body. The plug body pressure surface contacting the large gasket shall be perpendicular to the longitudinal axis of the threads and shall be flat, smooth, and free from burrs and markings. When tested as specified in 4.5.1, the gap shall be not greater than 0.015 inch between the thread plug gage and the pressure surface of the plug body in contact with the large gasket. The torque required to loosen and remove the plug from the gage shall be not greater than 20 foot-pounds. The threads of the plug body after plating shall conform to the dimensional requirements of Drawing 3-3-48 when tested by a plug gage as specified in 4.5.1.

3.4.5 Adapter body. The adapter body surface contacting the small gasket shall be smooth and free of ridges due to die lines. The pipe thread of the adapter body shall conform to the dimensional requirements of Drawing 3-3-49 when tested as specified in 4.5.2.

3.4.6 Swivel coupling nut. The swivel coupling nut shall rotate freely on the swivel coupling body. The swivel coupling threads shall conform to the dimensional requirements of Drawing 3-3-49 when tested as specified in 4.5.3.

3.4.7 Vent tubes. The vent tubes shall be deburred inside and outside before the threading operation. After brazing the connectors and after being plated, the threads of the vent tube and connectors shall conform to the dimensional requirements of Drawing 3-3-49 when tested as specified in 4.5.4.

3.4.8 Hose and clamps. The rubber hose shall conform to the requirements of MIL-H-10868. The hose clamps shall conform to type B, 1/2 inch nominal size, zinc plated of WW-C-440 except that the exposed length of the screw shall not be greater than 1/4 inch beyond the nut.

3.4.9 Gaskets.

* 3.4.9.1 Large gasket. The material of the large synthetic rubber gasket shall conform to type II of MIL-R-7362 and to the dimensions specified on Drawing 3-3-49.

* 3.4.9.2 Small gasket (O-Ring). The material of the small synthetic rubber gasket shall conform to type I of MIL-R-7362 and to the dimensions detailed on Drawing 3-3-49.

3.5 Finish.

3.5.1 Anodizing. The adapter body, after complete fabrication and thorough cleaning, but prior to final assembly, shall have an anodic film formed on all surfaces conforming to type II, class 1 of MIL-A-8625.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

* 3.5.2 Zinc-plating. After complete fabrication and thorough cleaning, but prior to final assembly, the cam, clevis pin, cotter pin, steel washer, vent tube with brazed connector, and plug body shall be zinc-plated in accordance with type II (with a minimum thickness of 13 micrometers), of ASTM B 633 with the following exceptions:

(a) The color may be clear chromate
(b) Zinc plating thickness shall be not less than 0.0003 inch on other than threaded surfaces
(c) The salt spray test shall be for 32 hours
(d) Evidence of red rust on other than threaded surfaces shall constitute a failure
(e) White corrosive products of zinc or slight red rust on threads shall not constitute failure

3.6 Instruction tag. The instruction tag shall conform to size No. 6, type A, grade 2 or 3 of UU-T-81. Color of the instruction tag shall be either white or light yellow. Stringing shall be galvanized wire. The instruction tag shall be securely wired to the hose clamps and shall freely hang a distance not less than 2 inches. The instructions and illustrations shown on Drawing 3-3-50 shall be reproduced legibly, and neatly on each instruction tag. The reproduction shall be as large as practicable, keeping the border around the tag to a minimum.

3.7 Markings.

3.7.1 Marking for identification. Marking for identification shall be in accordance with MIL-STD-130 and as shown on the drawings.

3.7.2 Special markings. The word tighten and a directional arrow, in the size, characters and location shown on Drawing 3-3-48, shall be indented on the plug body.

3.7.3 Die cast markings. The adapter body may bear the name, trade name, or trademark of the actual manufacturer of the die casting. Die cast markings shall be located as shown on Drawing 3-3-49 and shall be legible and shall not exceed an area greater than 1/4 inch in diameter.

3.8 Workmanship. The units shall be free from fractures, splits, punctures, tears, dents, creases, deteriorations or malformations. There shall be no sharp edges, burrs or slivers. The finish shall be free from blisters, peel, chipped areas or areas of no film. Threaded fasteners shall not be broken, stripped, fractured or loose. The surface of parts to be welded shall be free from oxide, scale, paint, grease and other foreign matter. Welds shall be sound, continuous, smooth and free from porosity, cracks, incomplete fusion and deformation of material. All scale and flux deposit shall be removed from the finished welds.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in this document where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

* 4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this document shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the document shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicted or actual, nor does it commit the Government to acceptance of defective material.

* 4.1.2 Responsibility for dimensional requirements. Unless otherwise specified in the contract or purchase order, the contractor is responsible for assuring that all specified dimensions have been met. When dimensions cannot be examined on the end item, inspection shall be made at any point, or at all points in the manufacturing process necessary to assure compliance with all dimensional requirements.

4.2 Classification of inspection. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.3).
b. Quality conformance inspection (see 4.4).

4.3 First article inspection. When a first article is required (see 6.2), it shall be examined for the defects specified in 4.4.3 and 4.4.4 and tested as specified in 4.5.1 and 4.5.4. The presence of any defect or failure to pass any test shall be cause for rejection of the first article.

4.4 Quality conformance inspection. Unless otherwise specified, sampling for inspection shall be performed in accordance with MIL-STD-105.

4.4.1 Component and material inspection. In accordance with 4.1, components and materials shall be inspected in accordance with all the requirements of referenced documents, unless otherwise excluded, amended, modified, or qualified in this document or applicable purchase document.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

* 4.4.1.1 Component testing. In addition to the quality assurance provisions of the referenced documents, the cams and washers shall be tested as specified in 4.5.5 for conformance to the surface hardness and depth of hardness requirements specified in 3.4.3. The lot size shall be expressed in terms of cams or washers. The sample unit shall be one cam or washer as applicable. The inspection level shall be S-2 and the acceptable quality level (AQL), expressed in terms of defects per hundred units, shall be 2.5. The number of determinations per sample unit shall be three and the results shall be reported as the average of the three determinations to the nearest Rockwell 15N Scale reading for the case depth.

4.4.2 In-process inspection. Inspection shall be made of the following operations to establish conformance with specified requirements. Whenever nonconformance is noted, correction shall be made to the process and all items processed.

TABLE I. In-process examination

Requirement	Paragraph
Thread coating and torque	3.4.1
Durometer test of drip interceptors are tested as specified in MIL-G-432	3.4.2
Hydrogen embrittlement relief	3.4.3
Cleaning and deburring	3.5.1, 3.5.2 and 3.8

* 4.4.3 End item visual examination. The end item shall be examined for the defects listed in table II. The lot size shall be expressed in units of adapter kits. The sample unit shall be one completely assembled adapter kit. The inspection level shall be II and the AQL, expressed in terms of defects per hundred units, shall be 1.0 for major defects, and 4.0 for total (major and minor combined) defects.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

TABLE II. Classification of defects

Examine	Defect	Classification Major	Minor
Finish (on steel parts)	Zinc coating omitted, area of no coating, not specified coating, or rust on exposed surfaces	X	
	Coating not smooth and uniform, not tightly adherent, flaky, blistered, peeling, coating scratched or stained		X
Finish (on aluminum parts)	Any component not anodized	X	
	Anodic film not continuous, scratches, breaks or abrasions		X
Design, construction and workmanship, general (applicable to all components and assemblies)	Any component or part missing or not specified type or size	X	
	Fractured, split, punctured, torn, dented, creased, deteriorated or malformed	X	
	Component loose		X
	Sharp burr, edge or sliver		X
	Casting contains blowhole, pitted or flash not removed		X
	Vents or gasoline openings not complete, or are blocked	X	
	Gasket seat surface on plug body not smooth and flat (signs of unevenness or distortion)	X	
	Evidence that seat of swivel coupling body not smooth	X	
	Signs of abrading on rubber hose	X	
	Surfaces of rubber gaskets not smooth		X
	Adapter body does not turn when cam is unlocked	X	
	Cam does not lock securely	X	
	Cam difficult to operate by hand (even when lubricant is used)		X
	Plug of hole omitted from lower vent tube	X	
	Plug not pressed into lower vent tube		X

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

TABLE II. Classification of defects (cont'd)

Examine	Defect	Classification Major	Minor
Design, construction and workmanship, general (applicable to all components and assemblies) (cont'd)	Connectors on upper and lower vent tubes not securely brazed (check doubtful sample units by turning connector with a wrench)	X	
	Connectors on vent tubes not brazed all around, or brazing omitted from plugged end of lower vent tube	X	
	Swivel coupling nut does not rotate freely	X	
	Instruction tag missing or not firmly wired to hose clamp		X
	Instruction tag defective, wrong size tag, marking incomplete, not legible, torn or damaged, not white or yellow in color		X
	Hose connector not sealed in adapter body with cement	X	
Welding	Missing, incomplete, burn holes, cracked, fractured, not fused	X	
	Not smooth and uniform or scale or flux deposits not removed		X
Bolts, nuts, screws studs and other types of threaded fasteners	Broken, stripped, fractured or not tight		X
Identification marking	Missing, incomplete, not legible, not specified area, not in proper location	X	

* 4.4.4 End item dimensional examination. Examination shall be made of the end item for compliance with the dimensions marked with an asterisk on Drawings 3-3-48 and 3-3-49. Any dimension not within the specified tolerance shall be classified as a defect. The lot size shall be expressed in units of adapter kits. The sample unit shall be one adapter kit. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 4.0.

* 4.4.5 End item testing. Testing of the threads of the plug body, adapter body, coupling swivel and vent tubes shall be as specified in 4.5.1 through 4.5.4. Any nonconforming thread shall be classified as a defect. The lot size shall be expressed in units of adapter kits. The sample unit shall be

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

one adapter kit. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 2.5.

* 4.4.6 Packaging examination. The fully packaged end items shall be examined for the defects listed below. The lot size shall be expressed in units of shipping containers. The sample unit shall be one shipping container fully packaged. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 4.0.

Examine	Defect
Marking (exterior and unit pack)	Omitted; incorrect; illegible; of improper size, location, sequence, or method of application.
Materials	Any component missing, damaged, or not as specified.
Workmanship	Inadequate application of components, such as incomplete use of cushioning material.
Content	Number of adapter kits per container is more or less than required.

* 4.4.7 Palletization examination. The fully packaged and palletized end items shall be examined for the defects listed below. The lot size shall be expressed in units of palletized unit loads. The sample unit shall be one palletized unit load, fully packaged. The inspection level shall be S-1 and the AQL, expressed in terms of defects per hundred units, shall be 6.5.

Examine	Defect
Finished dimensions	Length, width, or height exceeds specified maximum requirements.
Palletization	Pallet pattern not as specified. Interlocking of loads not as specified. Load not bonded with required straps as specified.
Weight	Exceeds maximum load limits.
Marking	Omitted; incorrect; illegible; of improper size, location, sequence, or method of application.

4.5 Methods of inspection.

4.5.1 Plug body test. The GO gage used in checking the threads and pressure surface of the plug body shall be the same or equal to the one shown on Drawing 3-3-48. The plug shall be screwed into the GO gage until the pressure surface of the plug body contacts the flat surface of the GO gage. After the plug has been tightened with a torque not greater than 5 ft. lbs., loosening

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

shall require a torque not greater than 20 ft. lbs. The size and completeness of the threads near the surface that comes in contact with the large gasket, and the perpendicularity shall be checked on the plug gasket surface and threads, and the gap between the plug and the GO gage shall be check tested. Any nonconformance to the requirements of 3.4.4 shall constitute failure of this test.

4.5.2 Adapter body test. The adapter body thread dimensions shall be tested with a National pipe thread (NPT) plug type thread gage with gaging notch to indicate depth. Any nonconformance to the requirements of 3.4.5 shall constitute failure of this test.

4.5.3 Swivel coupling nut. The swivel coupling nut thread dimensions shall be tested with NPT plug and ring type gage. Any nonconformance to the requirements of 3.4.6 shall constitute failure of this test.

4.5.4 Vent tubes. The vent tubes and connectors thread dimension shall be tested with a NPT plug and ring type gage. Any nonconformance to the requirements of 3.4.7 shall constitute failure of this test.

4.5.5 Cam and washer test. The cam and washer shall be tested in accordance with ASTM E 18. The effective depth shall be determined in accordance with SAE J423. Any nonconformance to the harden and case depth requirements as specified in 3.4.3 shall constitute failure of this test.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or Commercial as specified (see 6.2).

5.1.1 Level A.

5.1.1.1 Disassembly. The vent tube assembly shall be unscrewed from the adapter body and disassembled into its two components. The hose shall not be detached from the adapter body.

5.1.1.2 Unit pack. One complete, disassembled adapter kit shall be unit packed in a folding or setup paperboard box conforming to variety 1, style III, type G, class i or style IV, type I or J, class i of PPP-B-566; or type I, variety 1, class a, style 3 or 4 of PPP-B-676, respectively. The inside dimensions of the box shall approximate 9-5/8 inches in length, 3-3/4 inches in width, and 2-7/8 inches in depth. Approximate dimensions are furnished as a guide only. Cushioning material conforming to type II, class B of PPP-C-843, or type III, style 1 or 2 of PPP-P-291 shall be used to isolate and immobilize the components within the box. Closure shall be in accordance with the appendix of the applicable box document.

* 5.1.2 Commercial. Adapter kits shall be preserved in accordance with ASTM D 3951.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

5.2 Packing. Packing shall be level A, B, or Commercial (see 6.2).

* 5.2.1 Level A packing. Forty adapter kits, preserved as specified in 5.1, shall be packed in a snug-fitting fiberboard shipping container conforming to style RSC, V2s of PPP-B-636. Level A unit packs shall be packed flat, five in length, two in width, and four in depth. The inside dimensions of the shipping container shall be approximately 19-3/4 inches in length, 19-1/2 inches in width, and 12 inches in depth. Approximate dimensions are furnished as a guide only. Each shipping container shall be closed in accordance with method III, waterproofed in accordance with method V and reinforced as specified in appendix of PPP-B-636. Shipping containers shall be arranged in unit loads in accordance with MIL-L-35078 for the type and class of load specified (see 6.2). Strapping shall be limited to nonmetallic strapping, except for type II, class F loads.

5.2.2 Level B packing. Forty adapter kits, preserved as specified in 5.1, shall be packed in a snug-fitting fiberboard shipping container conforming to style RSC, type CF, variety SW, or type SF, class domestic of PPP-B-636. Level A unit packs shall be packed flat, five in length, two in width, and four in depth. The inside dimensions of the shipping container shall be approximately 19-3/4 inches in length, 19-1/2 inches in width, and 12 inches in depth. Approximate dimensions are furnished as a guide only. Closure shall be in accordance with method II of the appendix of PPP-B-636.

5.2.2.1 Weather-resistant fiberboard containers. When specified (see 6.2), the shipping container shall be a grade V3c, V3s, or V4s fiberboard box fabricated in accordance with PPP-B-636 and closed in accordance with method III as specified in the appendix of the box document.

* 5.2.3 Commercial packing. Adapter kits preserved as specified in 5.1, shall be packed in accordance with ASTM D 3951.

* 5.3 Palletization. When specified (see 6.2), adapter kits, packed as specified in 5.2.2 and 5.2.3 shall be palletized on a 4-way entry pallet in accordance with load type 1a of MIL-STD-147. Pallet types shall be type I (4-way entry), type IV, or type V. Each prepared load shall be bonded with primary and secondary straps in accordance with bonding means K and L, or film bonding means O or P. Pallet pattern shall be number 6 in accordance with the appendix of MIL-STD-147. Interlocking of loads shall be effected by reversing the pattern of each course.

* 5.4 Marking. In addition to any special marking required by the contract, unit packs, shipping containers, and palletized unit loads shall be marked in accordance with MIL-STD-129 or ASTM D 3951, as applicable.

6. NOTES

6.1 Intended use. The gravity feed adapter kit is intended to be used with MIL-C-1283 for Can, Gasoline, Military, 5 Gallon, and with PPP-B-729 for Drum, Metal, 55 Gallon, to provide a method of withdrawing fuel at a low rate of speed

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

(gravity feed) for use with various Military field heating, cooking and laundry equipment.

* 6.2 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this document.
b. When a first article is required (see 3.1, 4.3, and 6.3).
c. Selection of applicable levels of preservation and packing (see 5.1 and 5.2).
d. Type and class of unit load required (see 5.2.1).
e. When weather-resistant grade fiberboard shipping containers are required for level B packing (see 5.2.2.1).
f. When palletization is required (see 5.3).

* 6.3 First article. When a first article is required, it shall be inspected and approved under the appropriate provisions of FAR 52.209-4. The first article should be a preproduction sample, initial production item or other specific item described under the definition of a first article in the FAR. The contracting officer should specify the appropriate type of first article and the number of units to be furnished.

6.4 Recycled material. It is encouraged that recycled material be used when practical as long as it meets the requirements of the document (see 3.2).

6.5 Subject term (key word) listing.

Adapter Kit
Cans, Gasoline, 5 Gallon
Drums, Gasoline, 55 Gallon
Fittings

6.6 Changes from previous issue. The margins of this document are marked with an asterisk to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

Custodians:

Army - GL
Navy - YD
Air Force - 99

Review activities:

Army - ME
DLA - GS

User activities:

Navy - MC
Air Force - 84

Preparing activity:

Army - GL

Project No. 7240-0239

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE ARMY

U.S. ARMY NATICK RESEARCH, DEVELOPMENT
and ENGINEERING CENTER
ATTN: STRNC-ES
Natick, MA 01760-5014

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12062 WASHINGTON D. C.
POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

Commander
U.S. Army Natick Research, Development
and Engineering Center
ATTN: STRNC-ES
Natick, MA 01760-5014

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-A-10957G	Adapter Kit, Gravity Feed, For 5 Gallon Military Gasoline Can & 55 Gallon Gallon Drum

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

NATICK OP-1, Feb 86

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:48Z
Check the source to verify that this is the current version before use.