MIL-C-7079A(USAF)
AMENDMENT 1
23 March 1967

MILITARY SPECIFICATION

CIRCUIT BREAKER, NON TRIP-FREE

GENERAL SPECIFICATION FOR

This amendment forms a part of Military Specification MIL-C-7079A(USAF), dated 19 Apr 1965.

Page 4, Para 3.3.1.1 Contact Resistance. - Delete the last sentence of the paragraph and insert the following: "The contact resistance shall not increase by more than 250 millivolts as a result of being subjected to the moisture resistance tests."

Page 8, Para 3.7 Performance. - Delete listed performance requirement "(S) Humidity, Para 4.6.20" and insert "Moisture Resistance, Para 4.6.20". Delete performance requirement "(t) Contact Resistance, Para 4.6.21" and insert "(t) Explosion Proof, Para 4.6.22". Delete "V Hold-in Rupture, Para 4.6.23" and insert "(U) Hold-in Rupture, Para 4.6.23".

Page 11, Para 4.5.1 Individual Tests. - Delete the word "three" in the second sentence and insert the word "these".

Page 12, Para 4.5.2 Sampling Tests. - Insert the applicable test paragraph numbers in the Test Paragraph column of TABLE II which identify the appropriate test paragraph covered in the Test Methods Paragraph 4.6. Delete Overload Cycling and Hold-In Capacity tests listed in TABLE II.

Page 13, Table III, Qualification Test Schedule. - Delete the test title "Humidity" for the 20th test listed and insert "Moisture Resistance". Delete Contact Resistance Test and entire line applicable to the contact resistance test for the 21st test listed. Include test samples numbered 18, 19, 20 with test samples number 16 and 17 so that all five test samples will be subjected to moisture resistance tests. Delete entire column applicable to test samples numbered 18, 19 and 20. List calibration test as the fourth test to be performed for test samples numbered 16, 17, 18, 19 and 20.

Page 21, Para 4.6.20 Humidity. - Delete entire paragraph and insert the following:

"4.6.20 Moisture Resistance. - The circuit breakers in the "on" position shall be subjected to the Moisture Resistance test as outlined in MIL-STD-202 Test Method 106, and Figure 106-1 with exception that the vibration test step 7b shall be omitted. Distilled, demineralized or deionized water having a PH value between 6.5 and 7.2 at 25°C shall be used to obtain the desired humidity. The drying period at the completion of the moisture exposure shall be extended to a ten day storage period. The contact resistance of the breakers shall be

FSC 5925

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T08:01Z
Check the source to verify that this is the current version before use.

determined prior to subjection to the moisture exposure and after completion of the storage period as follows: The circuit breaker contacts shall be manually operated to successively interrupt and make a test circuit having a direct current resistive load of 200 milliamps at 26 volts. The contact resistance (specified in terms of millivolt drop) shall be computed from the average of five consecutive measurements of which each is taken at the completion of each successive contact closure. All measurements shall be made across the circuit breaker external electrical terminals, by using identical measuring techniques. The breaker contacts shall be maintained in the closed position throughout the moisture exposure and storage period (without disturbance) until the first contact resistance measurements are taken at completion of the storage period. The circuit breaker shall meet the contact resistance requirement (see para 3.3.1.1) and successfully pass the overload calibration test at 200% rated current (see para 4.6.7.3) following the completion of the final contact resistance measurements. The tripping time shall be within 90 percent of the lower limit and 110% of the upper limit specified."

Para 4.6.21 Contact Resistance. - Delete entire paragraph.

CUSTODIANS:
Air Force - 85

PREPARING ACTIVITY:
Air Force - 85

REVIEW ACTIVITY:
Air Force - 85

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T08:01Z
Check the source to verify that this is the current version before use.