INCH-POUND

A-A-55004
September 10, 1990
SUPERSEDING
(See Heading)

COMMERCIAL ITEM DESCRIPTION

LAMP, FLUORESCENT, F96/T12/(COLOR)/IS

The General Services Administration has authorized the use of this Commercial Item Description (CID) as replacement for CIDs A-A-1583, A-A-1852A, A-A-1853A, A-A-1854A, A-A-1855A, and Federal Specifications W-L-00116/43A, /44A, and /45A which are canceled.

1. Abstract. This CID describes the general requirements for procurement of one type fluorescent lamp of certain colors used for typical illumination.

2. Salient characteristics. This Commercial Item Description (CID) covers F96/T-12, instant-start, fluorescent lamps, 75 watt, 425 ma, 96 inch nominal length, single pin contact base, 12,000 hours average rated life at 3 hrs/start, further described in table I.

Table I. Color/lumen characteristics.

Color[1] (color temperature) [CRI]	Cool White (4100K) [62]	Cool White Deluxe (4200K) [89]
Initial lumens[2] (after 100 hrs burning)	5900	4230
Lumens at 4800 hours[2]	5350	3800
CID based part ID number[3]	A55004-1	A55004-2

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be sent by letter to: Commander, Defense General Supply Center, ATTN: Parts Control Branch (SSC), Richmond VA 23297-5000.

OMB control number N/A FSC 6240

DISTRIBUTION STATEMENT A: Approval for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:41Z
Check the source to verify that this is the current version before use.

Footnotes to table I: Dimensional and electrical characteristics shall be in accordance with ANSI C78.3.

[1]In compliance with ANSI C78.376, where applicable. Color temperature and color rendering index [CRI] are approximates.
[2]Indicates the average nominal value per lamp on a lot basis.
[3]These part identification numbers are for government purposes and do not constitute a requirement for the contractor.

3. Contractor certification. The contractor shall certify and maintain substantiating evidence that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices. The Government reserves the right to require proof of such conformances prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

4. Metric Products. Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, provided they fall within the tolerances specified using conversion tables contained in the latest revision of Federal Standard No. 376, and all other requirements of this Commercial Item Description are met.

If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch/pound units, a request should be made to the contracting officer to determine if the product is acceptable.

The contracting officer has the option of accepting or rejecting the product.

5. Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practical.

6. Preservation, packaging, packing, labeling, and marking. Preservation, packag- ing, packing, labeling, and marking shall be as specified in the contract or order. If not specified in the contract or order shall comply with ASTM D-3951.

6.1. Anti-counterfeit marking. When an item has been deemed to be susceptible to counterfeiting, each item shall be marked in such a manner as to provide the contracting activity with an authentication and traceability track to the true manufacturer. The method in which this is done shall be proprietary to the true manufacturer and provided to the quality assurance office of the contracting agency by secure means.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:41Z
Check the source to verify that this is the current version before use.

7. Notes. The issues of ANSI C78.3, C78.376, and ASTM D-3951 in effect on the date of solicitation shall be used to determine compliance with these requirements.

(Copies of ANSI Standards are available from the American National Standards Institute, 1430 Broadway, New York NY 10018.)

(Copies of ASTM Standards are available from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

Purchaser should specify the following ordering data;
Title, number and date of this document
CID based part identification number

Brand names and National Stock Numbers are listed in table II:

Table II. Brand names and stock numbers

CID part no.	National Stock Numbers (NSNs)	Commercial stock number	Manufacturer CAGE code[1]
A55004-1	6240-00-299-2899	F96T12/CW	06107, 1HT85, 62607,
A55004-2	6240-00-681-1639	F96T12/CWX	08599, 08805, 1HT85, 56589, 58325, 62607 8521

[1]Footnote to table II: Commercial And Government Entity (CAGE) code definition:

06172 - Marvel Lamp Co. Inc., 2083 Center Ave., Ft . Lee, NJ 07024-4999.
08599 - Arc Ray Electric Co., 350 5th Ave., Empire State Bldg. NY, NY 10001-5100
08808 - General Electric Co., Lamp Glass and Components Dept., 24400 Highland Rd. Richmond Heights, OH 44143-2503.
1HT85 - GTE Products Corp., Lighting Center, Danvers MA 01923
56589 - 21st Century Enterprises Inc., 725 Industrial Rd., San Carlos, CA 94070-3310.
62607 - North American Phillips Lighting Corp., A Div., 1 Westinghouse Plaza Bloomfield, NJ 07003-4601.
85271 - Duro Test Corp., 9 Law Dr., Fairfield, NJ 07007

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:41Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Military Coordinating Activity

Navy - AS

Custodians

Air Force - 99
Army - ME
Navy - SH

CIVIL AGENCY COORDINATING ACTIVITIES:

COMMERCE - NIST

GSA - FSS

PREPARING ACTIVITY:

Navy - AS

AGENT:

DLA - GS

Project 6240-1111

FSC 6240

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:41Z
Check the source to verify that this is the current version before use.