DATA ITEM DESCRIPTION
TITLE: Seismic Qualification Document

Number: DI-FACR-82307
AMSC Number: 10125
DTIC Applicable: No
Preparing Activity: MDA
Applicable Forms: No

Approval Date: 20191114
Limitation:
GIDEP Applicable: No
Project Number: FACR-2019-005

Use/Relationship: The Seismic Qualification Document outlines the design, test procedures, documented data, and results for the site and the facility project. After facility acceptance, the data shall be retained for reference by the operations and maintenance personnel.

This DID contains the format, content, and intended use information for the data product resulting from the work task described in the contract SOW.

Requirements:

1. Format. Contractor format is acceptable. Format shall be machine-readable by the government.

2. Content. The Seismic Qualification Document shall contain the following:

2.1 Cover Page and Document Tracking Information.

2.1.1 Cover Page: Title, Date of Issue, Revision Date, Contract Number, Contractor's name and address, Distribution Statement, Export Control Warning Label, and Security classification,

2.1.2 Record of Change Page: Enter a record of all changes made to the Document.

2.2 Table of Contents. A listing of the major sections identified as below.

2.3 Overview. Describe the purpose of the Seismic Qualification Document (SQD) and the system(s) to which it applies.

2.4 Reference Documentation. List the applicable reference documentation.

2.5 Site Considerations. Identify the site, location, physical properties, and considerations that are applicable to the facility project. Provide subsurface investigation results and analysis that would affect ground motion. Provide the site threat/vulnerability assessment and risk analysis results that would affect the site and facility.

2.6 Seismic Design Performance Objectives. Outline the facility seismic design performance objectives derived from the threat/vulnerability assessment and risk analysis and indicate the grade level (Low, Moderate, or Large) of each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:01Z
Check the source to verify that this is the current version before use.

2.7 Design Analyses and Calculations. Provide the seismic installation design analysis and calculations necessary to substantiate the design performance objectives and design assumptions. Provide complete descriptions with cut sheets and photos.

2.8 Testing. Provide the type of testing, test procedures, test location, and results of testing. List the test standards and calibration methods for each test. Outline and provide the applicability of the testing to the design and design analysis. Indicate pass or failure for each test in relation to the design performance objectives and facility requirements.

2.9 Drawings. Provide drawings of the equipment and the location within the facility. Provide drawings outlining seismic details and accommodations for the facility.

2.10 Development Responses. Provide the development of in-structure demand response and the capacity response (fragility curve) for vertical and horizontal shaking. Provide the rationale and analysis that supports each response.

END OF DI-FACR-82307

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:01Z
Check the source to verify that this is the current version before use.