A-A-1741
April 17, 1981

COMMERCIAL ITEM DESCRIPTION

BATTERY CHARGER
(FOR 6/12/18/24 VOLTS)

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers automatic battery chargers of 120 volts, 60 Hz current.

Salient characteristics:

Designed for charging both maintenance free and conventional (including dry charge activation) batteries
Multi-position top switch.
Scaled ammeter.
Polarity protection.
Automatic reset circuit breaker.
Full wave rectification.
Triple insulated transformer.
DC charging leads - 8 feet of AWG No. 4.
Short-proof charging clamps.
Power cord with 10 feet of 3 conductor AWG No. 14.
Thermal overheat protection.
Rubber tread wheels.
Chargers shipped ready for service.
Marking, including identifying, rating, and cautionary, shall be in accordance with UL Standard No. 1236.

Discharged Battery Rating 6/12/18/24 Volts	UL Rating Amps 6/12/18/24 Volts	AC Input at 120 Volts, 60 Hz	Polarity Protection	Boot (Cranking) current
130/80/50/40 Amps	100/70/40/30	15 Amps	Positive Indicator	350 Amps

Issue of UL 1236 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices, and is the same product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. The items shall be packaged in accordance with normal commercial practice and packed to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

Copies of UL Standard No. 1236 are available from Underwriters Laboratories, Inc., 1285 Walt Whitman Road, Melville, Long Island, NY 11746.

Preparing activity:

GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:16Z
Check the source to verify that this is the current version before use.