FED-STD-H28/10A
21 June 1993
SUPERSEDING
FED-STD-H28/10
31 August 1978
(See Note)

# FEDERAL STANDARD
# SCREW-THREAD STANDARDS FOR FEDERAL SERVICES
# SECTION 10
# HOSE COUPLING AND FIRE HOSE COUPLING SCREW THREADS

This standard was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

AMSC N/A

AREA THDS

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.

INFORMATION SHEET ON FEDERAL STANDARDS

This Federal Standard is issued in loose-leaf form to permit the insertion or removal of new or revised pages and sections.

All users of Federal Standards should keep them up to date by inserting revised or new pages as issued and removing superseded and canceled pages.

New and revised pages will be issued under Change Notices which will be numbered consecutively and will bear the date of issuance. Change Notices should be retained and filed in front of the Standard until such time as they are superseded by a reissue of the entire Standard.

## FOREWORD

This section was developed to provide Hose Coupling and Fire Hose Coupling Screw Thread Standards for the Federal Services. It was formerly known as "American National Hose Coupling and Fire-Hose Coupling Threads". FED-STD-H28/10A is a complete revision of FED-STD-H28/10 dated 31 August 1978.

FED-STD-H28/10A was prepared by the Defense Industrial Supply Center (DLA-IS) and incorporates the American National Standards for Hose Coupling Screw Threads, ASME B1.20.7-1991, and for Screw Threads and Gaskets for Fire Hose Connections, NFPA 1963-1985. Changes from the previous issue include the following:

(1) Added 3/4-11.5NHR; 2 1/2, 3, 3 1/2, and 4-8NPSH threads.

(2) Applied thread designation 3/4-11.5NH to 1/2, 5/8, and 3/4 nominal sizes of garden hose.

(3) Increased tolerances on plain plug gages and ring gages from class Y to class Z.

(4) Changed major diameters of ring gage setting plugs to agree with the latest issue of FED-STD-H28/6.

(5) Deleted optional Y gage tolerance for pitch diameters of GO ring gages and their setting plugs.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.

# SECTION 10 - Hose Coupling and Fire Hose Coupling Screw Threads

1. Scope. This section provides the standards for hose coupling screw threads used for general purpose hoses and fire hose coupling screw threads for fire fighting water hoses and associated equipment. Gages and gaging for acceptance of coupling threads are also provided.

2. Referenced documents.

2.1 Government publications. The issues of the following documents in effect on the date of invitation for bids or request for proposal form a part of this standard to the extent specified herein.

FEDERAL STANDARDS

FED-STD-H28/1 - Nomenclature, Definitions and Letter Symbols for Screw Threads

FED-STD-H28/7 - Pipe Threads, General Purpose

(Activities outside the Federal Government may obtain copies of Federal specifications, standards, and commercial item descriptions as outlined under General Information in the Index of Federal Specifications, Standards, and Commercial Item Descriptions. The Index, which includes cumulative bi-monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this standard and other Federal specifications, standards and commercial item descriptions required by activities outside the Federal Government for bidding purposes are available from the General Services Administration, Federal Supply Service Bureau, Specifications Section, Suite 8100, 470 East L'Enfant Plaza, SW, Washington, DC 20407; telephone (202) 755-0325.

(Federal Government activities may obtain copies of Federal standardization documents, and the Index of Federal Specifications, Standards, and Commercial Item Descriptions from established distribution points in their agencies.)

2.2 Other publications. The following documents form a part of this standard to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.

AMERICAN NATIONAL STANDARDS

ASME B1.20.7-1991 - Hose Coupling Screw Threads (Inch)

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017-2392 or the American National Standards Institute, 11 West 42nd Street, New York, NY 10036-8002.)

NFPA 1963-1985 - Screw Threads and Gaskets for Fire Hose Connections

(Application for copies should be addressed to the National Fire Protection Association, One Batterymarch Park, Quincy, MA 02169-7473 or the American National Standards Institute, 11 West 42nd Street, New York, NY 10036-8002.)

3. Definitions. Screw thread terms applicable to this standard are defined in FED-STD-H28/1.

4. General requirements.

4.1 Garden hose coupling threads. Couplings for 1/2, 5/8, and 3/4 inch nominal hose sizes use 3/4-11.5NH threads or alternatively 3/4-11.5NHR threads. Basic profile of NH threads has a 60 degree included angle with major and minor diameter flat widths of 1/8 pitch. NHR threads are shallower than NH threads and are used on thin walled material which is formed to the required profile. Garden hose coupling threads, thread gages and acceptability requirements shall be in accordance with ASME B1.20.7-1991.

NOTE: Coupling threads, previously designated 1/2-11.5NH or 5/8-11.5NH, are the same as 3/4-11.5NH threads.

4.2 General purpose hose coupling threads. Couplings for steam, air, water, fuel and other general purpose hoses of nominal sizes 1/2 through 4 inch, use NPSH threads. NPSH threads have the same basic profile as NH threads but are sized to assemble with standard NPT pipe threads, FED-STD-H28/7. General purpose hose coupling threads, thread gages and acceptability requirements shall be in accordance with ASME B1.20.7-1991.

4.3 Fire hose coupling threads. Couplings for fire hoses, of nominal sizes 3/4 through 6 inch, and other associated equipment use NH threads. These threads will not assemble with garden hose or general purpose hose threads. Fire hose connection threads, their applications, and gages/gaging shall be in accordance with NFPA 1963-1985.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.

4.4 Special Navy/marine hose coupling threads. Four inch nominal size hose couplings for shipboard, use 4-6NH(SPL) threads and will not assemble with general purpose hose coupling threads or with standard fire hose coupling threads. These threads, their gages and acceptability requirements shall be in accordance with ASME B1.20.7-1991. Special fire hose couplings also exist for Military use with NPSH threads in accordance with ASME B1.20.7-1991.

5. Detailed requirements. Not applicable.

6. Notes.

6.1 Supersession note. In addition to superseding FED-STD-H28/10 dated 31 August 1978, this document also supersedes Appendix A9 of FED-STD-H28 dated 31 March 1978.

MILITARY INTERESTS:

Custodians:
Army - AR
Navy - AS
Air Force - 99

Review Activities:
Army - AT
Navy - SH
Air Force - 82, 84
DLA - CS

User Activity:
Navy - YD

Civil Agency Coordination Activities:

Commerce - NIST
GSA - 7FXE

PREPARING ACTIVITY:
DLA - IS

(DoD Project THDS-0090)



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.

# STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS

1. The preparing activity must complete blocks 1, 2, 3, and 8. In block 1, both the document number and revision letter should be given.
2. The submitter of this form must complete blocks 4, 5, 6, and 7.
3. The preparing activity must provide a reply within 30 days from receipt of the form.

NOTE: This form may not be used to request copies of documents, nor to request waivers, or clarification of requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

| I RECOMMEND A CHANGE: | 1. DOCUMENT NUMBER | 2. DOCUMENT DATE (YYMMDD) |
|---|---|---|
| | FED-STD-H28/10A | 21 June 1993 |

3. DOCUMENT TITLE

HOSE COUPLING AND FIRE HOSE COUPLING SCREW THREADS

4. NATURE OF CHANGE (Identify paragraph number and include proposed rewrite, if possible. Attach extra sheets if needed.)

5. REASON FOR RECOMMENDATION

6. SUBMITTER

| a. NAME (Last, First, Middle Initial) | b. ORGANIZATION | |
|---|---|---|
| c. ADDRESS (Include Zip Code) | d. TELEPHONE (Include Area Code)<br>(1) Commercial<br>(2) AUTOVON (If applicable) | 7. DATE SUBMITTED (YYMMDD) |

8. PREPARING ACTIVITY

| a. NAME | b. TELEPHONE (Include Area Code)<br>(1) Commercial | (2) AUTOVON |
|---|---|---|
| Defense Industrial Supply Center | 215-697-3637 | 442-3637 |
| c. ADDRESS (Include Zip Code)<br>ATTN: DISC-EPT<br>700 Robbins Avenue<br>Philadelphia, PA 19111-5096 | IF YOU DO NOT RECEIVE A REPLY WITHIN 45 DAYS, CONTACT:<br>Defense Quality and Standardization Office<br>5203 Leesburg Pike, Suite 1403, Falls Church, VA 22041-3466<br>Telephone (703) 756-2340 AUTOVON 289-2340 | |

DD Form 1426, OCT 89 *Previous editions are obsolete.* 198/290

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:53Z
Check the source to verify that this is the current version before use.