INCH-POUND
A-A-59954
21 MAY 2014

COMMERCIAL ITEM DESCRIPTION

TEMPERATURE CALIBRATOR

The General Services Administration has authorized the use of this Commercial Item Description (CID) as a replacement for Class 2 designs of MIL-PRF-28800 for all federal agencies.

1. SCOPE. This Commercial Item Description (CID) describes a Temperature Calibrator that is portable. Its intended purpose is to calibrate for both servo-powered and meter movement (D'arsonval) type temperature indicators. The temperature calibrator will measure and provide simulated source signals for thermocouples, resistance temperature detectors (RTD) and other millivolt transducers. The temperature calibrator will also test synch type temperature indicators. In addition, it will measure thermocouple circuit and thermocouple harness insulation resistance. The temperature calibrator is a support equipment test set that is used for depot and flight line tests.

2. CLASSIFICATION. The temperature calibrator shall be designed in accordance with the Class 2 requirements of MIL-PRF-28800.

3.0 SALIENT CHARACTERISTICS.

3.1 First article. First article testing is required except as otherwise specified herein; one sample shall be subjected to first article inspection in accordance with 5.2. The contractor shall demonstrate a successful design/redesign with no furnished equipment/property required by the Government.

3.2 Temperature calibrator. The temperature calibrator shall consist of a high brightness display and adapters to connect and test Movement thermo-couples, meter movement RTDs, servo thermo-couples and commercial thermo-couples. All necessary cables to test each component must be provided with the temperature calibrator.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any data that may improve this document should be sent to: WR-ALC 404 SCMS/GUEEA, 235 Byron Street Suite 19A, Robins AFB, GA 31098-1670. Since contact information can change, you may want to verify the currency of this address information using the ASSIST Online database at https://assist.dla.mil/ .

AMSC N/A FSC 6685

Distribution Statement A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

3.3 Design and construction. The temperature calibrator shall be designed and constructed so that no parts will work loose in service. It shall be built to withstand the strains, jars, vibrations, and other conditions incident to shipping, storage, installation, and service. It shall be weatherproof and designed to prevent the intrusion of water and sand into critical operating components. It shall be easy to be carried by one person and small enough such that it can be used with ease in small spaces such as a cockpit.

3.3.1 Materials, protective coatings, and finish.

3.3.1.1 Recycled, recovered, or environmentally preferable materials. Recycled, recovered, or environmentally preferable materials shall be used to the maximum extent possible provided that the material meets or exceeds the operational and maintenance requirements, and promotes economically advantageous life cycle costs. However, used, rebuilt, or refurbished items shall not be provided.

3.3.1.2 Protective coatings. Materials that deteriorate when exposed to sunlight, weather, or operational conditions normally encountered during the service life of the item shall not be used or shall have means of protection against such deterioration that does not prevent compliance with the performance requirements specified herein. Protective coatings that chip, crack, or scale with age or extremes of climatic conditions or when exposed to heat shall not be used. Fasteners, handles, and fittings used in the assembly of the item shall also be primed and painted. Surface preparation and pretreatment shall be in accordance with the respective primer and topcoat specifications.

3.3.1.3 Dissimilar metals. Dissimilar metals, as defined in MIL-STD-889, shall not be in contact with each other. Metal plating or metal spraying of dissimilar base metals to provide electromotively compatible abutting surfaces is acceptable. The use of dissimilar metals only when separated by suitable insulating material is permitted, except in systems where bridging of insulation materials by an electrically conductive fluid can occur. Sealants or gel type gasket materials shall be used between faying surfaces and butt joints.

3.3.1.4 Ventilation. Ventilation shall be sufficient to prevent moisture retention and buildup.

3.3.2 Markings. All external devices which require an operational or maintenance interface shall be marked in accordance with MIL-STD-130. Painted markings shall be 1-inch high block letters unless prohibited by the available space. In such cases, the markings shall be the largest size possible, but shall not be less than ½-inch high. Markings, Information/Caution shall be Lusterless Black, Color Number 37038 of FED-STD-595, and Markings, Warning/Danger shall be Lusterless Red, Color Number 31136 of FED-STD-595.

3.3.3 Identification and information plates.

3.3.3.1 Identification plate. An identification plate in accordance with MIL-STD-130 shall be securely attached to the temperature calibrator in a readily accessible location. The identification plate shall contain the following information: nomenclature, part number, serial number, date of manufacture, manufacturer's name, Commercial and Government Entity (CAGE) code, date of warranty expiration, and National Stock Number (NSN). The temperature calibrator and any components meeting Unique Identification (UID) criteria shall have UID information in

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

accordance with MIL-STD-130 permanently affixed near the respective identification plate(s). UID information shall be included as both a bar code and human readable markings.

3.3.4 Safety.

3.3.4.1 System safety. The design of the temperature calibrator shall not contain any system safety mishap risk categories greater than medium as defined in Table A-IV of MIL-STD-882.

3.3.4.2 Component protection. All space in which work is performed during operation, service, and maintenance shall be free of hazardous protrusions, sharp edges, or other features which may cause injury to personnel. All rotating and reciprocating parts and all parts subject to high operational temperatures or subject to being electrically energized, that are of such nature or so located as to be hazardous to personnel, shall be guarded or insulated to eliminate the hazard.

3.3.4.3 Foreign object damage (FOD). All loose metal parts, such as cable adapters, shall fit neatly in the temperature calibrator's case. "Dog tag" style beaded chains shall not be provided. Removable panels, if provided, shall be attached with captive fasteners.

3.3.4.4 Electromagnetic interference (EMI). The temperature calibrator shall be in accordance with the following radiated emission and susceptibility requirements of MIL-STD-461: CE102, CE106, CS101, CS103, CS104, CS105, CS114, CS115, CS116, RE102, and RS103.

3.3.4.5 Electrostatic discharge. The design of the temperature calibrator shall preclude equipment damage due to electrostatic discharge (ESD), protect personnel from electrical shock due to static charging, and prevent ignition of explosive atmospheres due to sparking.

3.3.5 Human factors. The temperature calibrator shall be designed in accordance with MIL-STD-1472 for ease of operation, inspection, and maintenance, including the use of arctic mittens and Mission- Oriented Protective Posture (MOPP) Level 4 Chemical Warfare Gear.

3.3.6 Fastening devices. All screws, bolts, nuts, pins, and other fastening devices shall be properly designed, manufactured, and installed with adequate means of preventing loss of torque or adjustment. Cotter pins, lock washers, or nylon patches shall not be used for this purpose, except for the attachment of trim items or as provided in commercial components. Tapped aluminum threads shall have a minimum thread engagement of at least two times the nominal fastener diameter.

3.3.7 Welders and welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surfaces to be welded shall be free from rust, scale, paint, grease, and other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the welded parts. Welds shall transmit stress without cracking or permanent distortion when the parts connected by the welds are subjected to test, proof, and service loadings.

3.3.8 Foolproofness. Where improper installation of an item causes a malfunction, an asymmetric mounting system shall be provided, where practical, to ensure proper mounting of the item.

3.3.9 Service life. The temperature calibrator shall be designed for a minimum service life of five years with no major repairs.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

3.4 Environmental conditions.

3.4.1 Operating temperature range. The temperature calibrator shall be capable of operating in ambient temperatures ranging from -40 degrees Celsius to +55 degrees Celsius.

3.4.2 Storage temperature range. The temperature calibrator shall be capable of being stored in ambient temperatures ranging from -40 degrees Celsius to +55 degrees Celsius.

3.4.3 Solar radiation. The temperature calibrator shall not be adversely affected by full time exposure to solar radiation, such as those conditions encountered in desert environments while exposed to temperatures specified in 3.4.1.

3.4.4 Salt fog. The temperature calibrator shall be capable of storage and operation in high temperature (see 3.4.1), high humidity, salt laden, and sea coast environments without damage or deterioration of performance.

3.4.5 Sand and dust. The temperature calibrator shall be capable of storage and operation during exposure to wind-blown sand or dust without damage or deterioration of performance.

3.5 Weight and dimensions. Overall weight and dimensions shall not exceed: 35 pounds; 20 inches in length; 15 inches in width; 15 inches in height. A handle for carrying the temperature calibrator shall be attached to the case. A mechanism for locking the temperature calibrator shall be provided.

3.6 Transportability.

3.6.1 Surface transportability. The temperature calibrator shall be transportable via all modes of surface shipment: rail, sea, road, etc. and shall be capable to withstand mechanical shock and vibration characteristics of rail, sea, and road transport.

3.6.2 Air transportability. The temperature calibrator shall be transportable for internal air transport in military prime mission cargo aircraft and long range international segment of the Civil Reserve Air Fleet (CRAF). Design criteria can be found in MIL-STD-1791. In all air transport configurations, the temperature calibrator shall be capable of being restrained and withstanding, without loss of serviceability, 2.0 G up and 4.5 G down accelerations, and shall be capable of being restrained and withstanding, without loss of structural integrity, 3.0 G forward, 1.5 G aft, and 1.5 G lateral accelerations. The temperature calibrator shall be equipped with pressure relief devices or configured for air transport to prevent any part from becoming a projectile in the event of catastrophic loss of aircraft cabin pressure.

3.7 Maintainability.

3.7.1 Preventive maintenance. The temperature calibrator shall have a recommended preventive maintenance interval (PMI).

3.8 Performance. The temperature calibrator shall be, at minimum, capable of performing diagnostics and calibration.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

3.8.1 Malfunction. The temperature calibrator shall be able to simulate individual components therefore identifying which components may be defective.

3.8.2 Power supply. The temperature calibrator shall power DC/AC indicators and simulate temperature input from a thermocouple to the indicators by sourcing: resistance, voltage or current.

3.8.3 Measuring device. The temperature calibrator shall measure voltage, resistance, and current from thermo-couples and millivolt transducers.

3.8.4 Connection. The temperature calibrator shall connect to all components (see 3.9) which might be tested.

3.8.5 Power source. The temperature calibrator shall be powered from an onboard battery provided with the temperature calibrator for up to 3.5 hours or be powered from a wall outlet (115V, 60Hz) without depleting the battery.

3.8.6 Extension cord. The temperature calibrator shall have a 10ft extension from the temperature calibrator to item under test.

3.8.7 Commercial thermocouples. The temperature calibrator shall test commercial type K, T, J, and TF-30 Thermocouples by measuring resistance or voltage.

3.9 Components.

3.9.1 Power cable. The temperature calibrator shall be equipped with an 115V 60Hz power cable which shall plug into a commercial power outlet. A 230V 60 Hz (ac) voltage shall also be included for synchro testing which requires voltage from an aircraft or power supply. The cable must be at least 6ft long and no more than 10ft long.

3.9.2 Resistances check cable. The temperature calibrator shall be equipped with a resistance check cable. The resistance cable must be at least 5ft long and no more than 8ft long. The ends of the cable shall have small alligator type clips.

3.9.3 RTD indicator cables. The temperature calibrator shall have the ability to test all applicable RTD indicators. The RTD indicators shall come with hermetically sealed, electrical receptacle wiring.

3.9.4 Servo and movement thermocouple indicators. The temperature calibrator shall have the ability to test servo and movement thermocouples. The servo and movement indicators shall come with hermetically sealed, electrical receptacle wiring.

3.9.5 Interface. An interface shall be provided. It shall display values, between 50 and 100 degrees F, being measured or sourced with the following accuracy:

a. Temperature values in Degrees Celsius or Fahrenheit, user select +/-1 degree.

b. Resistance +/- .5 Ohm.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

c. Voltage (measure or source) +/-.05mV

3.9.6 On/off switch. The temperature calibrator shall have an on/off switch to save power.

3.9.7 Battery indicator. The temperature calibrator shall have a battery charge indicator which shows the state of charge of the onboard battery.

3.9.8 Source/measure. The temperature calibrator shall have a source/measure switch such that it is clear which operation, measuring a voltage or creating a voltage/current level to test a subject, is being performed.

3.9.8.1 Voltage sourcing capability. When sourcing voltages, the temperature calibrator shall have the ability to tune the output voltage, range 0-35V, down to .5mV of the desired output. The temperature calibrator shall have the ability to source 22.5 or 28.5 +/-.5mV for testing RTD indicators. The temperature calibrator shall have the ability to simulate the voltage range of RTD indicators.

3.9.8.2 External AC voltage. The temperature calibrator shall have the ability to simulate the voltage range of Synchro Indicators using Aircraft AC voltage. The incoming voltage shall be displayed on the indicator. Methods to tune the incoming voltage to the requirements of the item under test shall be provided.

3.9.9 Mode selection switch. The temperature calibrator shall have a mode selection capability such that the level being read or measured can be determined: ohms, current, voltage, AC, DC.

3.9.10 RTD indicator. The temperature calibrator shall have the ability to test single/dual RTD indicators.

3.9.11 Workmanship. The temperature calibrator, including all parts and accessories, shall be constructed and finished in a thoroughly workmanlike manner. Workmanship objectives shall include freedom from blemishes, defects, burrs, sharp corners and edges; accuracy of dimensions, surface finish, and radii of fillets; thoroughness of welding, painting, and riveting; marking of parts and assemblies; proper alignment of parts and tightness of assembly fasteners; maintainability and operation of hydraulic lines and fittings; etc.

3.9.12 Bolted connections. Bolt holes shall be accurately punched or drilled and shall be de-burred. Threaded fasteners shall be tight and shall not work loose during testing or service usage.

3.9.13 Riveted connections. Rivet holes shall be accurately punched or drilled and shall be de-burred. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads shall be full, neatly made, concentric with the rivet holes and in full contact with the surface of the component.

3.9.14 Instructions. Clearly written instructions to use the machine shall be provided on the temperature calibrator's interface.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

4. REGULATORY REQUIREMENTS

4.1 The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

4.2 Green Procurement Program. Green Procurement Program (GPP) is a mandatory federal acquisition program that focuses on the purchase and use of environmentally preferable products and services. GPP requirements apply to all acquisitions using appropriated funds, including services and new requirements. FAR 23.404(b) applies and states the GPP requires 100% of EPA designated product purchase that are included in the Comprehensive Procurement Guidelines list that contains recovered materials, unless the item cannot be acquired: a) competitively within a reasonable timeframe; b) meet appropriate performance standards, or c) at a reasonable price. The prime contractor is responsible for ensuring that all subcontractors comply with this requirement.

5. PRODUCT CONFORMANCE

5.1 Testing. Compliance with all requirements specified in this document shall be accomplished through the use of first article testing. The testing requirements specified herein are required to obtain first article approval:

a. In plant contracting testing.

b. Compatibility testing.

5.2 First article testing.

5.2.1 In plant testing. The first article unit shall be subjected to the examinations, tests, and analyses described in section 5.4. Apparatus used in conjunction with the testing specified herein shall be laboratory precision type, calibrated at proper intervals to ensure laboratory accuracy, and supplied by the contractor. The Contractor's facility or subcontracted facility shall be utilized to perform the in plant testing. No further testing will occur until the in-plant first article testing is complete and the in-plant first article test report is reviewed and approved by the Government. The contractor shall be responsible for performing all in-plant first article testing. Tests shall be witnessed by the Government or its representative, unless otherwise noted.

5.2.2 Compatibility testing. After successful completion of the in plant first article testing specified in section 5.2, the first article test unit shall be subject to a compatibility testing performed by military personnel. Following Government approval of the test report from the in-plant first article testing, the contractor will be notified within twenty-one (21) days where the test unit will need be transferred to. The contractor shall provide support (telephone, e-mail, or fax) as required for the compatibility test, although the Government will administer the test. The contractor shall be responsible for all costs associated with the transportation, to and from, of the first article test unit. Upon arrival of the first article test unit, commencement of the compatibility testing will occur by government personnel and be completed within 60 days. Compatibility test shall be satisfactorily completed prior to First Article acceptance.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

5.3 Inspection requirements.

5.3.1 General inspection requirements. Apparatus used in conjunction with the inspections specified herein shall be laboratory precision type, calibrated at proper intervals to ensure laboratory accuracy, and supplied by the contractor.

5.3.2 Data. During all testing specified herein, at least the following data, unless not applicable, shall be recorded at intervals not to exceed 1 minute. Additional data and/or shorter intervals shall be provided as appropriate for any specific test.

a. Date.

b. Time started.

c. Time finished.

d. Ambient temperature.

e. Item under test.

f. Item value provided/expected.

g. Item value read.

5.3.3 Test rejection criteria. Throughout all tests specified herein, the temperature calibrator shall be closely observed for the following conditions, any occurrence of which shall be cause for rejection:

a. Failure to conform to design or performance requirements specified herein.

b. Structural failure of any component, including permanent deformation, or evidence of impending failure.

c. Evidence of excessive wear.

d. Misalignment of components.

e. Conditions that present a safety hazard to personnel during operation, servicing, or maintenance.

f. Evidence of corrosion or deterioration.

5.4 Test methods.

5.4.1 Examination/ demonstration of product. The temperature calibrator shall be examined or demonstrated to verify compliance with the requirements herein. A contractor-generated, Government-approved checklist that identifies each relevant requirement not verified by a test or analysis and the inspection results shall be used. Particular attention shall be given to materials, workmanship, dimensions, and markings. Copies of all certificates and test data required herein

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

shall be provided to the Government in the first article test report. The contractor shall certify and maintain substantiating evidence that the product offered meets the characteristics of this document and that the product conforms to the producer's own drawings, specifications, workmanship standards, and quality assurance practices. Items with known defects shall not be submitted for Government acceptance.

5.4.2 System safety hazard analysis. A system safety hazard analysis of the temperature calibrator shall be conducted in accordance with 5.2 through 5.8 of MIL-STD-882 to demonstrate compliance with the mishap risk requirement of 3.3.4.1.

5.4.3 Electromagnetic interference test. The first article temperature calibrator shall be tested in accordance with MIL-STD-461: CE102, CE106, CS101, CS103, CS104, CS105, CS114, CS115, CS116, RE102, and RS103.

5.4.4 Electrostatic discharge analysis. An engineering analysis shall be performed to demonstrate compliance with the electrostatic discharge requirement of 3.3.4.5.

5.4.5 Service life analysis. An engineering analysis shall be performed to demonstrate compliance with the service life requirement of 3.3.9.

5.4.6 Environmental testing.

5.4.6.1 High temperature storage and operation test. The first article temperature calibrator shall be tested in accordance with MIL-STD-810, Method 501.5, Procedures I and II, to demonstrate compliance with the high temperature storage and operating requirements of 3.4.1 and 3.4.2. Test duration shall be one 24-hour cycle for each procedure.

5.4.6.2 Low temperature storage and operation test. The first article temperature calibrator shall be tested in accordance with MIL-STD-810, Method 502.5, Procedures I and II, to demonstrate compliance with the low temperature storage and operating requirements of 3.4.1 and 3.4.2. Test duration shall be one 24-hour cycle for each procedure.

5.4.6.3 Solar radiation. Contractor certification that the temperature calibrator performance is not adversely affected by full time exposure to solar radiation, such as those conditions encountered in desert environments.

5.4.6.4 Salt fog test. The first article temperature calibrator shall be tested in accordance with MIL-STD-810, Method 509.5, to demonstrate compliance with 3.4.4. Test duration shall be alternating 24-hour periods of salt fog exposure and drying conditions for 24-hour periods (two wet and two dry).

5.4.6.5 Sand and dust test. The first article temperature calibrator shall be tested in accordance with MIL-STD-810, Method 510.5, Procedures I and II, to demonstrate compliance with 3.4.5.

5.4.7 Weight and dimension measurement.

5.4.7.1 Weight. The weight of the first article temperature calibrator shall be measured to demonstrate compliance with the weight requirements of 3.5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

5.4.7.2 Dimension measurement. The first article temperature calibrator shall be measured to demonstrate compliance with the dimensional requirements of 3.5.

5.4.8 Transportability verification.

5.4.8.1 Surface transportability analysis. An engineering analysis shall be performed to demonstrate compliance with 3.6.1. The engineering analysis shall utilize the data for rail, ship, and road transportation modes referenced in MIL-STD-810, Method 514.6.

5.4.9 Maintainability demonstration. Preventive maintenance tasks shall be selected by the procuring activity from an approved list of tasks provided by the contractor and shall be performed. This list shall represent all expected failures over the life of the temperature indicator. Five of the tasks shall be selected by the Government. As part of the in plant testing, the recommended frequencies of the preventive maintenance tasks and the times recorded to accomplish the tasks shall be used to develop an expected value of preventive maintenance time per measure of use, such as calendar time and hours of operation. The capability of performing preventive maintenance tasks by personnel wearing arctic mittens and MOPP Level 4 Chemical Warfare Gear shall be demonstrated.

5.4.10 Malfunction test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.1.

5.4.11 Power supply test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.2.

5.4.12 Measuring device test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.3.

5.4.13 Connection test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.4.

5.4.14 Power source test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.5.

5.4.15 Extension cord test. The temperature calibrator shall be examined for compliance with 3.8.6.

5.4.16 Commercial thermocouples test. The temperature calibrator shall be tested to demonstrate compliance with 3.8.7.

5.4.17 Power cable test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.1.

5.4.18 Resistance check cable. The temperature calibrator shall be examined for compliance with 3.9.2.

5.4.19 RTD indicator cables. The temperature calibrator shall be tested to demonstrate compliance with 3.9.3.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

5.4.20 Servo and movement thermocouple indicators test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.4.

5.4.21 Interface test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.6.

5.4.22 On/off switch test. The temperature calibrator shall be examined and tested to demonstrate compliance with 3.9.7.

5.4.23 Battery indicator test. The temperature calibrator shall be examined for compliance with 3.9.8.

5.4.24 Source/measure test. The temperature calibrator shall be examined for compliance with 3.9.9.

5.4.25 Voltage sourcing capability test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.9.1.

5.4.26 External AC voltage test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.9.2.

5.4.27 Mode selection switch test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.10.

5.4.28 RTD indicator test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.11.

5.4.29 Instructions test. The temperature calibrator shall be tested to demonstrate compliance with 3.9.15.

6. PACKAGING

6.1 Packaging resources. For acquisition purposes, the packaging requirements shall be as specified in the contract or order (see 7.3). When packaging of materiel is to be performed by Department of Defense (DoD) or in-house contractor personnel, these personnel need to contact the responsible packaging activity to ascertain packaging requirements. Packaging requirements are maintained by the Inventory Control Point's packaging activities within the Military Service or Defense Agency, or within the military service's system commands. Packaging data retrieval is available from the managing Military Department's or Defense Agency's automated packaging files, CD-ROM products, or by contacting the responsible packaging activity.

7. NOTES

7.1 Intended use. The temperature calibrator is intended to be a portable calibrator for both servo-powered and meter movement (D'arsonval) type temperature indicators. The temperature calibrator will measure and provide simulated source signals for thermocouples, resistance temperature detectors (RTD) and other millivolt transducers. The temperature calibrator will also test synch type temperature indicators. In addition, it will measure thermocouple circuit and thermocouple harness insulation resistance. The temperature calibrator is a support equipment

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

test set that is used for depot and flight line tests. The contractor shall demonstrate a successful design/redesign with no furnished equipment/property required by the Government.

7.2 Source of documents.

7.2.1 The FAR may be obtained from the Superintendent of Documents, P.O. Box 371954, Pittsburgh PA 15250-7954. Electronic copies of the FAR may be obtained from https://www.acquisition.gov/far/.

7.2.2 Military Specifications, Standards, and Handbooks referenced herein may be obtained at http://quicksearch.dla.,mil or available from the Standardization Documents Order Desk, 700 Robbins Ave, Bldg. 4, Section D, Philadelphia, PA 19111-5094. Phone (215) 697-1187, FAX (215) 697-2978, or Customer Service (215) 697-2667/2179.

7.3 Acquisition requirements. Acquisition documents must specify the following:

a. Title, number and date of the CID.
b. When first article is required (see 3.1)
c. Packaging requirements (see 5)

7.4 RTD indicator cable wiring. The RTD indicators will come hermetically sealed and electrical receptacle wired as follows:

Pin	Connection
A	Power voltage (21-29V DC)
B	Resistance bulb connection
C	Ground and remaining bulb connection
D	5V lighting input (if Applicable)
E	5V lighting ground (if Applicable)

7.5 Servo and movement indicators wiring. The servo and movement indicators will come hermetically sealed and electrical receptacle wired as follows:

Pin	Connection
A	Alumel conductor
B	Open
C	115 V 400-cps input
D	Chromel conductor
E	5V ac or dc input for lighting
F	115V 400-cps and 5V ground. Case ground
G	Open

- see applicable MIL-SPEC for additional information

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.

7.6 National Stock Number (NSNs). The following is a list of NSNs assigned that correspond to this CID. The list may not be indicative of all possible NSNs associated with this CID.

NSN	6685-01-570-5253

7.7 Key Words.

Indicators
Meter movement
Portable
Resistance temperature detectors (RTD)
Servo-powered
Support equipment
Temperature measurement
Test set
Thermocouple circuit
Thermocouple harness

MILITARY INTEREST

Custodians:
Air Force - 84

Preparing Activity:
Air Force - 84

Reviewer:
Air Force – 11, 71, 99

Agent:
Air Force – 99
(Project 6685-2014-001)

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil/ .

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:31Z
Check the source to verify that this is the current version before use.