| NOT MEASUREMENT SENSITIVE |

MIL-F-16716E
23 August 1990
SUPERSEDING
MIL-F-16716D
23 February 1982

MILITARY SPECIFICATION

FANS, CENTRIFUGAL, INDUSTRIAL

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers electric-motor-driven centrifugal fans which are not integral parts of equipment designed as complete units be manufactured, and which are designed for ventilating uses and industrial air-handling applications.

1.2 Classification. The fans are of the following types, as specified (see 6.2).

Type I - Forward-curved blades.
Type II - Radial blades.
Type III - Backward-inclined blades.

1.2.1 Part or Identifying Number (PIN). A specification-based PIN to identify types and sizes is included in 6.3.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications. The following specifications form a part of this document to the extent specified herein. Unless otherwise specified, the issues

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4140

DISTRIBUTION STATEMENT A. Approved for public release, distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the specification (see 6.2).

SPECIFICATIONS

FEDERAL

ZZ-B-225 - Belt, V, Industrial (Multiple Drive).

MILITARY

MIL-E-16298 - Electric Machines Having Rotating Parts and Associated Repair Parts, Packaging of.

(Unless otherwise indicated, copies of specifications are available from Standardization Documents Order Desk, Bldg. 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094.)

2.1.2 Other Government documents. The following other Government documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues are those cited in the solicitation.

DEPARTMENT OF LABOR (DOL)
OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION (OSHA)

Title 29, CFR, Part 1910.219 - Occupational Safety and Health Standards.

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington, DC 20406.)

(Copies of specifications, standards, handbooks, drawings, publications, and other Government documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DODISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS are the issues of the documents cited in the solicitation (see 6.2).

AIR MOVEMENT AND CONTROL ASSOCIATION (AMCA)

AMCA 99 - Drive Arrangements for Tubular Centrifugal Fans.
AMCA 210 - Laboratory Methods of Testing Fans for Rating.
AMCA 300 - Reverberant Room Method for Sound Testing of Fans.

(Application for copies should be addressed to the Air Movement and Control Association, 30 W. University Drive, Arlington Heights, IL 60004.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

AMERICAN NATIONAL STANDARDS INSTITUTE, INC. (ANSI)

ANSI B15.1 - Mechanical Power - Transmission Apparatus, Safety Code for.

(Application for copies should be addressed to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.)

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA ICS 1 - General Standards for Industrial Control and Systems.
NEMA ICS 2 - Standards for Industrial Control Devices, Controllers, and Assemblies.
NEMA ICS 6 - Enclosures for Industrial Control and Systems.
NEMA MG 1 - Motors and Generators.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.)

RUBBER MANUFACTURERS ASSOCIATION (RMA)

RMA Engineering Standards for Multiple V-Belt Drives.

(Application for copies should be addressed to the Rubber Manufacturers Association, 1901 Pennsylvania Avenue, Washington, DC 20006.)

(Non-Government standards and other publications are normally available from the organizations that prepare or distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Description. The unit shall consist of a centrifugal fan, electric motor, guards, and accessories. All components shall be attached to a common base which shall include provisions for fastening it to a foundation. The unit shall be completely assembled, ready for installation.

3.2 First article. When specified (see 6.2), the contractor shall furnish a fan of the type required for first article inspection and approval (see 4.2.1 and 6.5).

3.3 Standard commercial product. The fan shall, as a minimum, be in accordance with the requirements of this specification and may be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product, may be included in the fan being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements of manufacturer's catalogs, or brochures, and represents the latest production model.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

3.3.1 System of measurement. The dimensions used in this specification are not intended to preclude the use of metric system of measurement in the fabrication and production of the material, individual parts, and the finished product, provided form, fit, and function requirements are satisfied.

3.4 Materials. Materials used shall be free from defects which would adversely affect the performance of maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new.

3.5 Interchangeability. All units of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

3.6 Standards compliance. Fans shall be capacity rated in accordance with AMCA 210 and sound rated in accordance with AMCA 300, prior to approval of the first article, if one is specified, or prior to approval of the first shipment, if a first article is not specified. The supplier shall submit to the contracting officer satisfactory evidence that the fan he proposes to furnish has been rated in accordance with AMCA 210 and AMCA 300.

3.7 Design. The fan assembly shall be designed to handle clean or dust-laden air at temperatures up to 250 degrees Fahrenheit (°F), and up to 600°F when equipped with a bearing cooling device (see 3.10.3.1). The design of the equipment and accessories shall permit accessibility for maintenance and service in the field. The design shall be such as to prevent conditions hazardous to personnel or deleterious to equipment. The fan assembly shall be built in accordance with AMCA 99.

3.8 Safety. All parts which are energized electrically shall be insulated, fully enclosed, or guarded when such parts are exposed to contact by personnel or otherwise create a hazard. All moving parts hazardous to personnel shall be enclosed or guarded. Nonfunctional sharp edges, projecting points, and excessive length of fastening devices shall be avoided. Protective devices shall be mounted on or near components containing hidden hazards. Applicable portions of OSHA Title 29, CFR, Part 1910.219 shall apply.

* 3.9 Performance. The fan shall deliver its rated capacity in cubic feet per minute at the static pressure in inches of water specified (see 6.2) with tolerances set forth in AMCA 210. Fan sound power level shall not exceed 90 decibels, A-weighted scale, continuous or intermittent, at five feet from the equipment.

3.10 Details of components. The unit shall consist of the components specified below; and when the motor is connected to the matching power source, the unit shall function in accordance with the performance requirements.

* 3.10.1 Fan wheel. Unless otherwise specified (see 6.2), the fan wheel shall be constructed of cast aluminum alloy or carbon steel plate, as specified (see 6.2). Each steel blade shall be riveted or welded to form the fan wheel.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

* 3.10.2 Fan shaft. Unless otherwise specified (see 6.2), the shaft shall be turned, ground, and polished carbon steel alloy. The maximum allowable turnout after all machining shall be 0.001 inch on shafts with diameter less than or equal to 1.5 inches in diameter and 0.002 inches on shafts greater than 1.5 inches in diameter. The shaft shall be sized for maximum speed of the size of fan involved and shall operate at not more than 80 percent of the first critical speed.

* 3.10.3 Fan bearings. Unless otherwise specified (see 6.2), the fan shall be equipped with precision anti-friction bearings with an average life of B-10. The bearings shall be of the self-alining type and shall be mounted in suitable pillow blocks having provision for attachment to the fan housing or base assembly.

3.10.3.1 Bearing cooling device. When specified (see 6.2), a bearing cooling fan of suitable size, of split design, or a heat slinger shall be provided with anti-friction bearing when the air temperature in the fan is greater than 250°F but not less than 600°F.

3.10.4 Fan housing. The housing shall be constructed of carbon steel plate or sheet and of a nominal thickness not less than that listed in table I. The scroll and side plate joints shall be made airtight. The housing shall be reinforced to minimize vibration. When specified (see 6.2), the discharge direction for types I and III larger than 33 inches in fan diameter, and type II larger than 57 inches in fan diameter shall be easily converted at angles of 45 degrees. When specified (see 6.2), a threaded drain connection to accommodate a 1-inch or 3/4-inch diameter standard pipe, as specified (see 6.2). Standard pipe shall be located at the lowest point in the scroll. When specified (see 6.2), a flush type access door shall be installed on the fan scroll and held by quick-release clamps on type II fans. Inlet and outlet duct connections shall be flanged.

TABLE I. Housing gages.

Nominal fan diameter (inches)	Sides and Scroll
12 up to 16	16 gage
16 up to 24	14 gage
24 up to 72	12 gage
72 up to 132	10 gage

3.10.5 Motor. The motor shall conform to NEMA MG 1, and shall be capable of continuous operation when driving the fan at rated conditions, and may be single or multi-speed, unless one of these is definitely specified (see 6.2). Features of bearings, enclosure, and electrical characteristics shall be as specified (see 6.2). When specified (see 6.2), an across-the-line part-wind wye-delta or autotransformer shall be supplied. When specified (see 6.2), the motor shall be open drip proof, totally enclosed, or explosion proof.

3.10.5.1 Direct drive. When a direct drive is specified (see 6.2), the fan wheel shall be mounted on the motor shaft or driven through a suitable coupling

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

by the motor. The motor shall be alined to minimize drive line vibration. When specified (see 6.2), the assembly shall be mounted on resilient vibration isolators.

3.10.5.2 V-belt drive. The fan shall be driven by means of single or multiple V-belts. Quantity and cross-sectional size of the belts shall be determined by the motor horsepower rating corrected to the service and arc-of-contact factors. For the motor location specified, a standard belt length shall be used to the nearest, but not less than the recommended, motor and fan shaft center distance. Sheave pitch diameters shall be as specified by the manufacturer for the speed ratio and fan speed required. When specified (see 6.2), sheaves shall be of a variable pitch type. The motor shall be solidly mounted to a suitable base which shall provide for belt tension adjustment and for anchorage to the fan foundation. All exposed belt-driven fans shall have safety guards that conform to ANSI B15.1 and adjustable motor mounts for belt tension adjustment and belt replacement. V-belts shall conform to ZZ-B-225. Sheaves shall conform to NEMA MG 1 for minimum electric motor sheave diameter for a given horsepower motor. Motor sheaves shall be of the adjustable pitch type which provides a 20 percent speed variation, selected so that the specified capacity will be delivered with sheaves at approximately mid-position. V-belt drives shall be selected for continuous duty in accordance with RMA Engineering Standards for Multiple V-Belt Drives with a service factor of 1.5.

3.10.5.3 Motor starter. The starter control shall be manual or magnetic as specified (see 6.2), applicable NEMA type with thermal overload protection of the size and capacity suitable for the required service outlined in NEMA ICS 1 and NEMA ICS 2. The control enclosure shall be as required by NEMA ICS 6 and shall be as specified (see 6.2).

3.11 Guards.

3.11.1 Inlet guard. Unless otherwise specified (see 6.2), the type I and type III fans shall be provided with an air-inlet screen guard of heavy gage galvanized wire. The meshes of the screen guard shall not be greater than two inches square and not less than 1/2 inch square. If required to facilitate removal, the screen shall be of split construction.

3.11.2 V-belt guard. A protective guard of heavy gage wire or sheet metal shall be mounted to the fan unit to prevent objects from being jammed between the belts and sheaves.

3.11.3 Shaft and coupling guard. A protective guard of heavy gage wire or sheet metal shall be mounted on the fan unit to completely enclose the motor shaft, coupling, and fan shaft.

3.11.4 Bearing-cooling fan guard. When a bearing-cooling fan is supplied (see 3.10.3.1), a protective guard of heavy gage wire mesh shall be mounted on the fan unit to completely enclose the bearing-cooling fan.

3.12 Lifting attachments. When specified (see 6.2), suitable lifting attachment plate(s) shall be provided to enable the equipment to be lifted in its normal position. Attachment eye(s) shall be not less than three inches in diameter, and plate(s) shall withstand any handling conditions encountered, such

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

as rapid lowering and braking of the load. When practicable, only one attachment shall be used. Where more than one attachment is required, each attachment, when practicable, shall be of sufficient capacity to carry the total weight. A copper or zinc-base-alloy or aluminum plate securely fastened to the unit shall indicate diagrammatically the lifting capacity of each attachment.

3.13 Lubrication. Unless otherwise specified (see 6.2), means for lubricating shall be provided in accordance with the manufacturer's standard practice. Parts requiring lubrication shall be so located as to make the lubricating points easily visible and accessible. All parts requiring lubrication shall be properly lubricated before delivery. Manufacturer's standard means for pressure lubrication shall be provided.

3.14 Cleaning, treatment, and painting. Surfaces normally painted in good commercial practice shall be cleaned, treated, and painted as specified herein. Surfaces to be painted shall be cleaned and dried to insure that they are free from contaminants such as oil, grease, welding slag and spatter, loose mill scale, water, dirt, corrosion product, or any other contaminating substances. As soon as practicable after cleaning, and before any corrosion products or other contamination can result, the surfaces shall be prepared or treated to insure the adhesion of the coating system. The painting shall consist of at least one coat of primer and one finish coat. The primer shall be applied to a clean dry surface as soon as practicable after cleaning and treating. Painting shall be with manufacturer's current materials according to manufacturer's current processes and the total dry film thickness shall be not less than 2.5 mils over the entire surface. The paint shall be free from runs, sags, orange peel, or other defects.

3.15 Dissimilar metals. Metals dissimilar with respect to the galvanic scale shall not be used unless separated by an insulating material which will avoid electrolytic corrosion.

3.16 Workmanship.

3.16.1 Steel fabrication. The steel used in fabrication shall be free from kinks, sharp bends, and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the steel to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to insure uniformity of size and shape.

3.16.2 Riveted connections. Rivet holes shall be accurately punched or drilled and shall have the burrs removed. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads, when not countersunk or flattened, shall be of approved shape and of uniform size for the same diameter of rivet. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member.

3.16.3 Bolted connections. Bolt holes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided in accordance with good commercial practice, and all bolts, nuts, and screws shall be tight.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

3.16.4 Castings. All castings shall be sound and free from patching, misplaced coring, warping, or any other defect which reduces the casting ability to perform its intended function.

3.16.5 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items shall meet all requirements of section 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.2 Classification of inspection. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).
c. Packaging inspection (see 4.5).

4.2.1 First article inspection. First article inspection shall be performed on one fan when a first article is required (see 3.2 and 6.4). This inspection shall include the examination of 4.3 and the tests of 4.4. Failure of the first article to pass the examination or any of the tests shall be cause for rejection. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

4.2.2 Quality conformance. Each fan furnished under a contract shall be examined in accordance with 4.3 and tested in accordance with 4.4.1.

4.3 Examination. Each fan shall be examined for compliance with the requirements specified in section 3 of this specification. Any redesign or modification of the contractor's standard product to comply with specified requirements, or any necessary redesign or modification following failure to meet specified requirements shall receive particular attention for adequacy and suitability. This element of inspection shall encompass all visual examinations and dimensional measurements. Noncompliance with any specified requirements or presence of one or more defects preventing or lessening maximum efficiency shall constitute cause for rejection.

4.4 Tests. The first article, when furnished, shall be tested, and any unit failing to pass the following tests, as applicable, shall be rejected. Tests shall be conducted as outlined in the referenced documents and as herein specified.

4.4.1 Operational test. The fan unit shall be connected to the specified power source and operated for ten minutes. The fan wheel, motor, and accessories shall be inspected during the test for vibration, overheating, and loose parts.

4.4.2 Capacity test. The fan shall be subjected to air volume and pressure tests in accordance with AMCA 210. The test shall be performed as outlined in the test code.

4.5 Packaging inspection. The preservation, packing, and marking of the fans shall be inspected to the requirements of section 4 of MIL-E-16298. When specified (see 6.2), a preproduction pack inspection shall be performed in accordance with MIL-E-16298.

5. PACKAGING

5.1 Preservation, packing, and marking. The fans shall be preserved, packed, and marked in accordance with MIL-E-16298. The level of preservation and packing shall be as specified (see 6.2).

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

6.1 Intended use. The three types of centrifugal fans covered in this specification apply to fans which are not integral parts of equipment designed as complete units by manufacturers, and are intended to be used as follows. Type I, forward-curved fans, should be used where compactness of site is a factor in packaged unit applications (example: in a heating or a high efficiency air conditioning system). Type II, radial blade fans, should be used in systems handling such materials as heavy dust (example: in a woodworking shop). Type III, backward-inclined blade fans, which may be used in air conditioning applications, should be used when high efficiency and nonoverloading characteristics are required to move air containing no condensable fume or vapors (example: in a power generating plant).

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

6.1.1 Selection factors.

a. Fungus resistant varnish conforming to MIL-V-173 should be used to coat electrical components and circuit elements, including terminal and circuit connections, when the fan is to be installed in humid conditions. Components and elements inherently inert to fungi or in hermetically sealed enclosures or current-carrying contact surfaces should not be coated.
b. Electromagnetic interference suppression (EMI), when required, should conform to the EMI suppression requirements and test limits for class C3, group I equipment as specified in MIL-STD-461. The fan should be subjected to tests to determine conformance in accordance with MIL-STD-462.

6.2 Acquisition requirements. Acquisition documents should specify the following:

a. Title, number, and date of the specification.
b. Type of fan required (see 1.2).
c. Issue of DODISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1.1 and 2.2).
d. When a first article is required (see 3.2 and 6.5).
e. Capacity at the required static pressure (see 3.9).
f. Fan wheel and fan shaft material required (see 3.10.1 and 3.10.2).
g. Requirement for bearings if other than specified (see 3.10.3).
h. When bearing-cooling fan is required (see 3.10.3.1).
i. Angle of discharge if other than specified (see 3.10.4).
j. When a drain connection is to be fitted to the scroll and size required (see 3.10.4).
k. When an access door is to be installed on the fan scroll of type II fans (see 3.10.4).
l. Whether motor is to be single or multi-speed; features of bearing, enclosure, and electrical characteristics; and when an across-the-line part-wind wye-delta or autotransformer is required (see 3.10.5).
m. When the motor is to be open, drip proof, totally enclosed, or explosion proof (see 3.10.5).
n. When a direct drive is required, and whether resilient vibration isolators are required (see 3.10.5.1).
o. Sheave type requirements (see 3.10.5.2).
p. Type of motor starter control, and control enclosure requirements (see 3.10.5.3).
q. Requirement for air inlet guard if other than specified (see 3.11.1).
r. When lifting devices are required (see 3.12).
s. Lubrication requirements (see 3.13).
t. When the preproduction pack inspection requirements are required (see 4.5).
u. Level of preservation and packing required (see 5.1).

* 6.3 Part or identifying number (PIN). The PIN to be used for fans applied to this specification are created as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

	M16716	X
Specification part number		
Type code number (see 6.3.2)		

* 6.3.2 Type code number. The type of fans is identified by a single digit number as follows:

Type I - 1
Type II - 2
Type III - 3

6.4 Data requirements. When this specification is used in an acquisition and data are required to be delivered, the data requirements shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved Contract Data Requirements List (DD Form 1423), incorporated into the contract. When the provisions of DOD FAR Supplement, Part 27, Sub-Part 27475.1 (DD Form 1423) are invoked and the DD Form 1423 is not used, the data shall be delivered by the contractor in accordance with the contract or purchase order requirements.

6.5 First article. When a first article inspection is required, the item will be tested and should be a first production item or it may be a standard production item from the contractor's current inventory (see 6.2) as specified in 4.2.1. The first article should consist of one unit. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

* 6.6 Subject term (key word) listing.

Air handling
Ventilation

6.7 Changes from previous issue. The margins of this specification are marked with asterisks to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Custodians:
Army - ME
Navy - YD

User Activities:
Army - CE
Navy - MC

Preparing Activity:
Navy - YD

(Project 4140-0141)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T09:19Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS

1. The preparing activity must complete blocks 1, 2, 3, and 8. In block 1, both the document number and revision letter should be given.
2. The submitter of this form must complete blocks 4, 5, 6, and 7.
3. The preparing activity must provide a reply within 30 days from receipt of the form.

NOTE: This form may not be used to request copies of documents, nor to request waivers, or clarification of requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

I RECOMMEND A CHANGE:	1. DOCUMENT NUMBER MIL-F-16716E	2. DOCUMENT DATE (YYMMDD) 1990 August 23

3. DOCUMENT TITLE
FANS, CENTRIFUGAL, INDUSTRIAL

4. NATURE OF CHANGE (*Identify paragraph number and include proposed rewrite, if possible. Attach extra sheets as needed.*)

5. REASON FOR RECOMMENDATION

6. SUBMITTER

a. NAME (Last, First, Middle Initial)	b. ORGANIZATION	
c. ADDRESS (Include Zip Code)	d. TELEPHONE (Include Area Code) (1) Commercial (2) AUTOVON (If applicable)	7. DATE SUBMITTED (YYMMDD)

8. PREPARING ACTIVITY

a. NAME A. L. LYONS, Project Manager Equipment Criteria Development Div.	b. TELEPHONE (Include Area Code) (1) Commercial: (805) 982-5801 x421 (2) AUTOVON: 551-5801 x421
c. ADDRESS (Include Zip Code) Commanding Officer (156) Naval Construction Battalion Center Port Hueneme, CA 93043-5000	IF YOU DO NOT RECEIVE A REPLY WITHIN 45 DAYS, CONTACT: Defense Quality and Standardization Office 5203 Leesburg Pike, Suite 1403, Falls Church, VA 22041-3466 Telephone (703) 756-2340 AUTOVON 289-2340

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T00:10Z
Check the source to verify that this is the current version before use.