RR–F–183
AMENDMENT–4
MAY 4, 1962

SUPERSEDING
Int. Am–3,
June 13, 1961 and
Amendment–1
November 8, 1949

FEDERAL SPECIFICATION

FENCE-POSTS, GATES, AND ACCESSORIES

This amendment, which forms a part of Federal Specification RR–F–183, dated August 13, 1946, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Page 1, paragraph C–1 *Materials,* lines 2–3: Delete "having a carbon content of not less than 0.10 percent".

Page 2, Table I: Delete in its entirety and substitute new table I and add table II.

Page 3, paragraph D–2 *Zinc coating*: Delete last sentence beginning with "The zinc coating," and add new paragraph D–2a:

D–2a The weight of the zinc coating per square foot of actual surface shall average not less than 2.0 ounces and no individual specimen shall show less than 1.8 ounces.

Page 3, present paragraph D–2a: Renumber as "D–2b".

Page 4, paragraph E–5, line 1: Delete "(tubular)" and substitute "or square (tubular) or H-Section".

Page 5, paragraph F–1b, line 1: Delete "uniformity and".

Page 5, paragraph F–3a: Delete entire paragraph and substitute new paragraph F–3a.

F–3a Weight of zinc coating shall be determined in accordance with the provisions stipulated in ASTM Designations A120 or A123 (latest issue) whichever is appropriate for the product under test.

Page 7, following paragraph I–6 add new table III.

Page 7, paragraph I–8, delete and add new paragraph I–8 as follows:

I–8 *Transportation description.* Transportation descriptions and minimum weights applicable to this commodity are:

Rail:
Fence posts, steel
Carload minimum weight 40,000 pounds

Motor:
Fence posts, steel.
Truckload minimum weight 40,000 pounds, subject to Rule 34, National Motor Freight Classification.

Rail:
Fence gates, steel
Carload minimum weight 36,000 pounds.

Motor:
Fence gates, steel, not otherwise indexed.
Truckload minimum weights 25,700, 30,900 and 36,000 pounds, subject to Rule 34, National Motor Freight Classification.

Rail:
Fence post fixtures, steel
Carload minimum weight 40,000 pounds

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

TABLE I—*Dimensions and weights*

Use and Section		Size *	Outside diameter nominal	Weight per foot, nominal
			Inches	*Pounds*
End corner and pull posts (tubular) for fabric heights:				
6 ft. and less	Round	2	2.375	3.65
	Square		2.0	3.85
Over 6 feet:	Round	2½	2.875	5.79
	Square		2.5	5.70
Gate posts for nominal width of gate (single, or one leaf of double):				
Gate width				
6 ft. and less:	Round	2½	2.875	5.79
	Square		2.5	5.70
Gate width over:				
6 ft. to 13 ft:	Round	3½	4.00	9.11
	Square		3.0	9.10
Gate width over:				
13 ft. to 18 ft.:	Round	6	6.625	18.97
Gate width over 18 ft.	Round	8	8.625	24.70
Gates: Exterior frames for fabric heights:				
6 ft. and less	Round	1¼	1.660	2.27
	Square		1.50	1.90
Over 6 ft.	Round	1½	1.900	2.72
	Square		2.00	2.60
Interior bracing (tubular) for fabric heights:				
6 ft. and less	Round	1	1.315	1.68
Over 6 ft.	Round	1¼	1.660	2.27
	Square		1.50	1.90
Rails and post braces:				
Round (tubular)		1¼	1.660	2.27
Square (tubular)			1.50	1.90
H-Section		1.5x1.31	25x.125	2.27
Intermediate posts for fabric heights:				
6 ft. and less Tubular (round)		1½	1.900	2.72
U-Section		2.125x1.	875x3/16	2.65
H-Section		1.875x1.	625x.113	2.72
Over 6 ft:				
Tubular (round)		2	2.375	3.65
U-Section		2.5x1.87	5x3/16	4.00
U-Section (modified with flanges)				3.65
H-Section		2.25x1.9	5x.143	4.10

* See table III for additional information on standard pipe.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

TABLE II—*Permissible tolerances in dimensions and weights*

Section	Outside diameter Tolerances	Weight per foot Tolerance
		Percent of pounds plus or minus
Tubular diameter		
To 1½" inclusive	+1/64"-3/32"	5
2" and over	+1%-1%	5
	Dimensional Tolerances	
	Inches	
H-Section		
1.5x1.3125	±.0625	5
1.875x1.625	±.0625	5
2.25x1.95	±.0937	5

Motor:
Fence post fixtures, steel
Motor volume minimum weight 40,000 pounds

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications, Standards, and Handbooks and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U. S. Government Printing Office, Washington 25, D. C.

(Single copies of this specification and other product specifications required by activities outside the Federal Government for bidding purposes are available without charge at the General Services Administration Regional Offices in Boston, New York, Washington, D. C., Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, and Auburn, Wash.

TABLE III—*Standard pipe—Standard weight pipe*

Dimensions and Weights
Plain Ends and Threads and Couplings

Size: Nominal, Inch	Weights per foot: Nom., Thds. & Cplg., lb.	Weights per foot: Calculated Plain Ends, lb.	Wall Thickness, Inch	Diameters: Outside, Inch	Diameters: Inside, Inch	No. of Threads per inch	Couplings: Length, Inch	Couplings: Outside Diameter, Inch	Couplings: Calculated Weight, lb.
1/8	.24	.24	.068	.405	.269	27	5/16	.563	.03
1/4	.42	.42	.088	.540	.364	18	1 3/16	.719	.07
3/8	.57	.57	.091	.675	.493	18	1 3/16	.875	.09
1/2	.85	.85	.109	.840	.622	14	1 3/16	1.063	.17
3/4	1.13	1.13	.113	1.050	.824	14	1 5/8	1.313	.26
1	1.68	1.68	.133	1.315	1.049	11½	2	1.576	.40
1¼	2.28	2.27	.140	1.660	1.380	11½	2 1/16	1.900	.48
1½	2.73	2.72	.145	1.900	1.610	11½	2 1/16	2.200	.67
2	3.68	3.65	.154	2.375	2.067	11½	2 1/8	2.750	1.05
2½	5.82	5.79	.203	2.875	2.469	8	3 1/8	3.250	2.09
3	7.62	7.58	.216	3.500	3.068	8	3¼	4.000	3.35
3½	9.20	9.11	.226	4.000	3.548	8	3 3/8	4.625	4.82
4	10.89	10.79	.237	4.500	4.026	8	3½	5.000	4.61
5	14.81	14.62	.258	5.563	5.047	8	3¾	6.296	8.52
6	19.18	18.97	.280	6.625	6.065	8	4	7.390	11.27

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.

Note—

(a) The customary weight tolerance is 5 per cent above and 5 percent below.

(b) Taper of threads on all sizes of pipe and in couplings in sizes 2 1/2 inch and over is 3/4 inch per foot on diameter.
Couplings 2 inch and smaller are straight tapped.

(c) This table is same as Table 4-2 Standard Pipe, Standard Weight Pipe of AISI Steel Tubular Products, September, 1957, except that Test Pressure Requirements have been eliminated.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications, Standards, and Handbooks from established distribution points in their agencies.)

(Copies of Military Specifications and Standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

Page 8, bottom of page: Delete "For sale" statement and substitute the following:

"Copies of this specification may be purchased for 5 cents each."

MILITARY INTERESTS:
Navy—Y MC W

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:09Z
Check the source to verify that this is the current version before use.