RR-S-30F
April 18, 1975
SUPERSEDING
Fed. Spec. RR-S-30E
November 2, 1971

FEDERAL SPECIFICATION

SAFETY CANS, SPRING CLOSING TYPE

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers safety cans of the spring closing type for temporary storage or handling of flammable liquids (see 6.1).

1.2 Classification. Safety cans shall be of the following styles, capacities, and grades, as specified (see 6.2):

Style I - With short fixed pouring spout

Capacity - 1 pint
Grade B - Galvanized steel
- 1 quart
Grade B - Galvanized steel
- 2 quart
Grade B - Galvanized steel
- 1 gallon
Grade B - Galvanized steel
Grade C - Terne metal
- 2 gallon
Grade B - Galvanized steel
- 5 gallon
Grade B - Galvanized steel
Grade C - Terne metal

Style II - With flexible pouring spout

Capacity - 1 gallon
Grade B - Galvanized steel
- 3 gallon
Grade C - Terne metal
- 5 gallon
Grade B - Galvanized steel
Grade C - Terne metal

FSC 7240

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issues in effect on date of invitation for bids or request for proposal, form a part of this specification to the extent specified herein:

Federal Specifications:

QQ-P-416	-	Plating, Cadmium (Electrodeposited).
QQ-S-775	-	Steel Sheets, Carbon, Zinc-Coated.
QQ-T-191	-	Terns Sheets (Long and Short Terns).
QQ-Z-325	-	Zinc Coating, Electrodeposited, Requirements for.
TT-C-490	-	Cleaning Methods and Pretreatment of Ferrous Surfaces for Organic Coatings.
PPP-P-130	-	Pails and Cans, Packaging and Packing of.

Federal Standards

Fed. Test Method Std. No. 101 - Preservation, Packaging and Packing Materials· Test Procedures.

Fed. Std. No. 595 - Colors.

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information ir tne Index of Federal Specifications and Standards and at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal specifications required by activities outside the Federal Government for bidding purposes are available without charge from Business Service Centers, at the General Services Administration Regional Offices in Boston, New York, Washington, DC, Atlanta, Chicago, Kansas City, MO, Ft. Worth, Denver San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Standard·

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.

(Copies of Military Specifications and Standards required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

LAWS AND REGULATIONS

29 CFR 1910 - Occupational Safety and Health Act (OSHA) Standards.

(The Code of Federal Regulations (CFR) and Federal Register (FR) are for sale on a subscription basis by the Superintendent of Documents, US Government Printing Office, Washington, DC 20402. When indicated, reprints of certain regulations may be obtained from the Federal agency responsible for issuance thereof.)

2.2 Other publications The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply

American Society for Testing and Materials (ASTM) Standard

A 90 - Weight of Coating on Zinc-Coated (Galvanized) Iron or Steel Articles

(Applications for copies should be addressed to American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

Factory Mutual (FM) Engineering Division Standard

Factory Mutual Approval Standards for Safety Containers and Filling and Supply Containers, Class No. 6051 and 6052.

(Application for copies should be addressed to Factory Mutual Engineering Division, 1151 Boston-Providence Turnpike Norwood, MA 02062.)

Underwriters' Laboratories, Inc (UL) Standard

30 - Metal Safety Cans.

(Application for copies should be addressed to the Underwriters' Laboratories Inc., 207 East Ohio Street Chicago, IL 60611 333 Pfingsten Rd Northbrook IL 60062 1285 Walt Whitman Road Melville, Long Island, NY 11746 or 1655 Scott Boulevard Santa Clara, CA 95050.)

3. REQUIREMENTS

3.1 Standard product The safety cans covered by this specification shall be the manufacturer's current standard product except for any changes necessary to comply with specification requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

3.2 Safety standards. Safety cans shall conform to the Underwriters' Laboratories, Inc. Standard 30 for Metal Safety Cans or Factory Mutual Approval Standards for Safety Containers and Filling and Supply Containers. Prior to approval of the first shipment, the supplier shall submit satisfactory evidence to the contracting officer or his authorized representative that the safety cans he proposes to furnish under this specification meet the applicable requirements of FM Approval Standard for Safety Containers, or UL Standard No. 30. Acceptable evidence of meeting the requirements of these standards may be the FM identification mark, the UL label or listing mark, or a certified test report from a recognized independent testing laboratory acceptable to the Government, indicating that the cans have been tested and conform to the UL or FM standards. Compliance with the UL or FM requirements as to fire and casualty hazards does not relieve the supplier from compliance with this specification.

3.3 Materials and components. Materials and components shall be as specified herein. Materials not definitely specified shall be of the quality normally used by the manufacturer in his commercial product, provided that the completed item complies with all provisions of this specification.

3.4 Design and construction. Grade B safety cans shall be fabricated of either type I class d, galvanized sheets conforming to QQ-S-775 or uncoated steel sheets. Grade B cans fabricated from uncoated steel sheets shall be galvanized as specified in 3.6.1. Grade C safety cans shall be fabricated of type I or type II, class 1 grade A terne sheets, having a coating weight of 0.35 ounce per square foot (normal 9 pound per double base box), conforming to QQ-T-191. The safety cans shall have a cylindrically shaped body, dome shape top and recessed bottom. A carrying handle shall be attached to the domed top. Openings into the cans shall be located in the dome above the highest liquid level of the cans and shall be fitted with flame arresters. Openings shall have independent, automatic closing valves designed to remain closed with the filled can in any position until manually opened. The cans shall contain the rated capacity below the lowest opening in the dome. The outage shall be not less than 6 percent of the rated capacity when tested as specified in 4.4.4.

3.4.1 Style I can. The style I can shall have a short, rigid, valved pour spout in the dome for pouring and filling.

3.4.2 Style II can. The style II can shall have a valved pour spout with an attached nozzle of flexible metallic hose, not less than 9-1/4 inches long, a separate valved fill fitting, and an independent air vent valve, to allow air to displace liquids during pouring.

3.4.3 Sheet metal thickness. The thickness of uncoated steel sheets and galvanized steel sheets shall be as specified in table I. Commercial tolerances shall apply.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

TABLE I. Capacities, dimensions, and test loads

Rated capacity	Thickness of sheet steel (inch)		Pour spouts and fill fittings (as applicable) inside diameter (inches) minimum		Test loads (pounds)	
					Pour spout	Top handle
	Uncoated	Galvanized	Style I	Style II		
1 pint	0.0179	0.0187	1/2	-	25	75
1 quart	0.0179	0.0187	1/2	-	25	75
2 quarts	0.0179	0.0187	1/2	-	25	75
1 gallon	0.0179	0.0187	1	3/8	50	125
2 gallons	0.0239	0.0247	1-1/2	-	75	150
3 gallons	0.0239	0.0247	-	3/4	100	175
5 gallons	0.0239	0.0247	1-1/2	3/4	125	250

3.5 Performance requirements

3.5.1 Flame arrester. The flame arrester shall prevent the flame of a hydrocarbon gas - air mixture from reaching the gas source when tested as specified in 4.4.1

3.5.2 Gasket. The gasket shall not deteriorate when tested as specified in 4.4.2

3.5.3 Stability. The safety can shall not tip when one edge is inclined 30° from the horizontal when tested as specified in 4.4.3.

3.5.4 Seam and joint strength. The safety can shall not leak when tested as follows

(a) When dropped (see 4.4.5).
(b) When subjected to hydrostatic pressure (see 4.4.6)
(c) When subjected to pneumatic pressure (see 4.4.10).

3.5.5 Flame test. The safety can shall not leak or show evidence of burning within the can when tested as specified in 4.4.7.

3.5.6 Pour spout and fill fittings. The pour spouts and fill fittings shall not deform (see 4.4.8), nor become displaced from the valve (see 4.4.11) when the test load specified in table I is applied.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

3.5.7 Carrying handle. The carrying handle and fastenings shall not deform (see 4.4.9) nor the valves shall not become dislodged (see 4.4.11).

3.5.8 Valve operation. The valves shall withstand 10,000 opening and closing cycles when tested as specified in 4.4.11).

3.5.9 Internal pressure relief. When the internal pressure exceeds 3 pounds per square inch (psig) and before reaching 5 psig, the internal pressure shall be relieved by overcoming the spring resistance of the pour and filling valves, or pressure release devices, as applicable, when tested as specified in 4.4.12.

3.5.10 Flexible nozzles. The flexible nozzles of the style II can shall not leak when tested as specified in 4.4.13.

3.5.11 Air vent. The air vent valve of the style II cans shall permit an uninterrupted flow of liquid from the can when tested as specified in 4.4.13.

3.6 Finish.

3.6.1 Hot dip galvanizing. Grade B cans fabricated from uncoated steel sheet shall be hot dip zinc coated. Prior to coating, grit loose scale and rust shall be removed from the parts to be coated The weight of zinc coating shall be not less than 1.25 ounces per square foot when tested as specified in 4.2.3.1.

3.6.2 Component plating. Carbon steel carrying handles valve operating linkage, pour spouts, nozzles, springs and fire arresters when not otherwise plated, shall be cadmium or zinc plated in accordance with QQ-P-416 or QQ-Z-325, respectively.

3.6.3 Painting. Exterior surfaces of the safety can shall be prepared for painting in accordance with TT-C-490. The exterior surfaces shall be enameled. The color of the enamel shall be red, approximating color No. 11105 of FED-STD-595 A yellow band approximating color No 13655 of FED-STD-595, shall be applied as specified in OSHA standards

3.7 Marking. Markings shall be applied to the can by a cold application method. The safety can shall be marked with the manufacturer s name or trademark of known character to readily identify the source of manufacture. Grade C cans shall be marked "DO NOT USE FOR UNLEADED GASOLINE".

3.8 Instruction sheet. The supplier shall furnish an instruction sheet with each safety can. The instructions shall contain operating instructions, illustrations, parts list, manufacturer's part numbers, assembly, and disassembly instructions, and safety precautions necessary for operation and maintenance of the safety can.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

3.9 Workmanship. The end item shall be clean and free of any defects such as loose handles, rough edges, burrs, loose, or missing components, areas of no paint, blisters, and sags or runs. Protective metallic coatings damaged or removed from any surface during the manufacturing process shall be repaired. Galvanizing shall be adherent and free from lumps of embedded foreign material, cracks, dross, or flux. Soldering and welding shall be adherent, free from pits, acid, or flux deposits. Spot welds shall be adherent and free from craters.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Certificates of compliance. When certificates of compliance are submitted the Government reserves the right to check test such items to determine the validity of certification (see 3.1).

4.2 Inspection. Sampling for inspection shall be performed in accordance with MIL-STD-105, except where otherwise indicated hereinafter.

4.2.1 Component and material inspection. In accordance with 4.1 components and materials shall be inspected and tested in accordance with all the requirements of referenced specifications, drawings, and standards unless otherwise excluded, amended, modified, or qualified in this specification or applicable purchase document.

4.2.1.1 Component testing. Prior to assembly, the flame arrester shall be tested as specified in 4.4.1 and the gasket shall be tested as specified in 4.4.2. The lot shall be all flame arresters or gaskets offered for inspection at one time. The sample unit shall be one flame arrester or gasket. The inspection level shall be S-1 Any failure shall be cause for rejection of the lot.

4.2.2 In-process inspection.

4.2.2.1 In-process examination Examination shall be made to determine compliance with the soldering or welding requirements specified in 3.9. Whenever a deviation is noted, correction shall be made to affected items and process.

4.2.3 In-process testing.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

4.2.3.1 Testing of plating. The carrying handles, valve operating linkage, pour spout, valve cap, flexible nozzle, springs, and fire arresters, and their retaining components, when cadmium or zinc plating is required, shall be tested as specified in QQ-P-416 or QQ-Z-325, as applicable, for compliance with plating requirements in 3.6.2. The hot dip galvanized coating of grade B cans shall be tested for the coating weight requirement in 3.6.1 in accordance with ASTM A 90. Whenever deviation is noted correction shall be made to the affected items and process.

4.2.4 End item inspection. The lot shall be all cans of one style, capacity, and grade offered for inspection at one time. The sample unit shall be one complete can.

4.2.4.1 Visual examination. The completely assembled and painted can shall be examined for defects listed in table II. The inspection level shall be II and the acceptable quality level (AQL) shall be 2.5 for major defects and 6.5 for total defects, expressed in terms of defects per hundred units.

TABLE II. Classification of defects

Examine	Defect	Classification Major	Minor
Finish			
Exterior surfaces	Not painted	X	
	Area of no paint		X
	Wrong color		X
	Blisters, teardrops, sags foreign inclusions, or uncoated areas		X
	Tacky (not dry to touch)		X
	Any edge not rounded or beveled		X
	Any burrs or sharp edges	X	
Interior surfaces 1/	Any discontinuity of coating, exposing base metal	X	
	Any rivet head not soldered	X	
Design, construction and workmanship	Not specified style	X	
	Can not clean		X
	Handles loose	X	
	Plating nonadherent	X	
	Components loose		X
	Components missing	X	
	Body not cylindrical, top not dome shaped or bottom not recessed	X	

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

TABLE II. Classification of defects (cont'd)

Examine	Defect	Classification Major	Minor
Design, construction and workmanship (cont'd)	Any opening below normal fill level	X	
	Valves not automatic closing, manual opening type	X	
	Pour valve operating lever not as specified	X	
	Functioning component does not operate as intended	X	
Pour spout and fill fitting (when applicable)			
Interior surfaces 1/	Any damage to metallic coatings exposing metal when flame arresters are not removed from can	X	
Exterior surfaces	Not joined to body of can as specified	X	
Type I cans	Not seamless		X
Valve cap	Not recessed for gasket	X	
	Main bearing pin not permanently secured in frame	X	
	Gasket not mechanically secured or not removable		X
	Valve closure not effected at specified location		X
Flexible nozzle, style II cans	Not attached to pour nozzle by collar and machine screws or machine cut threads		X
	Ferrule not secured at open end	X	
	Pour spout end not provided with reinforcing spring (when applicable)		X
	Removable screen not provided (when applicable)	X	
Flame arresters and their retaining components	Arrester or components missing	X	
	Not in position as specified		X
	Not removable from can	X	
	Any damage to metallic coatings exposing base metal when removed from can	X	

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

TABLE II. Classification of defects (cont'd)

Examine	Defect	Classification Major	Minor
Joints and seams	Seams not double folded and soldered or not fusion welded (as applicable)	X	
	Component not attached mechanically or not fusion welded	X	
Rivets	Not headed over on outside surface of can		X
Fastening devices	Not secured to prevent loss of tightness or adjustment	X	
Marking	Marking made by a hot application method	X	
	Manufacturer's identification marking, missing, or illegible		X
	Warning missing from grade C cans		X
Instruction sheet	Missing, illegible, or not as specified		X

1/ Illuminate can interior, pour spout, or fill fitting as applicable, and use inspection mirror.

4.2.4.2 Dimensional examination. Examination shall be made of the end item for defects in dimensions. Any dimension not within tolerances specified shall be classified as a defect. The inspection level shall be S-2 and the AQL 4.0, expressed in terms of defects per hundred units.

4.2.4.3 Testing of the end item. The assembled cans shall be tested for characteristics indicated in table III to determine compliance with specified requirements. The lot shall be all cans of the same style, capacity, and grade offered for inspection at one time. Two safety cans, selected from the first shipment, shall be tested as specified in 4.4.3, 4.4.4, 4.4.5, 4.4.6, and 4.4.7. When noncompliance is noted correction shall be made prior to further testing. The tests shall be repeated upon termination of UL or FM approval, or change in design, materials or manufacturing process. Each lot shall be tested as specified in table III. The sample unit shall be one safety can. Unless otherwise specified in table III, the inspection level shall be S-3 and the AQL shall be 1.5, expressed in terms of defects per hundred units. The contracting officer may accept the UL or FM label as evidence of compliance with these requirements (see 4.4.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

TABLE III. End item testing

Characteristic	Requirement paragraph	Test method paragraph	Testing frequency and sequence
Pour spout	3.5.6	4.4.8	-
Carrying handle	3.5.7	4.4.9	-
Leakage	3.5.4(c)	4.4.10	100%
Valve	3.5.8	4.4.11	Cans tested in 4.4.8 and 4.4.9 after passing the test in 4.4.10
Internal pressure relief	3.5.9	4.4.12	-
Flexible nozzle	3.5.10	4.4.13	-
Air vents	3.5.11	4.4.13	-

4.3 Examination of preparation for delivery. Examination shall be made to determine that packing and marking comply with PPP-P-130.

4.4 Tests.

4.4.1 Flame arresters. A combustible hydrocarbon gas-air mixture shall be passed through the arrester, ignited, and allowed to burn. After 1 minute, the flow will be cut off. Evidence of flame passing through the flame arrester shall constitute failure of this test.

4.4.2 Gasket treatment. The gasket shall be submerged in gasoline for 24 hours, withdrawn, dried, and placed in a humidity chamber at a relative humidity of 90 percent and temperature of 100 degrees for 48 hours. Deterioration of gasket shall constitute failure of this test.

4.4.3 Stability. The can shall be filled to its rated capacity. The can shall be tipped to an angle of 30° from the horizontal and released. Failure of the can to return to the upright position shall constitute failure of this test.

4.4.4 Capacity. Capacity and outage shall be determined in accordance with Method 5010 of FED-STD-101. Noncompliance with requirements of 3.4 shall constitute failure of this test.

4.4.5 Drop test. Cans shall be filled with water and shall withstand a drop to a concrete floor, landing on any part of the container except the spout or spout mechanism, from a height of 3 feet. Loosening of components or leakage from the can shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

4.4.6 Hydrostatic test. Cans, not including the valve seats, shall be capable of withstanding a pressure test of not less than 25 psig. Rupture or opening of any joint or seam shall constitute failure of this test.

4.4.7 Fire exposure. The can filled to rated capacity with gasoline, shall be placed upright in a level pan containing 1 inch of gasoline. The minimum dimensions of the pan shall be 8 inches in height and 6 inches in every direction from the can, or approximately 2-1/2 to 4-1/2 square feet. The gasoline in the pan shall be ignited and permitted to burn until consumed. The flame from escaping vapors shall be extinguished and the can with the remaining liquid contents shall be allowed to rest for 30 minutes. Leakage of the contents or evidence of burning within the can shall constitute failure of this test.

4.4.8 Pour spout loading. The can shall be secured in a testing machine or jig. The applicable test load specified in table I shall be applied externally as a concentrated load against the nozzle for not less than 15 seconds. The load shall be applied on the side opposite the valve opening linkage, or either side of a spout or fill fitting which has no valve opening linkage, 1/4 inch below the top of the pour opening and perpendicular to the center axis of the can. Deformation of pour spout or displacement shall constitute failure of this test.

4.4.9 Carrying handle loading. The can shall be secured in a testing machine or jig. A pull load, equal to the applicable test load specified in table I, shall be applied at the center of the normal grip position on the handle, for not less than 30 seconds. The direction of the applied load shall be parallel to the center axis of the can. Failure of handle, fastenings, loss of value tightness or leakage shall constitute failure of this test.

4.4.10 Leakage test. The cans shall be tested for leakage in accordance with Method 5009 of FED-STD-101 for pneumatic pressures of not less than 5 psig.

4.4.11 Valve tests. The pour valve and vent and fill valves, when applicable, shall be opened and closed at least 10,000 times, using the regular valve operating means provided on the can. After completing the opening and closing cycles, the can shall be filled with water at room temperature, and held in the inverted position for at least 10 minutes and observed for leaks. Leakage in excess of 4 drops (0.003 ml) per minute shall constitute failure of this test.

4.4.12 Internal pressure relief. The can shall have the pour spout and fill fitting submerged in water to a minimum depth of 2 inches and subjected to a gradually increasing internal air pressure. The air pressure gage shall be observed to determine the start of the discharge pressure point. Failure of valves or release devices shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

4.4.13 Flexible nozzle and air venting style II cans. The nozzle of the style II cans shall be rapidly flexed to the smallest arc possible, without forcing, and straightened at least 100 times. The can shall then be filled with water and the contents discharged through the nozzle. Leakage through the nozzle sidewall or base or an interrupted stream of water shall constitute failure of this test.

5. PREPARATION FOR DELIVERY

5.1 Packing. Cans shall be packed and marked for level A, B, or C, as specified, in accordance with PPP-P-130 (see 6.2).

6. NOTES

6.1 Intended use. The safety cans covered by this specification are intended for temporary storage or handling of flammable liquids such as gasoline, naptha, or benzine inside buildings that are not provided with special storage rooms and for transport of such liquids for filling and supply purposes within local outside areas.

6.2 Ordering data Purchasers should select the preferred options permitted herein and include the following information in procurement documents

(a) Title, number, and date of this specification.
(b) Style, capacity, and grade required (see 1.2).
(c) Selection of applicable levels of packing (see 5.1).

6.3 The degree of corrosion protection afforded by grades B and C cans is tabulated in descending order. The grades refer to the materials for fabrication of the dome body, and bottom of the can The grade C can is not recommended for marine application, use or unleaded gasoline, or where exposure to salt atmosphere is anticipated.

6.4 Classification comparison Grade A cans were deleted since there are no items of supply fabricated of corrision-resisting steel.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

MILITARY CUSTODIANS:

Army - GL
Navy - YD
Air Force - 84

Review activity:

Army - MI

User activities:

Navy - OS, MC

Civil Agency Coordinating Activities:

AGR-AFS
GSA-FSS
HEW-FDA
NASA-JFK

Preparing activity:

Army - GL

Project No. 7240-0196

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain extra copies or other documents referenced herein. Price 40 cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No 22-R255

INSTRUCTIONS The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document DoD contractors, government activities, or manufacturers/vendors who are prospective suppliers of the product are invited to submit comments to the government Fold on lines on reverse side, staple in corner, and send to preparing activity Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements Attach any pertinent data which may be of use in improving this document If there are additional papers, attach to form and place both in an envelope addressed to preparing activity

DOCUMENT IDENTIFIER AND TITLE

Safety Cans, Spring Closing Type RR-S-30F

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1 HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A GIVE PARAGRAPH NUMBER AND WORDING

B RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2 COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3 IS THE DOCUMENT RESTRICTIVE?

☐ YES ☐ NO (If "Yes" in what way?)

4 REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO

DATE

DD FORM 1 JAN 72 1426

REPLACES EDITION OF 1 JAN 66 WHICH MAY BE USED

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE ARMY
US ARMY NATICK Development Center
NATICK, MA 01760

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300
STSNL-TDT

POSTAGE AND FEES PAID
DEPARTMENT OF THE ARMY
DOD – 314

Commander
US Army Natick Development Center
ATTN STSNL-TDT
Natick, MA 01760

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:08Z
Check the source to verify that this is the current version before use.