MILITARY SPECIFICATION

CONNECTORS, ELECTRICAL AND FIBER OPTIC,
PACKAGING OF

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers the requirements for the preservation, packing, and container marking of all types of electrical and fiber optic connectors (including interconnectors, splices, couplers, splitters, mixers, and associated accessories) which are primarily in FSC's 5935, 6005, and 6060 (see 6.1).

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

FEDERAL

QQ-S-781	-	Strapping, Steel, and Seals.
PPP-B-566	-	Boxes, Folding, Paperboard.
PPP-B-601	-	Boxes, Wood, Cleated-Plywood.
PPP-B-621	-	Boxes, Wood, Nailed and Lock-Corner.
PPP-B-636	-	Boxes, Shipping, Fiberboard.
PPP-B-676	-	Boxes, Setup.

MILITARY

MIL-P-116	-	Preservation, Methods of.

STANDARDS

FEDERAL

FED-STD-123	-	Marking for Shipment (Civil Agencies).

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	-	Marking for Shipment and Storage.
MIL-STD-147	-	Palletized Unit Loads.
MIL-STD-202	-	Test Methods for Electronic and Electrical Component Parts.
MIL-STD-794	-	Parts and Equipment, Procedures for Packaging and Packing of.
MIL-STD-2073-1	-	DoD materiel, Procedures for Development and Application of Packaging Requirements.
MIL-STD-45662	-	Calibration Systems Requirements.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, US Army Communications - Electronics Command, ATTN: AMSEL-ED-TD, Fort Monmouth, NJ 07703-5000 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

(Copies of specifications and standards, required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, (except for associated detail specifications, specification sheets or MS standard), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 General. The packaging terms used herein shall be in accordance with the definitions listed in MIL-STD-129, MIL-STD-794, and MIL-STD-2073-1. The following general requirements apply, as applicable, to levels A, B, and C as well as to shipments to non-Government activities.

3.1.1 Hardware. Mounting brackets, screws, and other hardware accompanying or furnished with the connectors shall be protected and enclosed within the unit packs in a manner that will not damage the connectors or the packaging materials. When practical, the hardware should be mounted on each connector.

3.1.2 Physical protection. Connectors and accessories shall be packaged in a manner that will ensure compliance with the applicable requirements of MIL-P-116 as well as those specified herein. For shipments to non-Government activities, large quantity unit packs may be used.

3.1.2.1 Contacts, leads, and terminals. Contacts, leads, terminals, and other outward projections shall be protected by means of container design, noncorrosive die-cut inserts, or other suitable supporting materials or devices. If not otherwise protected, protective caps shall be used to prevent damage to the coupling or accessory connector threads.

3.1.2.2 Wrapping and cushioning. Wrapping and cushioning materials shall be noncorrosive and dry. In addition, materials used for fiber optic connectors shall be nonstatic generating and shall not crumble, flake, powder or shed. Cushioning is not required for accessories.

3.1.3 Exterior containers. Exterior containers shall be of minimum tare and cube consistent with the protection required and shall contain equal quantities of identical stock numbered or otherwise designated items to the greatest extent practicable (see 3.3).

3.2 Preservation. Preservation shall be in accordance with level A, B, or C, as specified (see 6.2).

3.2.1 Level A.

3.2.1.1 Cleaning. Connectors and accessories shall be cleaned in accordance with MIL-P-116, process C-1.

3.2.1.2 Drying. Connectors and accessories shall be dried in accordance with MIL-P-116.

3.2.1.3 Preservatives. Contact preservatives shall not be used.

3.2.1.4 Unit packs.

3.2.1.4.1 Connectors. Unless otherwise specified (see 6.2), and except as specified herein, connectors (both electrical and fiber optic) shall be individually unit packed in accordance with MIL-P-116, submethod IA-8. Electrical connectors with only gold plated contacts shall be preserved in accordance with submethod IC-1 or IC-3 of MIL-P-116.

3.2.1.4.1.1 Connectors with removable contacts. Removable crimp type contacts shall not be installed in the connector insert but shall be placed in a close fitting noncorrosive rigid container such as a vial or box and enclosed within the unit pack. Any spare contacts furnished shall also be within this container.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

3.2.1.4.1.2 Connectors with grommet sealing plugs. Grommet sealing plugs supplied with various connectors shall be placed in an envelope or rigid container and enclosed within the unit pack.

3.2.1.4.2 Accessories (when separately acquired).

3.2.1.4.2.1 Contacts. Unless otherwise specified (see 6.2), contacts shall be unit packed five each in accordance with MIL-P-116, submethod 1A-8.

3.2.1.4.2.2 Other accessories. Other accessories such as adaptors (mechanical), boots, caps, clamps, covers, elbows, grommet sealing plugs, nuts, rings, and tools shall be unit packed in accordance with MIL-P-116, method III. Unit pack quantities for other than one each shall be as specified (see 6.2).

3.2.1.4.3 Supplementary containers. Connectors and accessories, unit packed as specified in 3.2.1.4.1 and 3.2.1.4.2, with a unit pack volume of 30 cubic inches (491.7 cubic centimeters) or more, or an item dimension 4 inches (10.16 centimeters) or longer shall be placed in a supplementary container conforming to variety 2 of PPP-B-566 or PPP-B-676.

3.2.1.5 Intermediate packs. When the unit pack is a bag of any type or the unit pack is less than 64 cubic inches (1,049 cubic centimeters), uniform quantities of connectors or accessories of the same NSN shall be placed in intermediate containers conforming to variety 2 of PPP-B-566, or variety 2 of PPP-B-676; or PPP-B-636, class weather resistant. Alternatively, nonweather or nonwater resistant versions of these containers may be used provided they are overwrapped with waterproof barrier materials. Intermediate containers shall contain multiples of five unit packs not to exceed 100 unit packs. No intermediate packs are required when the total quantity shipped to a single destination will result in only one intermediate pack per shipping container.

3.2.2 Level B. The level B preservation for connectors and accessories shall be identical to that specified for level A except that submethods 1C-1 or 1C-3 shall be used in lieu of submethod 1A-8.

3.2.3 Level C. In addition to the applicable provisions of 3.1, the level C preservation for connectors and accessories shall conform to the MIL-STD-794 requirements for this level.

3.3 Packing. Packing shall be level A, B, or C, as specified (see 3.1 and 6.2).

3.3.1 Level A. Connectors and accessories, preserved as specified in 3.2, shall be packed in wood containers conforming to PPP-B-601, overseas type or PPP-B-621, class 2. Closure and strapping shall be in accordance with the applicable container specification except that metal strapping shall conform to QQ-S-781, type I, finish A. The requirements for level B packing shall be used when the total quantity of a stock numbered connector or accessory for a single destination does not exceed a packed volume of 1 cubic foot (0.02832 cubic meter).

3.3.2 Level B. Connectors and accessories, preserved as specified in 3.2, shall be packed in fiberboard containers conforming to PPP-B-636, class weather resistant, style optional, special requirements. The requirements for box closure, waterproofing and reinforcing shall be in accordance with method V of the PPP-B-636 appendix.

3.3.3 Level C. Connectors and accessories, preserved as specified in 3.2, shall be packed in fiberboard containers conforming to PPP-B-636, class domestic, style optional, special requirements. Closures shall be in accordance with the PPP-B-636 appendix.

3.3.4 Unitized loads. Unless otherwise specified (see 6.2), unitized loads, commensurate with the level of packing specified in the contract or purchase order, shall be used whenever total quantities for shipment to one destination equal 40 cubic feet (1.1328 cubic meters) or more. Quantities less than 40 cubic feet need not be unitized. Unitized loads shall be uniform in size and quantities to the greatest extent practicable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

3.3.4.1 Level A. Connectors, packed as specified in 3.3.1, shall be unitized on pallets in conformance with MIL-STD-147, load type I, with a wood cap (storage aid 5) positioned over each load.

3.3.4.2 Level B. Connectors, packed as specified in 3.3.2, shall be unitized as specified in 3.3.4.1, except that weather resistant fiberboard caps (storage aid 4) shall be used in lieu of wood caps.

3.3.4.3 Level C. Connectors, packed as specified in 3.3.3, shall be unitized as specified in 3.3.4.2 except that the fiberboard caps shall be class domestic.

3.4 Marking. The following marking is mandatory for shipments both to U.S. Government and non-Government activities.

3.4.1 Standard marking. In addition to any special or other identification marking required by the contract (see 6.2), each unit, supplementary, intermediate, and exterior container and unitized load shall be marked in accordance with MIL-STD-129. The complete military or contractor's type or part number, as applicable, including the Commercial and Government Entity (CAGE) code, shall be marked on all unit and intermediate packs in accordance with the indentification marking provisions of MIL-STD-129. When specified in the contract (see 6.2), the marking of domestic shipments for civil agencies shall be in accordance with FED-STD-123.

3.5 First article and quality conformance inspections. First article and quality conformance inspections and tests shall be required as specified in 4.4 and 4.5, respectively. Samples for these tests shall be furnished in accordance with the procedures outlined in 4.4 and 4.5. The performance of the visual and dimensional inspections, rough handling tests, and leakage tests shall conform to the inspections and tests outlined in 4.6.1, 4.6.2.1, and 4.6.2.2, respectively.

3.5.1 Functional requirements.

3.5.1.1 Rough handling test (when specified, see 6.2). When packs have been tested in accordance with 4.6.2.1, all materials and components comprising each pack shall be free from damage or evidence of misplacement which might affect the utility of the preservation method or pack. The connectors and associated accessories within the tested packs shall show no visible signs of damage. When specified in the contract (see 6.2), functional tests in accordance with the group A inspection requirements of the applicable commodity specification shall be conducted on those connectors subjected to the rough handling test to determine freedom from operational malfunction. The examination of the connectors tested under this group A inspection shall be in accordance with the visual and mechanical inspection requirements specified in the applicable connector commodity specification.

3.5.1.2 Leakage test (when applicable). When a barrier enclosed unit pack has been tested in accordance with 4.6.2.2, there shall be no evidence of moisture within the unit pack.

3.6 Workmanship. The quality of workmanship shall assure acceptance of the completed preservation, packing, and marking requirements in accordance with the inspections specified in section 4.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order (see 6.2), the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

4.1.1 Responsibility for compliance. All items must meet all requirements of section 3. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Test equipment and inspection facilities. Test and measuring equipment and inspection facilities of sufficient accuracy, quality, and quantity to permit performance of the required inspection shall be established and maintained by the contractor. The establishment and maintenance of a calibration system to control the accuracy of the measuring and test equipment shall be in accordance with MIL-STD-45662.

4.1.3 Inspection conditions. All inspections shall be performed in accordance with the test conditions specified in the general requirements of MIL-STD-202.

4.2 Classification of inspections. The inspections specified herein are classified as follows:

a. Materials inspection (see 4.3).

b. First article inspection (see 4.4).

c. Quality conformance inspection (see 4.5).

4.3 Materials inspection. Materials inspection shall consist of certification supported by verifying data that the materials used are in accordance with the applicable requirements specified herein.

4.4 First article inspection. When specified (see 6.2), first article inspection shall be performed by the contractor, after award of contract and prior to production at a time and location acceptable to the Government. First article inspection shall not be required:

a. When there have been no changes in materials, processes, or packaging design that will not adversely affect item protection since the last recorded inspection.

b. When the detailed packaging instructions are furnished by the acquisition activity.

c. When level C protection is specified.

d. When a prior successful inspection was conducted on a like item and pack (subject to the approval of the administrative contracting officer).

4.4.1 Sample size. One sample unit consisting of a level A or level B, as applicable, fully packed shipping container shall be submitted for first article inspection. The sample for the rough handling test shall consist of the pack selected for first article inspection. The sample for the leakage test shall be five unit packs selected at random from the first article exterior pack (shipping container).

4.4.2 Inspection routine. The sample shall be subjected to the inspections specified in tables I and II. The leakage test, when applicable, shall follow the rough handling test.

4.4.3 Failures. One or more failures shall be cause for refusal to grant first article approval.

4.4.4 Resubmission of first article sample. If the sample fails to pass first article inspection, the contractor shall change the preservation and packing processes to correct the cause of the deficiency. First article inspection shall be performed on a corrected sample to prove that the corrective action is acceptable.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

TABLE I. Visual and dimensional inspections.

Major defects	Requirement paragraph	Method paragraph
Packaging materials not conforming to referenced specification requirements	Section 3	4.6.1
Uncleaned or improperly cleaned items	3.2.1.1 and 3.2.1.2	
Punctured or improperly fabricated barrier bag	3.2.1.4.1 and 3.2.1.4.2	
Incorrect preservation method	3.2.1.4.1 and 3.2.1.4.2	
Wrong quantity per unit pack	3.2.1.4.1 and 3.2.1.4.2	
Nonuse or incorrect application of intermediate containers	3.2.1.5	
Improper box closures	3.3.1 and 3.3.2	
Omitted, incorrect, or illegible marking	3.4	

TABLE II. Functional inspections.

Test	Requirement paragraph	Method paragraph
Rough handling (when specified)	3.5.1.1	4.6.2.1
Leakage (when applicable)	3.5.1.2	4.6.2.2

4.5 Quality conformance inspection. This inspection shall consist of the inspections and tests specified in tables I and II, respectively.

4.5.1 Inspection lot. An inspection lot, as far as practicable, shall consist of unit or exterior (shipping) packs produced under essentially the same conditions and offered for inspection at one time. For the purpose of selecting samples to be inspected and tested for compliance with the requirements of this specification, either items in process or completed packs except as stated herein, may be combined into lots without regard to individual items, contracts, or the quantities therein. Unit packs of the same size and made from the same packaging materials may be grouped together except when item complexity, item value, or the complexity of the preservation method warrants that the inspection of such items be performed on a separate basis. A separate application of the sampling or inspection procedure shall be made on these items. The combination of items to be subjected to inspection shall be determined by either the Government or the contractor, subject to the approval of the Government.

4.5.2 Visual and dimensional inspection. Visual and dimensional inspection shall consist of those inspections specified in table I.

4.5.2.1 Sampling plan. Statistical sampling and inspection shall be in accordance with MIL-STD-105 for special inspection level S-4. The acceptable quality level (AQL) shall be 4.0 percent defective for all inspections of table I combined.

4.5.2.2 Rejected lots. If an inspection lot is rejected, the contractor may rework it to correct the defects, or screen out the defective units, and resubmit for reinspection. Resubmitted lots shall be inspected using tightened inspection. Such lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

4.5.2.3 Disposition of sample units. Sample units which have passed all the inspections specified in table I may be delivered on the contract, provided the lot is accepted.

4.5.3 Functional inspection. Functional inspection shall consist of the tests specified in table II.

4.5.3.1 Sampling plan. Sampling plans shall be as follows:

a. One sample unit for the rough handling test shall be selected whenever the design of the item or packaging is changed.

b. For unit packs requiring waterproof or water-vaporproof barriers, five sample units for the leakage test shall be selected daily at random from the first lot processed each day. Five additional samples shall be selected at random from the day's total production.

c. The leakage test shall also be performed following the rough handling test on unit packs requiring waterproof or water-vaporproof barriers. Five sample units or the number of units contained within the shipping container (if less than five) shall be selected.

4.5.3.2 Failures. One or more failures shall be cause for rejection of the lot.

4.5.3.3 Disposition of sample units. Sample units which have passed the inspections specified in table II may be delivered on the contract if the lot is accepted and opened packs have been reprocessed.

4.5.3.4 Noncompliance. If a sample fails to pass the inspections specified in table II, the contractor shall take corrective action on the materials or processes or both, as warranted, on all unit, intermediate, and exterior (shipping) packs which can be corrected and which were processed under essentially the same conditions, with essentially the same materials, and which are considered subject to the same failure. Acceptance of the unit, intermediate, and exterior packs shall be discontinued until corrective action has been taken and the applicable inspections specified in table II have been repeated on additional sample units. (All inspections or the inspection which the original sample failed shall be at the option of the Government.) Inspections specified in table II may be reinstituted; however, final acceptance shall be withheld until the reinspection in accordance with table II has shown that the corrective action was successful. In the event of failure after reinspection, information concerning the failure and corrective action taken shall be furnished to the administrative contracting officer.

4.6 Methods of inspections and tests.

4.6.1 Visual and dimensional inspections. Unit, intermediate, and exterior packs shall be examined to verify that the materials, designs, methods, physical limitations, marking, and workmanship are in accordance with the applicable requirements (see 3.1 through 3.6).

4.6.2 Functional tests.

4.6.2.1 Rough handling. Packs shall be subjected to the applicable rough handling tests and the interpretation of results or cause for rejection as specified in 3.5.1.1 and MIL-P-116.

4.6.2.2 Leakage. When a waterproof or water-vaporpruof barrier is required, the unit pack shall be subjected to the applicable leakage test and interpretation of results specified in 3.5.1.2 and MIL-P-116.

5. PACKAGING

5.1 Packaging requirements. This section is not applicable to this specification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

6. NOTES

6.1 Intended use. The preservation, packing, and marking specified herein are intended for direct shipments to the Government. Unless otherwise designated, the general requirements (3.1) and marking requirements (3.4) are applicable for the preparation of military specification connectors and accessories for shipment from the parts manufacturer to non-Government activities.

6.2 Ordering data. Acquisition documents should specify the following:

a. Title, number, and date of this specification.

b. Levels of preservation and packing (see 3.2 and 3.3).

c. Quantity per unit pack, if other than specified (see 3.2.1.4.1, 3.2.1.4.2.1, and 3.2.1.4.2.2).

d. Method of preservation, if other than that specified (see 3.2.1.4.1 and 3.2.1.4.2.1).

e. If a unitized load is not required for shipment to one destination when total quantities are equal to 40 cubic feet or more (see 3.3.4).

f. Whether any special marking or additional identification marking is required (see 3.4.1).

g. If FED-STD-123 is required for civil agency marking (see 3.4.1).

h. If a rough handling test is required (see 3.5.1.1).

i. If connector functional tests are required (see 3.5.1.1).

j. If the contractor is not responsible for the performance of all inspection requirements (see 4.1).

k. If first article inspection is not required (see 4.4).

6.3 Inspection for first article. The sample pack submitted for first article inspection (when satisfactorily performed as specified in 4.4) will serve as the production standard for subsequent packaging operations. The contractor should inform the acquisition activity or the activity administering the contract of the time and location of this specification so that the Government representative will have an opportunity to witness the tests.

6.4 Conditions for use of level B preservation. When level B preservation is specified (see 3.2), this level of protection should be reserved for the acquisition of connectors and accessories for resupply worldwide under known favorable handling, transportation and storage conditions (see 3.2.2).

6.5 Subject term (key word) listing.

Connectors
Connector accessories
Electrical connectors
Fiber optic connectors
Marking
Packaging
Packing
Physical protection
Preservation
Unitized loads

Source: https://assist.dla.mil - Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

6.6 International standardization agreement. Certain provisions of this specification are the subject of an international standardization agreement (a NATO specification covering fiber optic connectors). When amendment, revision or cancellation of this specification is proposed which will affect or violate the international agreement cited herein, the preparing activity will take appropriate reconciliation action through international standardization channels (including departmental standardization offices to change the agreement or make other appropriate accommodations.

6.7 Identification of changes. Asterisks are not used in this revision to identify changes with respect to the previous issue, due to the extensiveness of the changes.

Custodians:
Army - CR
Navy - EC
Air Force - 99
DLA - ES

Review activities:
Army - SM
Air Force - 80, 85

Preparing activity:
Army - CR

Agent:
DLA - ES

(Project PACK-0867)

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

Cdr, CECOM
ATTN: AMSEL-ED-TO
Fort Monmouth, NJ 07703-9990

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
U.S. Army Communications-Electronics Command
and Fort Monmouth
ATTN: AMSEL-ED-TO
Fort Monmouth, NJ 07703-9990

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-C-55330B	Connectors, Electrical and Fiber Optic, Packaging of

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T23:02Z
Check the source to verify that this is the current version before use.

DD FORM 1426