MIL-P-52632D(ME)
AMENDMENT 3
8 June 1981
SUPERSEDING
AMENDMENT 2
31 January 1977

MILITARY SPECIFICATION

POWER PLANT, UTILITY, MUST HOSPITAL SYSTEM

This amendment forms a part of military specification MIL-P-52632D(ME), dated 22 July 1976.

PAGE 2

* 2.1 under SPECIFICATIONS, FEDERAL delete:

"PPP-T-75 - Tape, Preservation and Sealing."

Under SPECIFICATIONS, MILITARY delete:

"MIL-C-45662 - Calibration System Requirements."

Add:

"MIL-G-5572 - Gasoline, Aviation, Grader, 80/100/115.
MIL-E-52798 - Enamel, Alkyd, Camouflage.
MIL-T-22085 - Tape, Pressure-Sensitive Adhesive, Preservation and Sealing."

Under STANDARDS, MILITARY add:

"MIL-STD-45662 - Calibration System Requirements."

PAGE 3

* 2.2, Air Moving and Conditioning Association

Delete: "205 West Touhy Avenue, Park Ridge, IL 60068"

Substitute: "30 West University Drive, Arlington Heights, IL 60004."

PAGE 7

* 3.6.1.3, Line 1, Change from "3500,000" to "350,000."

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:27Z
Check the source to verify that this is the current version before use.

PAGE 12

* 3.10.5 delete: lines 1, 2, and 3 in their entirety and substitute: "the following forces".

Direction of pull	Towing Attachment	Lifting attachment
Forward and rearward	11,000 lb	5,000 lb.
Sideways	2,000 lb	1,400 lb.
Upward	3,000 lb	--
Downward	--	2,100 lb."

PAGES 16 and 17

* 3.12.2.3, line 11, delete "The entire refrigerant system shall be . . . . . to 150 percent of refrigerant saturation pressure at 150° F." Substitute "The refrigerant system high pressure side shall be capable of withstanding a pressure of 150 psig and the low side pressure a pressure of 120 psig."

PAGE 17

3.12.3.1.1, delete and substitute:

"3.12.3.1.1 Condenser air door interlock. If the condenser air intake door is closed prior to starting the air conditioning system, the compressor shall not operate. If the condenser air discharge door is closed, the condenser fans and compressor shall not operate."

PAGE 18

* 3.14.1, line 1, delete "specified" and substitute "upper test".

PAGE 19

3.19, delete in its entirety.

PAGE 19 and 20

* 3.21, add to end of paragraph "Color shall be lusterless forest green conforming to MIL-E-52798 unless otherwise specified (see 6.2)."

PAGE 25

4.6.1, Table II, add in proper sequence:

	1	2	3	4	5	6	7	8
*	22a	X	X	X	X	Water compartment Heating	3.1, 3.6.3	4.6.3.13.4

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:27Z
Check the source to verify that this is the current version before use.

PAGE 26

4.6.1, Table II

a. Delete inspection sequence 33 and substitute:

1	2	3	4	5	6	7	8
	3/	3/		3/	Reliability	3.14.1	4.6.3.24
33	X	X		X			

b. Add to notes below table II:

3/ when specified, see 6.2

PAGE 29

* 4.6.3.1.1, line 4, delete: "MIL-C-45662" and substitute: "MIL-STD-45662."

PAGE 32

Add:

"4.6.3.3.7 Deicer manifold. With the utility element operating, connect the deicer manifold to the compressed air outlet with the 12 foot bleed air hose. Open the compressed air valve. Determine if air is issuing from each manifold hole. Failure of air to issue from one or more holes shall constitute failure of this test."

* 4.6.3.4.1, line 2, after ".....accordance with MIL-STD-705, method 512.2", add "except the generator shall be operated at 110% of rated load for 5 minutes in lieu of 2 hours."

PAGE 34

* 4.6.3.9.1, line 4, delete "type H-2" and substitute "type H-25"; line 5 and 6, delete "0.05 ounce per year" and substitute "6.0 X 10^{-6} cc/sec".

PAGE 35

* 4.6.3.10.3, line 6, delete "(cool air indicating light not glowing)".

PAGE 45

* 4.6.3.18.2, lines 9 and 10, delete "perform the water system operation test (see 4.6.3.13)" and substitute "measure the cold water and hot water flow rates at the outlet of the dual water hose".

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:27Z
Check the source to verify that this is the current version before use.

* 4.6.3.18.2, line 13, after "during the test" add:

"Circulating cold water through the cold water system, dual water hose and recirculating hose back to the water tank; and circulating hot water through the hot water system, dual water hose, recirculating hose to the hot water return."

Delete ", but the" and substitute ". The".

* 4.6.3.18.2, add "(f) Water flow rates less than required by 3.6.3."

PAGE 46

* 4.6.18.4, delete the first sentence and substitute "Conduct the humidity test in accordance with MIL-STD-810, method 507, procedure I, except the following procedure shall be substituted for step 6:

Step 6 - At the end of the tenth cycle remove the test item from the chamber, allow the temperature to return to ambient and conduct the Environmental Performance test, 4.6.3.18."

PAGE 48

* 4.6.3.2.1, lines 3 and 4, delete "Tactical Support (NON CE)" and substitute "Tactical NON-CE".

* 4.6.3.22, line 2, delete "Grade JP4" and substitute "MIL-T-5624".

PAGE 50

4.6.3.24, add:

"(d) Not withstanding the 60 minute repair criteria above, pattern failures as defined in MIL-STD-781 shall be corrected on the effected part or assembly."

PAGE 51

4.6.3.24.2, line 1, after "failure" add "whether or not the failure is relevant".

PAGE 53

* 4.6.3.3.24

TABLE IV
Note 8

a. line 1, delete "(Grade JP-4)".
b. line 2, after (Type FF-2) add "MIL-G-5572".
c. line 4, delete "JP-4".

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:27Z
Check the source to verify that this is the current version before use.

PAGE 55

4.8.2.3, defect 152, delete "packaged" and substitute "preserved"; defect 153, delete "and packaged"; defect 154, delete "packaged" and substitute "preserved".

5.1, lines 4 and 5, delete and substitute "applied preservation and marking comply with the packaging requirements of this specification. Examination shall be"; line 10, delete "and packaging".

5.2, delete in its entirety and substitute:

"5.2 Preservation. Preservation shall be level A or commercial as specified (see 6.2)."

PAGE 56

5.2.1.1, line 9, after "Type IV" add "or"; line 10, delete: "PPP-T-75, Type I" and substitute "MIL-STD-22085, Type II."

PAGE 58

5.2.1.5, line 1, delete "packaged" and substitute "placed"; line 2, after "and" add "the box".

PAGE 59

* 5.2.1.9, line 1, delete "packaged" and substitute "placed".

* 5.2.1.11, delete in its entirety and substitute:

"5.2.1.11 Access panels and doors. The access panels and doors shall be secured to prevent pilferage by the use of strapping conforming to QQ-S-781, class 1, type I or IV, size 3/4 by 0.015 inch. Unless otherwise specified (see 6.2), strapping shall be finish B. When specified (see 6.2), strapping shall be finish A. The strapping shall encircle the utility element either lengthwise or girthwise, as applicable. Edge protectors shall be utilized on each edge and as required to prevent damage."

* 5.2.1.12, line 1, delete "D13220E1146" and substitute "D13220E5242".

Add sentence end of paragraph "All strap ends shall be secured to prevent damage to the unit during shipment."

5.2.2, delete in its entirety and substitute:

Source: https://assist.dla.mil -- Downloaded: 20260-22T21:27Z
Check the source to verify that this is the current version before use.

"5.2.2 Commercial. The water system and engine of the utility element shall be preserved as specified in 5.2.1 for level A. Preservation of all other components shall be in a manner to assure protection against deterioration and damage from the contractor to the initial destination. Components shall be placed and secured in their applicable compartments. Receptacles, connections and ports shall be capped or covered as provided for. Access panels and doors shall be securely fastened and latched."

* 5.3, line 1, delete "and packaged".

* 5.4, delete in its entirety and substitute:

"5.4 Marking (see 6.9).

5.4.1 Military. In addition to any special marking required by the contract or order, military marking for shipment and storage shall be in accordance with MIL-STD-129.

5.4.2 Commercial. Marking for commercial packaging shall reflect as a minimum, the item name, National Stock Number, quantity, contract or purchase order number, and appropriate address markings on the exterior of the utility element. The marking shall be applied with a waterproof material, be legible, and shall provide a definite contrast."

PAGE 60

6.2 (k), delete and substitute:

"(k) Degree of preservation required (see 5.2)."

PAGE 61

* 6.5, line 5, delete ", package".

PAGE 62

* 6.9, delete the last sentence and substitute "For purposes of preservation/packing level marking, the marking shall be A/A or X/A as applicable."

The margins of this amendment are marked with an asterisk to indicate where changes (additions, modifications, corrections, deletions) from the previous amendment were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous amendment.

Custodian:
Army - ME

Preparing activity:
Army - ME

Review activity:
DSA - GS

Project 6115-A465

Source: https://assist.dla.mil -- Downloaded: 20260-22T21:27Z
Check the source to verify that this is the current version before use.