MIL-C-45820D(AL)
20 January 1989
SUPERSEDING
MIL-C-45820C(AL)
22 May 1984

MILITARY SPECIFICATION

CABLE ASSEMBLIES, ELECTRICAL

This specification is approved for use within the US Army Armament Research, Development and Engineering Center, Department of Army and is available for use by all Departments and Agencies of the Department of Defense

1. SCOPE

1.1 Scope. This specification covers special flexible electric power cable assemblies to be used with generator to field shop shelters and field maintenance shop sets.

1.2 Classification. The cable assemblies shall be furnished in the following types and lengths as specified (see 6.2.1).

Type	Length
I	25 feet
V	10 feet
VI	25 feet
VIII	50 feet
IX	50 feet
X	100 feet
XI	50 feet
XII	25 feet

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications and standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issue of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS), and supplement thereto, cited in the solicitation.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, US Army Armament Research, Development and Engineering Center, ATTN: SMCAR-EST-S, Rock Island, IL 61299-7300 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4910

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

FEDERAL

PPP-B-601	-	Boxes, Wood, Cleated-Plywood
PPP-B-636	-	Boxes, Shipping, Fiberboard
PPP-T-60	-	Tape: Packaging, Waterproof

MILITARY

MIL-P-116	-	Preservation, Methods of
MIL-C-3432	-	Cable, (Power and Special Purpose) and Wire, Electrical (300 and 600 Volts)
MIL-I-3930	-	Insulating and Jacketing Compounds, Electrical (For Cables, Cords, and Wires), General Specification for
MIL-C-5501	-	Caps and Plugs, Protective, Dust and Moisture Seal
MIL-I-23053	-	Insulation Sleeving, Electrical, Heat Shrinkable, General Specification for
MIL-B-43436	-	Band Markers, Blank, General Specification for

STANDARDS

FEDERAL

FED-STD-H28	-	Screw-Thread Standards for Federal Services

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	-	Marking for Shipment and Storage
MIL-STD-130	-	Identification Marking of US Military Property
MIL-STD-454	-	Standard General Requirements for Electronic Equipment
MIL-STD-889	-	Dissimilar Metals
MIL-STD-1189	-	Standard Department of Bar Code Symbology
MIL-STD-1190	-	Minimum Guidelines for Level C Preservation, Packing and Marking
MIL-STD-1250	-	Corrosion Prevention and Deterioration Control in Electronic Components and Assemblies

2.1.2 Other Government documents and publications. The following other Government documents and publications form a part of this specification to the extent specified herein. Unless otherwise specified, the issues shall be those in effect on the date of the solicitation.

DRAWINGS

ARMY

12535411	-	Cable Assembly Power 120/208V 60 Hz 3 Phase

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

12535412 - Cable Assembly, Power, Generator
7550251 - Cable Assembly, PWR, Electrical-Generator to Shelter

US DEPARTMENT OF LABOR

29 Code of Federal Regulation (CFR), Chapter XVII, Parts 1900 to 1910 - Occupational Safety and Health Standards Act (OSHA)

(Copies of specifications, standards, handbooks, drawings, and publications required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.2 Other publications. The following document(s) form a part of thisspecification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted shall be those listed in the issue of the DoDISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS shall be the issue of the nongovernment documents which is current on the date of the solicitation.

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 - National Electrical Code

(Application for copies should be addressed to the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.)

(Nongovernment standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein (except for associated detail specifications, specification sheets or MS standards), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 First article. When specified in the contract or purchase order, a sample shall be subjected to first article inspection (see 4.2.1 and 6.2.1).

3.2 Design. The cable assemblies shall be new and of the design meeting the requirements as specified herein. Cable assemblies not covered by drawings shall be designed to shield the connectors within the plugs and receptacles against water, dust, and oil when connected to their mating components. All cable assembly parts that are not covered on a drawing and are subject to wear or replacement shall be accessible.

3.3 Materials. Materials not specifically designated herein or in the contract shall be of a quality commensurate with best commercial practices, shall be suitable for the intended purpose in the design and fabrication of the Electrical Cable Assembly, and shall meet all requirements specified herein. Materials shall be free from defects which would affect the performance, maintainability, reliability,

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

durability, or longevity of the individual components of the Electrical Cable Assembly. When dissimilar metals are used in contact with each other, suitable protection against galvanic corrosion shall be applied in accordance with MIL-STD-889.

3.3.1 Reclaimed materials. The manufacturer is encouraged to use reclaimed materials for fabricating new parts without jeopardizing the chemical and physical property, design integrity and intent of the materials originally selected or specified. The reclaimed materials shall have been reprocessed, remanufactured or recycled parts as is or rebuilt from scrap or other used equipment. Reclaimed parts shall not be used in the equipment.

3.3.2 Corrosion resistance. All metallic materials shall be corrosion resistant or shall be treated to resist corrosion in accordance with MIL-STD-1250, and general requirements of MIL-STD-454.

3.3.3 Conductors. The conductors shall be made of stranded copper wire and shall conform to Table I.

3.4 Construction. Each Electrical Cable Assembly shall be constructed of parts which are new, without defects and free of repairs. The cable assembly shall withstand all forces encountered when used in its intended environment to its maximum rating and capacity, without deformation or degradation.

3.4.1 Fastening devices. All screws, pins, bolts and similar fasteners used shall be installed with means for preventing loss of tightness. Such parts subject to removal or adjustment shall not be swaged, peened, staked or otherwise permanently deformed.

3.4.2 Threads. All threaded parts of the cable assemblies shall conform to FED-STD-H28 and the applicable "Detailed Standard" section referenced therein. No testing in FED-STD-H28 shall be required.

3.4.3 Electrical connections. Electrical connections shall be mechanically secured and soldered, or brazed; except connections on screw type terminals which shall be mechanically secured. Resin base fluxes shall be used in all soldering operations. All connections shall be in accordance with MIL-STD-454.

3.4.4 Welding, brazing or soldering. All welding, brazing and soldering shall be free of defects and of a quality which shall sustain all requirements of the welded, brazed or soldered parts. Defects shall include but are not limited to such things as bubbles, cracks, gouges, holes, insufficient materials used, etc. All flux or other such materials used during these operations shall be thoroughly removed (cleaned), from the part(s) immediately upon completion of the parts. The welding, brazing, and soldering shall be of a quality as noted in workmanship paragraph 3.10 within this specification and also in accordance with MIL-STD-454.

3.4.5 Safety and health requirements. The Electrical Cable Assemblies herein shall comply with standards promulgated under 29 Code of Federal Regulations (CFR), Chapter XVII - Occupational Safety and Health Act (OSHA) - Part 1910, Safety and Health Standards, in addition to the Army drawings listed herein. The cable assemblies above shall also be in full compliance with the NFPA 70. Exceptions and additional requirements for safety and health shall be as specified (see 6.2.1 and 6.5).

3.4.6 Interchangeability. All parts of the Electrical Cable Assembly shall be manufactured to definite standards and tolerances that will provide for the interchangeability of parts between electrical cable

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

assemblies of the same model. All parts of the Electrical Cable Assembly shall be interchangeable without requiring modification of the replacement part or its mating components. All parts subject to future replacement shall be assigned a manufacturers part number and shall be identified in the repair parts manual. All replacement parts shall provide the same or better form, fit, function, and performance as the respective parts initially installed in the Electrical Cable Assembly.

3.4.7 Surfaces. Surfaces of all castings, forgings, molded parts, stampings, and welded parts shall be cleaned and free of sand, dirt, fins, sprues, scale, flux and other harmful or extraneous materials.

3.4.8 Casting and forgings. All castings and forgings shall be free of defects, fins, scale, inclusions, cold shuts, voids, cracks, thermal ruptures, laps, folds, mismatching, etc. which affect serviceability or performance. No processes such as welding, peening, plugging, or filling with solder or paste shall be used for reclaiming parts.

3.5 Performance and product characteristics. The type cable assembly specified (see 6.2.1) shall conduct the amperage and voltage as specified in Table I of this specification under any of the following conditions or combination of conditions.

3.5.1 Temperature and humidity conditions.

3.5.1.1 Operating temperature. The type cable assembly specified (see 6.2.1) shall conduct the Table I specified amperage and voltage in an ambient temperature of 115 or higher degrees Fahrenheit (F) for four (4) or more hours to an ambient temperature of minus 25 or colder degrees F for 72 or more hours.

3.5.1.2 Humidity conditions. The type cable assembly specified (see 6.2.1) shall conduct the Table I specified amperage and voltage in an atmosphere having a relative humidity of 95 or more percent and an ambient temperature of 85 or more degrees F of 20 or more hours. Immediately following these conditions, the same cable assembly shall conduct the same Table I specified amperage and voltage in an atmosphere having a relative humidity of not less than 100 percent and an ambient temperature of 80 or more degrees F for 4 or more hours.

3.5.2 High voltage requirement. The Electrical Cable Assembly shall withstand, without damage, malfunction, breakdown, arcing, surface or air discharge, 2500 or more volts peak, 60 Hertz, sinusoidal wave electrical energy at standard temperature and pressure. The electrical energy shall be applied instantaneously at full voltage and shall be maintained for 15 or more seconds. Each cable assembly conductor shall be isolated from other conductors in the same assembly and all of these conductors shall be isolated from electrical ground. No arcing or discharge is acceptable.

3.5.3 Strain relief. Strain reliefs provided at both plug and receptacle end of cable assembly shall withstand an instantaneous pull of 30 pounds directly to the terminals and shall wholly maintain complete terminal attachment without any detachment or dislodgment of either electrical cable assembly plug or receptacle.

3.5.4 General. If not specified (see 6.2.1), the cable for manufacturing the CCCCCCC cable assemblies shall meet the requirements of MIL-C-3432 and MIL-I-3930.

3.5.5 Continuity. Color of cable assembly conductors shall be assigned to the plug pin and receptacle socket numbers respectively in accordance with the manufacturers standard practice. The designated

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

wire color from any labeled plug pin connection will terminate at the corresponding receptacle socket. Visual verification shall be ensured using a circuit continuity tester.

3.5.6 Waterproofness. When specified (see 6.2.1), the plugs and receptacles of Type I, Type VIII, and Type XII shall be waterproof when mated with their specified connector.

3.6 Design details of Type I, Type VIII, and Type XII cable assemblies. Types I, VIII, and XII cable assemblies shall be constructed in accordance with Table I.

3.6.1 Cable. Unless otherwise specified (see 6.2.1), cable shall be fabricated CCCCC of an oil and moisture resistant, heavy duty, hard service flexible cable conforming to the requirements of NFPA 70. When specified (see 6.2.1), the cable for the Type I and VIII cable assemblies shall conform to MIL-C-3432.

3.6.2 Plugs and receptacles for Type I, VIII, and XII cable assemblies. Connector shall be constructed to provide watertight seal upon connection with plug or receptacle of similar design.

3.6.2.1 Plug Type I and VIII. Unless otherwise specified (see 6.2.1), the plug for the Type I and VIII cable assemblies shall be a 600 volt, 60 ampere, two-pole, grounded through shell with rubber bushings and shall be watertight. The plug shall be equal to and interchangeable with the Crouse-Hinds, style 1, APJ6275-M54.

3.6.2.2 Plug Type XII. Unless otherwise specified (see 6.2.1), the plug for the Type XII cable assembly shall be 600 VAC, style I, 4 wire - 4 pole, 100 amp grounded plug sleeve type, and waterproof. The plug shall be equal to an interchangeable with 600 VAC, style I, 4 wire - 4 pole, 100 amp rated, Crouse-Hinds Part Number APJ10477M-54 or APJ10475M-54.

3.6.2.3 End. The sheath, filler, and binder shall be removed from the other CCC end of Type VIII cable for a length of 6 inches to expose the insulation of the conductors. 3.6.2.4 Receptacle connector Type I and Type III. Unless otherwise specified (see 6,2,1), the receptacle for the Type I cable assembly shall be a 600 volt, 60 ampere, two pole, ground through shell with rubber bushings, and shall be watertight. The receptacle shall be equal to and interchangeable with Crouse-Hinds Style I, APR 6255-M54; and this Type I receptacle shall mate with plug specified in 3.6.2.1.

3.6.2.5 Receptacle connector Type XII. Unless otherwise specified (see 6.2.1), the receptacle connector for the Type XII cable assembly shall be 600 volts AC (VAC), Style 1, 4 wire-4 pole, 100 amp, integrally grounded, receptacle housing detect spring type, and weatherproof. The receptacle connector shall be equal to and interchangeable with Crouse-Hinds Part Number APR10457M-54 or APR10455M-54.

3.7 Type V, VI, and IX. Type V, VI, and IX cable assemblies shall be in accordance with Table I and shall conform to Army Drawing 7550251.

3.8 Type X and XI cable assembly. Type X and XI cable assembly shall conform to Army Drawings 12535411 and 12535412 respectfully.

3.9 Identification marking. The cable assemblies shall be marked for identification in accordance with MIL-STD-130 and shall include the National Stock Number (NSN) unless otherwise specified (see 6.2.1). As a minimum, the following information shall be listed: .JN

Source: https://assist.dla.mil -- Downloaded: 20260-22T03:57Z
Check the source to verify that this is the current version before use.

a. Supplier's name or trademark.
b. Date of manufacture (year).
c. National Stock Number.
d. Rated cable voltage.

The marking shall be either by indent lettering, by raised lettering on the sheath itself, on thin rubber slips molded into the sheath that do not project above the surface of the sheath more than 1/16 inch, by a metal wrap-around tag conforming to MIL-B-43436, or heat shrink sleeving conforming to MIL-I-23053.

3.10 Workmanship. The quality of workmanship imparted to the item and all of its components shall equal or exceed that typically provided to commercial products by domestic producers of the type of item addressed herein. The items presented for acceptance shall have been manufactured with skill and care, shall be uniform, neat, and clean, and shall be free of irregularities and anomalies which degrade form, fit, function, performance, and appearance.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specifications where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. Unless otherwise specified, first article inspection shall be applied to the preproduction model or initial production item. Unless otherwise specified (see 6.2.1), first article inspection shall consist of the product examination in 4.3 and all tests under 4.4. Failure of the first article to pass the examination or any of the tests shall be cause for rejection.

4.2.2 Quality conformance inspection. Quality conformance inspection shall be applied to production units being offered for acceptance under the contract. The inspection shall consist of a through e as follows and failure of any unit to pass these inspections or tests shall be cause for rejection of the unit.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

a. Produce examination (4.3)
b. High voltage requirement (4.4.4)
c. Continuity test (4.4.5)
d. Water proof test (4.4.6)
e. Packaging inspection (4.5)

4.2.2.1 Sampling. Sampling for quality conformance inspection shall be in CCCCCCCC accordance with MIL-STD-105, using Inspection Levels and Acceptable Quality Levels (AQL) as listed, unless 100 percent inspection is specified. Cable assemblies having one or more connectors shall be water proof tested. One cable assembly per lot, exclusive of the first article, shall be tested.

Inspection or Test	Inspection Level	AQL
Product examination (4.3)	II	1.0
High voltage requirement (4.4.4)	100%	-
Continuity tests (4.4.5)	100%	-
Water proof test (4.4.6)	1/lot	-
Packaging inspection (4.5)	S-4	4.0

Note: Lot size shall be no more than 150 assemblies.

4.3 Product examination. Visually, dimensionally and manually examine the assembly to determine conformance with the requirements of 3.2 through 3.4.8, 3.5.4, and 3.6 through 3.10. Visual examination shall include verification of completeness of manufacture, conformance to specified standards, adequacy of markings, proper cleaning, and freedom from identified defects. Dimensional examinations shall include all dimensions specified in Table I. Manual examination shall include the operation of movable parts by hand to assure proper functioning. The examination provisions may be applied at the earliest practical point in manufacture at which it is feasible to inspect for acceptance without risk of change in the characteristic by subsequent operations. Failure of the contractor to provide objective evidence that the assembly has passed the examinations prescribed for it by the contractor's inspection system shall be cause for rejection. In addition, failure of the contractor to provide objective evidence that all parts are manufactured to definite standards, clearances and tolerances so that no replacement part will degrade the form, fit or function of the end item (see 3.4.6), shall be cause for rejection.

4.4 Tests.

4.4.1 Environmental temperature test. A complete cable assembly, coiled in its final shipping configuration , shall be placed in a temperature chamber set at no less than 115 degrees Fahrenheit (F) for no less than four hours. The chamber shall then be set to minus 25 degrees F or colder. At the end of this period, the cable shall be removed from the chamber and immediately uncoiled. The cable shall then be examined for damage. Evidence of any cracks or breaks in the insulation , or damage to a connector shall be cause for rejection (3.5.1.1).

4.4.2 Humidity test. The same cable assembly tested in 4.4.1 shall be used in this test. The cable shall be placed in an environmental chamber for not less than 20 hours at a temperature of no less than 85 degrees F and a relative humidity of no less than 95 percent. The temperature shall then be lowered to no less than 80 degrees F and the relative humidity set to 100 percent for four hours. At the end of this test, any excess moisture shall be wiped from the surface of the cable and the assembly examined. Evidence of cracks, breaks or deformation shall be cause for rejection (3.5.1.2). Immediately following

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

this test, those assemblies with connectors shall be subjected to the pull test of 4.4.3. Following the pull test, the cable shall be subjected to the high voltage requirement test of 4.4.4.

4.4.3 Pull test. With the receptacle and plug securely held, a pull of 30 CCCCCCCCC pounds shall be applied to the cable for one minute. The direction of pull shall be in line with and away from the connector entry hole. Any slippage of the connector, or any broken strands or other evidence of stress on the conductors shall be cause for rejection (3.5.3).

4.4.4 High voltage requirement. A 60 Hertz test voltage shall be applied between each conductor and to the connector shells and every other conductor in the cable. The volt-ampere capability of the test voltage source shall be of sufficient capacity to maintain a voltage of at least 2500 volts peak when applied to a nondefective cable. The test voltage shall be maintained for no less than 15 seconds. Any audible or visible evidence of puncture, arcing, or other electrical breakdown, or a test voltage drop below 2500 volts peak at any time during the test shall be cause for rejection (3.5.2).

4.4.5 Continuity test. Every conductor in the completed cable assembly shall be tested for continuity. Cables having a connector at each end shall have continuity verified between corresponding pin designations. Cables with connectors on only one end shall have the continuity verified and that each connector pin is connected to the conductor of the correct insulation color. Failure to verify the correct continuity shall be cause for rejection (3.5.5).

4.4.6 Water proof test. The type I, VIII and XII cable assemblies shall be water proof tested. One cable from each lot, exclusive of the first article, shall be tested. The test shall consist of mating one of the cable assembly connectors with its conjugate connector. The connector pair and at least two inches of cable shall be completely immersed in a container of tap water, no colder than 60 degrees F, for no less than two hours. Immediately upon removal from the water, the exterior of the cable and the connector pair shall be wiped dry. Oven or forced air drying shall not be used to dry the assembly. The connectors shall not be disconnected. All conductors at the cable end that was not immersed shall then be subjected to the high voltage requirement test of 4.4.4. Those cable assemblies having a connector at each end shall then have the second connector tested in the same manner as the first. Failure of the cable assembly as evidenced by failure of test 4.4.4, shall be cause for rejection (3.5.6).

4.5 Packaging inspection. The items shall be inspected before and after packaging to determine compliance with the preservation, packaging, packing and marking requirements specified in Section 5.

5. PACKAGING

5.1 Preservation. Preservation shall be Level A or C, as specified (se 6.2.1).

5.1.1 Level A.

5.1.1.1 Cleaning. The cable assemblies shall be cleaned in accordance with CCCCCCCC procedures C-1 of MIL-P-116.

5.1.1.2 Drying. The cable assemblies shall be dried in accordance with procedures D-1 and D-4 of MIL-P-116.

5.1.1.3 Preservation. The cable assemblies shall be preserved in accordance with method III of MIL-P-116. The plug openings and receptacle shall be covered with tape conforming to PPP-T-60 or

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

with plastic plugs or caps conforming to MIL-C-5501. Coil cable to a minimum safe diameter and secure with at least three ties of cotton twine or tape, of sufficient strength to prevent breaking or uncoiling of cable.

5.1.1.4 Unit pack. The method of unit protection for the cable assemblies CCCCCCCCC shall be fiberboard containers conforming to PPP-B-636, class weather-resistance. Containers shall be closed in accordance with the appendix of the box specification.

5.1.2 Level C. The cable assemblies shall be preserved and provided with unit protection in accordance with MIL-STD-1190.

5.2 Packing. Packing shall be Level A, B, or C, as specified in the contract CCCCCCC (see 6.2.1).

5.2.1 Level A. When level A packing is specified, the cable assemblies shall be packed in cleated plywood boxes conforming to PPP-B-601, overseas type (see 6.2.1). Closure shall be in accordance with the appendix of the box specification.

5.2.2 Level B. The cable assemblies shall be packed the same as for Level A except that the shipping containers shall be domestic type or class 1, as applicable and class B strapping limitations need not apply.

5.2.3 Level C. Level C packing for the cable assemblies shall be in accordance with the requirements of MIL-STD-1190.

5.3 Marking. All markings required by the contract or purchase order, interior packages and exterior shipping containers shall be marked in accordance with MIL-STD-129. Bar code markings are required and shall be applied in accordance with MIL-STD-129 and MIL-STD-1189.

6. NOTES

6.1 Intended use. The cable assemblies are intended to be used on maintenance and repair shop specialized equipment. They may be subjected to the most severe usage and to the action of salt air, moisture, extremely dry, dusty atmospheric conditions, and extremes of temperature. The specific uses are as follows:

Type I - For automotive field maintenance shop sets
Type V - For generator to field shop shelter
Type VI - For generator to field shop shelter
Type VIII - For automotive field maintenance shop sets
Type IX - For generator to field shop shelter
Type X - For shelter to shelter
Type XI - For generator to shelter
Type XII - For electrical power

6.2 Ordering data.

6.2.1 Acquisition requirements. Acquisition documents should specify the following: .JN

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

a. Title, number, and date of this specification.
b. Type and length required (see 1.2).
c. First article, when required (see 3.1).
d. Special safety devices, when required (see 3.4.5 and 6.5).
e. Operating temperatures, if different (see 3.5.1.1).
f. Humidity conditions, if different (see 3.5.1.2).
g. General, when required (see 3.5.4)
h. Waterproofness, when required (see 3.5.6).
i. Cable, if different and when required (see 3.6.1).
j. Plug requirements, if different (see 3.6.2.1 and 3.6.2.2).
k. Receptacle requirements, if different (see 3.6.2.4 and 3.6.2.5).
l. Identification marking, if different (see 3.9).
m. First article inspection, when required (see 4.2.1).
n. Quality conformance inspection (see 4.2.2).
o. Sampling (see 4.2.2.1).
p. Product examination (see 4.3).
q. Tests (see 4.4).
r. Preservation level required (see 5.1).
s. Packing level required (see 5.2).
t. Cleated plywood boxes, when required (see 5.2.1).

6.2.2 Contract data requirements. Required technical data such as operator's manuals, parts lists, and other instructions for operations and maintenance, as identified on a numbered DD Form 1664, should be specified on a DD Form 1423 incorporated in the contract.

6.3 Subject term (key word) listing.

AMSC Number
Design
First article
First article inspection
Materials
Ordering data
Performance
Protective finish
Scope
Welding
Workmanship

6.4 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

6.5 Safety and health determinations. In order that equipment integrated into the user's operational environment will comply with OSHA limitation and control of noise levels, radiation, electromagnetic emission, noxious vapors, heat, etc., as applicable, specific requirements concerning guarding the point(s) of operation, and other safety and health requirements should be specified by the user/requisitioner (see 6.2.1).

Custodian: Preparing activity:

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

Army - AL

Army - AL

Review activities:
Army - SM, AT, CS, ER

Project No. 4910-A650

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T03:57Z
Check the source to verify that this is the current version before use.

TABLE I. Cable Characteristics

Type	Conductors Under One Cover			Cover	Fittings	Volts	Over-all assembly length ft.
	Qty	Size AWG	Min Strands per Conductor				
I	3	(1) No. 4 (1) No. 4 (1) No. 8	133 133 49	Styrene-butadiene rubber (SBR) or Cloroprene Jacket	1 Plug: 2 Pole, Para 3.6.2 & 3.6.2.1 1 Receptacle: 2 Pole Para 3.6.2.4	600 AC, 60 Amps 25 DC	25
V	4	(4) No. 4	133	Cloroprene	As specified on drawing 7550251	600 AC	10
VI	4	(4) No. 4	133	Cloroprene	As specified on drawing 7550251	600 AC	25
VIII	3	(1) No. 4 (1) No. 4 (1) No. 8 1/	133 133 49	SBR or Cloroprene Jacket	1 Plug: 2 Pole, Para 3.6.2 & 3.6.2.1 Exposed Insulated conductors, Para 3.6.2.3	600 AC, 60 Amps 25 DC	50
IX	4	(4) No. 4	133	Cloroprene	As specified on drawing 7550251	600 AC	50
X	5	(5) No. 6	133	Neoprene Jacket	As specified on drawing 12535411	120/208 AC	100
XI	5	(5) No. 6	133	Neoprene Jacket	As specified on drawing 12535412	120/208 AC	50
XII	4	(3) No. 2 (1) No. 2 1/	133	Oil Resistant Thermoset Cover Type SO Cable	1 Plug: Style 1, 4 Wire, 4 Pole, Para. 3.6.2.2, 1 Receptacle: Style I, 4 Wire, 4 Pole, Para. 3.6.2.5	600 AC, 100 Amps 600 AC, 100 Amps	25

1/ Ground wire shall be green or green with yellow stripes.

Source: https://assist.dla.mil -- Downloaded: 2026-02-22T03:57Z
Check the source to verify that this is the current version before use.