INCH-POUND
30 May 1989
A-A-50681

COMMERCIAL ITEM DESCRIPTION

TRAILER, MAINTENANCE POWER

The General Services Administration has authorized the use of this Commercial Item Description.

Scope. This commercial item description (CID) covers a mobile power unit used to supply electric power, ventilation, compressed air, and water removal for telecommunication and utility installation and maintenance crews in cable vaults and manhours at locations distant from commercial sources of power.

Applicable documents.

Specifications and standards. The following specifications and standards form part of this CID to the extent specified herein. Unless otherwise specified, the issues of this document are those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

MILITARY

VV G 1690	Gasoline, automotive, leaded or unleaded
MIL G 3056	Gasoline, automotive, combat
MS51336	Lunette and coupler drawbar, ring

(Copies of specifications, standards and other Government documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity).

Order of precedence. In the event of conflict between the text of this CID and the references cited herein (except for the associated detail specifications, specification sheets or MS standards) the text of this CID takes precedence. Nothing in this CID, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

Beneficial comments, recommendations, additons, deletions, clarification, etc. and any data which may improve this document should be sent to: Engineering Division SA-ALC/MMEDO, Kelly AFB TX 78241-5000

AMSC N/A FSC 4940

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:45Z
Check the source to verify that this is the current version before use.

Salient characteristics.

1. General. The mobile power utility trailer shall be suitable for its intended use. Structural elements shall be rigid and possess the requisite strength. Individual components shall be durable, reliable and suited for their intended purposes. The engine generator set, compressors and pump shall be standard commercial products. Service and parts shall be readily available for all components. The unit shall be towable at 60 MPH along paved highways. It shall have the following approximate minimum/maximum dimensions:

Length	124 in / 136 in
Width	68 in / 68 in
Height	50 in / 58 in

2. Trailer. The trailer shall be a low profile unit, properly balanced to be handled by one person. The frame shall be all steel construction with minimum 10 gauge formed channel steel capable of supporting all equipment and accessories. The trailer shall have a spring steel suspension. It shall travel on two F78x15, minimum size, tires, and have a 36 inch adjustable front landing gear with pneumatic tire. It shall have mechanical type parking brakes and hydraulic, fully self-contained, surge type service brakes. A towbar with lunette conforming to MS51336 (3 inch dia. eye and 1 5/8 dia. ring) and safety chains shall be provided. The trailer shall have fenders, recessed tail lights, stop and turn signals. A seven conductor electrical connector shall comply with SAE J560. An intervehicle jumper cable with plugs conforming to SAE J560 shall be provided.

3. Equipment and storage area. Equipment and accessory storage areas shall be provided. Winged doors on each side of th storage cabinet shall be securable in the open position. All doors shall be lockable with a common key. The storage cabinet shall have a minimum of 20 cubic feet designated storage space with access from either side. The equipment area shall be sufficient to provide for ease of access for full servicing of all equipment and the rear of the control panel. There shall also be storage areas for hoses, platform supports, and extension boards. The floor shall have a sufficient number of drain holes. The storage compartment shall have a DC light.

4. Control panel. the control panel shall be easily accessible and located at the rear of the unit. It shall be incorporated in the shell of the equipment storage cabinet. It shall have a DC light. It shall have a door to covers all switches, outlets, gauges and meters. It shall be lockable with the common key. It shall include three 120 VAC, GFI protected duplex receptacles; one 240 VAC, GFI protected receptacle; one DC ammeter, two AC ammeteres, one AC voltmeter, and electric hour meter, and circuit breaker on/off switched for each circuit. The rear of the control panel shall provide for easy removal and re-connenction of individual components.

5. Engine generator set. A minimum 7.5 KW, continuous duty, 120/240 VAC, 60 cycle, single phase, AC/DC generator directly connected to a four cycle gasoline engine rated 14 HP at 1800 RPM, water cooled, oil lubricated, electrically started, and designed in accordance with NEMA, AIEE and ASA standards shall be

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:45Z
Check the source to verify that this is the currentversion before use.

provided. Fuel will be MIL-G-3056 or VV-G-1690 automotive gasoline. The engine shall have a low oil pressure and high water temperature safety shut-offs. It shall have a replaceable oil filter and a 12 VDC starting battery, 36 month maintenance free. The set shall be of sufficient quality to average a minimum of 2500 hours of operation between major overhauls. The exhaust system shall have a silencer assembly. An electric engine block heater shall be provided. Two 12 gallon, minimum, fuel tanks with fuel gages shall be secured at the front of the trailer.

6. Compressors. Dual 3/4 HP air compressors, oilless type, single stage, drip proof, ball bearing design, shall provide 5 CFM at 100 PSI. They shall be activated by a combination switch-circuit breaker on the control panel. An air pressure switch shall automatically start the primary compressor when pressure in the receiver drops to 80 PSI and stop it when pressure reaches 100 PSI. The secondary compressor shall automatically start when the pressur drops to 75 PSI and stop when pressure reached 95 PSI. A high pressure line shall have a gauge and regulator assembly adjustable to furnish air from 0 to 100 PSI. A low pressure, dry air line shall contain and air filter and heatless desiccant type dryer. It shall have a gauge and regulator assembly which shall be adjustable to furnish air form 0 to 40 PSI for communications cable pressurization and flash testing. A 12 gallon, minimum, ASME stamped air tank with automatic drain and 1/4 inch by 25 foot air hose assembly with quick connector shall be provided.

7. Pump. A two inch submersible pump. 120 VAC, shall provide 110 GPM pumping rate. It shall be activated by a combination switch-circuit breaker on the control panel. A 2 inch by 25 foot discharge hose with quick connector shall be provided.

8. Ventilation equipment. A two speed blower shall deliver 1000 CFM free air a high speed for purging and 640 CFM free air at low speed for ventilating. The blower speed switch shall be on the control panel. The blower intake shall be located on the right side of the trailer and away form engine exhaust. The blower outlet shall be located at the rear of the trailer. The blower outlet shall allow and eight inch flexible blower hose to be attached. An 8 inch by 20 foot blower hose, with storage provision on the trailer, shall be provided. A heat exchanger, incorporated into the blower assembly, shall transfer heat fromt he einge colling water to the blower air. It shall be capable of raising the temperture of the air leaving the blower 100 degrees F over the ambient temperature. An electric water pre-heater shall facilitate a supply of warm air prior to the engine reaching sufficient temperature to warm its cooling system. The pre-heater shall work in conjunction with the engine to provide increased capability in cold weather. The heater control switches shall be mounted on the control panel.

9. Accessories. Accessories to be included are:

   a. Light standard adjustable to nine feet. An amber strobe light and two 300 watt (minimum) floodlight assemblies. A bracket shall be mounted inside the cabinet for storing the strobe and floodlight assemblies.

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:45Z
Check the source to verify that this is the currentversion before use.

b. A 12 inch deep manhole rim with air inflatable bladder for sealing and seating with mounting bracket or holder.

c. A manhole guard rail with holder.

10. Spare Parts. Spare parts to be provided are:

a. Oil, fuel and air filters, spark plugs, condenser, rotor, and distributor cap.

b. Two replacement lamps for the flood lights.

c. One replacement lamps for the strobe light.

d. One each bulb for the control panel and storage compartment lights.

11. Assembly. The unit sshall be furnished complete, with all equipment normally supplied, fully assembled and ready for use.

Certification. The contractor shall certify and maintain substantiating evidence that the product offered meets the salient characteristics of this description and that the product conforms to the producer's own drawings, specifications, standards and quality assurance practices and is the same product offered for sale in the commercial marketplace. Small businesses that cannot offer products with established commercial market acceptability, may compete by submission of bid samples. (The Government reserves the rights to require prof of such conformance before first delivery and thereafter as may be otherwise provided for under the provisions of the contract.)

Regulatory Requirements. The mobile power utility trailer shall comply with all applicable Federal Motor Carrier Safety Regulations and OSHA Regulations.

Packaging, packing and marking. The items shall be packaged in accordance with normal commercial practice and packed to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping container shall be in compliance with National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

Known acceptable products. The following product is known to meet the requirements of this CID.

Manufacturer	Model	NSN
Hesco Div Missouri Research Labs (CAGE 00602)	1500-3A-AF	4940-01-264-2233

Source: https://assist.dla.mil -- Downloaded: 202640-26T08:45Z
Check the source to verify that this is the currentversion before use.

Custodians:
Air Force - 99
Army - AL

Preparing activity:
Air Force - 82

(Project 4940-0533)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:45Z
Check the source to verify that this is the current version before use.