MIL-F-10934A(CmlC)
30 June 1957
SUPERSEDING
MIL-P-10934 (CmlC)
13 February 1951

MILITARY SPECIFICATION
FILTER UNIT, GAS-PARTICULATE, GED (or EMD), 300 CFM, ABC-M6

1. SCOPE

1.1 This specification covers one type of filter unit for use in protecting shelters that can be pressurized with air at a flow rate of 300 cubic feet per minute (c.f.m.) against war gases. The filter unit shall be gasoline engine driven or electric motor driven as specified in the contract or order (see 6.2).

2. APPLICABLE DOCUMENTS

2.1 The following standards and drawings, of the issue in effect on date of invitation for bids, form a part of this specification:

STANDARDS

MILITARY

MIL-STD-10	-	Surface Roughness, Waviness, and Lay.
MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	-	Marking for Shipment and Storage.

DRAWINGS

CHEMICAL CORPS

D5-19-726	-	Filter Unit, Gas-Particulate, 300 CFM, ABC-M6 - Bill of Material (3 sheets)
D5-20-139	-	Packing, Filter Unit - Bill of Material.

FSC 4240

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.

(Copies of specifications, standards, drawings, and publications required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

3. REQUIREMENTS

3.1 Materials. - All materials and components used in the manufacture and assembly of the filter unit shall conform to the specifications, standards, and drawings forming a part of this specification.

3.2 Manufacture and assembly. - The filter unit shall be manufactured and assembled as specified on Drawings D5-19-702, D5-19-703, and D5-19-704 which are listed on Drawings D5-19-726 and subsidiary drawings listed thereon. Surface roughness, waviness, and lay specified by symbols on detail drawings shall comply with the applicable classes specified in Standard MIL-STD-10.

3.3 Functioning. - The filter unit shall deliver not less than 300 c.f.m. of air, corrected to standard conditions (dry air at a temperature of 70°F. and a pressure of 29.92 inches of mercury) and when operating at 3450 ± 50 revolutions per minute and tested as specified in 4.4.

3.4 Workmanship. - The filter unit shall be free from any damage, defects, or contamination.

4. QUALITY ASSURANCE PROVISIONS

4.1 Lot. - A regular production lot shall consist of the filter units produced by one contractor, from the same materials, and under essentially the same manufacturing conditions. However, not more than one lot of gas filters shall be represented in any one lot of finished filter units. The inspection lot for nondestructive inspection, within the above limitations shall be designated by the inspector.

4.2 Sampling for nondestructive inspection. - Sampling for nondestructive inspection shall be conducted in accordance with the classification of defects (see 4.3.3) and Standard MIL-STD-105.

4.3 Inspection

4.3.1 Components. - The inspector shall ascertain that all materials, components, or subassemblies of the filter unit covered by separate specifications, standards, or drawings are in accordance with their respective specifications, standards, or drawings prior to final acceptance of the filter unit.

4.3.2 Packaging, packing, and marking. - The inspector shall inspect the packaging, packing, and marking of the filter unit for compliance with section 5.

4.3.3 Classification of defects. - Inspection of the filter unit shall be conducted as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.

4.3.3.1 Filter unit, gas-particulate, GED (or EMD), 300 CFM, ABC-M6. - (Dwgs. D5-19-702, D5-19-703, and D5-19-704 which are listed on Dwg. D5-19-726)

Categories and defects	Acceptance standards
Critical	
A. Functioning	4.4
Major	AQL 1.0 percent defective
1. Component missing, incorrect, or incorrectly assembled	
2. Marking (including nameplate) incorrect (misleading)	
3. Damage	
Minor	AQL 4.0 percent defective
41. Coating missing, incorrect, or inadequate	
52. Marking incorrect (missing or illegible)	
Incidental	AQL 10 percent defective
101. Contamination	

4.3.3.2 Packing, filter unit. - (Dwg. D5-20-140 which is listed on Dwg. D5-20-139) (Prior to closure of interior containers)

Categories and defects	
Major	AQL 0.65 percent defective
1. Interior containers type and size incorrect	
2. Processed components missing or incorrect	
3. Damage	
4. Marking incorrect, missing or illegible	
Minor	AQL 2.5 percent defective
51. Components incorrectly preserved or wrapped	
52. Cushioning and bracing missing or incorrect	
53. Contamination	
Incidental	
None	

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.

4.4 Functioning test. - The air inlet hose assembly (Dwg. C5-19-735 which is listed on Dwg. D5-19-726) and the air outlet hose assembly (Dwg. C5-19-736) which is listed on Dwg. D5-19-726) shall be assembled on the blower unit of the filter unit. The filter unit shall then be operated for a period of 10 minutes by either the electric motor or the gasoline engine and the volume of air delivered shall be measured.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging, level A. - The filter unit shall be processed and packaged for shipment as specified on Drawing D5-20-140 which is listed on Drawing D5-20-139.

5.2 Packing, level A. - The filter unit shall be packed for shipment as specified on Drawing D5-20-140 which is listed on Drawing D5-20-139.

5.3 Marking. - In addition to any special marking required by the contract or order, all interior packages and all shipping containers shall be marked in accordance with Standard MIL-STD-129.

6. NOTES

6.1 Ordering data. - Procurement documents should specify the following:

a. Title, number, and date of this specification.
b. That the filter unit shall be gasoline engine driven or electric motor driven as applicable.

6.2 Stock number. - The Federal stock numbers for this item are as follows:

a. Filter unit, gas-particulate, GED, 300 CFM, ABC-M6 - 4240-368-6126.
b. Filter unit, gas-particulate, EMD, 300 CFM, ABC-M6- 4240-368-6127.

Notice. - When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Custodian:

Army - Chemical Corps

Other interest:

Army - EMT
Air Force

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE NAVY

POSTAGE AND FEES PAID
NAVY DEPARTMENT

OFFICIAL BUSINESS

COMMANDING OFFICER
EDGEWOOD ARSENAL
ATTN: SMUEA-QA-WS-S
EDGEWOOD ARSENAL, MARYLAND 21010

FOLD

PLATE NO. 15419 (BACK)

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 119-R004

INSTRUCTIONS

This sheet is to be filled out by personnel either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity (as indicated on reverse hereof).

SPECIFICATION

ORGANIZATION *(Of submitter)*	CITY AND STATE

CONTRACT NO.	QUANTITY OF ITEMS PROCURED	DOLLAR AMOUNT
		$

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES.

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?

☐ YES ☐ NO IF "YES", IN WHAT WAY?

4. REMARKS *(Attach any pertinent data which may be of use in improving this specification. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity)*

SUBMITTED BY *(Printed or typed name and activity)*	DATE

DD, FORM 1 APR 63 1426 REPLACES NAVSHIPS FORM 4863, WHICH IS OBSOLETE C-0279

Source: https://assist.dla.mil -- Downloaded: 2026-10-17T14:37Z
Check the source to verify that this is the current version before use.