MIL-T-22238H(MF)
10 February 1987
SUPERSEDING
MIL-T-22238G
8 August 1980

MILITARY SPECIFICATION

TANK, LIQUID STORAGE, METAL, FOR PETROLEUM PRODUCTS, HORIZONTAL WITH SKIDS, 600-GALLON CAPACITY

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers a 600-gallon aluminum tank used for the transportation, dispensing, or storage of liquid petroleum products.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. The following specifications, and standards form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto, cited in the solicitation.

SPECIFICATIONS

FEDERAL

P-D-223	- Detergent, General Purpose, Liquid, Heavy Duty.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: USA Belvoir Research, Development, and Engineering Center, ATTN: STRBE-TSE, Fort Belvoir, VA 22060-5606 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 5430
DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

PPP-B-601	- Boxes, Wood, Cleated-Plywood.
PPP-P-40	- Packaging and Packing of Hand Tools.
PPP-T-60	- Tape: Packaging, Waterproof.

MILITARY

MIL-P-116	- Preservation, Methods of.
MIL-R-196	- Repair Parts, Accessories and Kits, Mechanical, Packaging of.
MIL-T-704	- Treatment and Painting of Materiel.
MIL-C-46168	- Coating, Aliphatic Polyurethane Chemical Agent Resistant.
MIL-C-52950	- Crates, Wood, Open and Covered.

STANDARDS

FEDERAL

FED-STD-101	- Test Procedures for Packaging Materials.

MILITARY

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-130	- Identification Marking of U.S. Military Property.
MIL-STD-889	- Dissimilar Metals.
MIL-STD-1472	- Human Engineering Design Criteria for Military Systems, Equipment and Facilities.

2.1.2 Other Government documents and drawings. The following other Government documents and drawings form a part of this specification to the extent specified herein. Unless otherwise specified, the issues shall be those in effect on the date of the solicitation.

DRAWINGS

ME

TA13226E2146	- Tank, Liquid Storage, Metal for Petroleum Products, Horizontal with Skids, 600-Gallon Capacity.

(Copies of specifications, standards, drawings, and other Government documents required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the current version before use.

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DOD adopted shall be those listed in the issue of the DoDISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS shall be the issue of the non-Government documents which is current on the date of the solicitation.

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

Boiler and Pressure Vessel Code Section IX, Welding Qualifications

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017).

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 3951 - Standard Practices for Commercial Packaging

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

AMERICAN WELDING SOCIETY (AWS)

D1.2 Structural Welding Code - Aluminum

(Application for copies should be addressed to the American Welding Society, 2501 NW, Seventh Street, Miami, FL 33125).

(Non-Government standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 Description. The tank shall be in accordance with Top Assembly TA13226E2146 and as specified herein.

3.1.1 Drawings. The drawings forming a part of this specification are end product drawings. No deviation from the prescribed dimensions or tolerances is permissible without prior approval of the contracting officer. Where tolerances could cumulatively result in incorrect fits, the contractor shall provide tolerances within those prescribed on the drawings to insure correct fit, assembly, and operation of the tanks. Any data (e.g. shop drawings, layouts, flow sheets, processing procedures, etc.) prepared by the contractor or obtained from a vendor to support fabrication and manufacture of the production item shall be made available upon request, for inspection by the contracting officer or his designated representative.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

3.2 First article (first produced tank). The contractor shall furnish one first article tank as specified (see 6.2) for examination and testing within the time frame specified (see 6.2) to prove that his production methods and choice of design detail will produce tanks that comply with the requirements of this specification. Examination and test shall be as specified in Section 4 and shall be subject to surveillance and approval by the Government (see 6.3).

3.3 Material. Material shall be as shown on the applicable drawings. Materials not specified shall be selected by the contractor and shall be subject to all provisions of this specification (see 3.3.4).

3.3.1 Materiel deterioration prevention and control. The tanks shall be fabricated from compatible materials, inherently corrosion resistant or treated to provide protection against the various forms of corrosion and deterioration that may be encountered in any of the applicable operation and storage environment to which the tanks may be exposed.

3.3.2 Dissimilar metals. Dissimilar metals shall not be used in intimate contact with each other unless protected against galvanic corrosion. Dissimilar metals and methods of protection are defined and detailed in MIL-STD-889.

3.3.3 Identification of materials and finishes. The contractor shall identify the specific material, material finish or treatment for use with components and subcomponents, and shall make the information available, upon request, to the contracting officer or designated representative.

3.3.4 Recovered materials. For the purpose of this requirement, recovered materials are those materials which have been collected from solid waste and re-processed to become a source of raw materials, as distinguished from virgin raw materials. The components, pieces and parts incorporated in the tanks may be newly fabricated from recovered materials to the maximum extent practicable, provided the tanks produced meets all requirements of this specification. Used, rebuilt or remanufactured components, pieces and parts shall not be incorporated in the tanks.

3.4 Human factors engineering. The tanks shall conform to human factors engineering design criteria as described in MIL-STD-1472, paragraphs 4 (General Requirements), 5.4 (Controls), 5.5 (Labeling), 5.9 (Design for Maintainability) and 5.13 (Hazards and Safety). The tanks shall be operable and maintainable by 5th percentile female through 95th percentile male soldiers who are dressed appropriately for the intended environments of use.

3.5 Treatment and painting. The portions of tanks normally painted internally and externally shall be cleaned, treated, and painted in accordance with MIL-T-704, type F or G, as applicable. Unless otherwise specified (see 6.2) top coat color shall be camouflage green 383 conforming to MIL-C-46168.

3.6 Identification marking. The tanks shall be identified in accordance with MIL-STD-130.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

3.7 Workmanship.

3.7.1 Fabrication. Metal used in the fabrication shall be free from kinks, sharp bends and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the materials to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to ensure uniformity of size and shape. Plasma cutting may only be used on non-heat treatable aluminum alloys and the heat affected zone must be removed by grinding. Precaution shall be taken during all fabrication to avoid overheating. External surfaces shall be free of burrs, sharp edges and corners except where sharp edges and corners are required or where they are not detrimental to safety.

3.7.2 Bolted connections. Bolt holes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided and all bolts, nuts and screws shall be tight.

3.7.3 Welding. The surfaces of parts being welded shall be free from oxides, paint, grease and other foreign matter. Welds shall transmit stress without permanent deformation or failure when the parts connected by the welds are subjected to proof and service loading. Welding shall be in accordance with AWS D1.2. The welding process used in the fabrication shall be at the option of the contractor.

3.7.4 Welders and welding operators. Before assigning any welder or welding operator to welding work covered by this specification, the contractor shall obtain certificaiton that the welder or welding operator has passed qualification tests as prescribed by one of the welding codes for the types of welding operations to be performed and that such qualification is effective as defined by the codes which follow:

AWS D1.2 Structural Welding Code - Aluminum
ASME Boiler and Pressure Vessel Code - Section IX. Welding Qualifications.

Certification shall be made available for review by the contracting officer or designated representative. The Government reserves the right to require recertificaton of any welder or welding operator.

3.7.5 Welding procedure. Welding procedure shall be qualified in accordance with AWS D1.2. Welding procedure shall be made available to the contracting officer or designated representative.

3.7.6 Tack welds. Tack welds must meet the same quality requirements as the welds.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.1.2 Component and material inspection. The contractor is responsible for ensuring that components and materials are manufactured, examined and tested in accordance with referenced specifications, standards and drawings, as applicable.

4.2 Classification of inspection. The inspection requirements specified herein are classified as follows:

a. First article tank inspection (see 4.3).
b. Quality conformance inspection (see 4.4).
c. Inspection comparison (see 4.6).
d. Inspection of packaging (see 4.7).

4.3 First article tank inspection.

4.3.1 Examination. The first article tank shall be examined as specified in 4.5.1. Presence of one or more defect shall be cause for rejection.

4.3.2 Test. The first article tank shall be tested as specified in 4.5.2.1. Failure of this test shall be cause for performing the inspection specified in 4.1.2.

4.4 Quality conformance inspection.

4.4.1 Sampling. Sampling for examination shall be in accordance with MIL-STD-105, inspection level III. Lot size shall not exceed 25 tanks.

4.4.2 Examination.

4.4.2.1 Individual. Each tank shall be examined for the critical defect specified in 4.5.1. Presence of a critical defect shall be cause for rejection.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

4.4.2.2 Samples. Samples selected in accordance with 4.4.1 shall be examined for the major and minor defects specified in 4.5.1. AQL shall be 0.4 percent defective for major defects and 1.0 percent defective for minor defects.

4.4.3 Tests.

4.4.3.1 Individual. Each tank shall be tested as specified in 4.5.2.1. Failure of this test shall be cause for rejection.

4.5 Examination procedure.

4.5.1 Examination. The tank shall be examined as specified herein for the following defects:

Number	Defects	Requirement Paragraph
CRITICAL		
1.	Welding cracked, broken or not fused. Burnholes, slag and oxide inclusions, undercutting or welds that are not as specified on drawings.	3.7
MAJOR		
101.	Dimensions not as specified.	3.7.3, 3.7.4, 3.7.5
102.	Material not as specified.	3.3
103.	Materials not resistant to corrosion and deterioration or not treated to be made resistant to corrosion and deterioration.	3.3.1
104.	Dissimilar metals not in accordance with MIL-STD-889.	3.3.2
105.	Material and material finish or treatment information not available.	3.3.3
106.	Rebuilt or remanufactured components incorporated into tank.	3.3.4
107.	Human factors not as specified.	3.4
108.	Treatment and painting not as specified.	3.5
109.	Paint color not as specified.	3.5
110.	Identification marking not as specified.	3.6
111.	Workmanship not as specified.	3.7
112.	Welder/Welding operator certification not available.	3.7.4
113.	Welding procedures not available.	3.7.5.1

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the current version before use.

MINOR

201.	Manhole gasket missing or not as specified.	3.1

4.5.2 Test.

4.5.2.1 Leakage. Prior to painting the tank and prior to testing, completely dry and clean the interior and exterior of the tank of all foreign matter. When the tank is completely dry and clean, close all openings such as valves and fill cap, plug the fill cap vent, and subject the tank to a constant internal air pressure of 3 to 5 pounds per square inch gage (psig). Spray liquid detergent conforming to P-D-223 over the entire exterior surface of the tank at a pressure of not less than 70 psig. Applying the liquid detergent by brush or other means shall not be acceptable. Observe the exterior of the tank. Leaks as evidenced by fizzing or bubbling of the liquid detergent, surface rupture, deformation, or broken hardware shall constitute failure of this test.

4.6 Inspection comparison. The Government may select tanks at any time during the contract production period and subject these tanks to the examination and the test specified in section 4 to determine conformance to the requirements of this specification. The inspection will be performed by the Government, at a site selected by the Government, on units selected at random from those which have been accepted by the Government and will not include the previously inspected tanks. In addition to any test specified as part of the inspection comparison, the Government reserves the right to conduct any and all other tests contained in this specification as part of the inspection comparison and failure of such additional tests shall give the same effect as failure of those tests specified as inspection comparison.

4.6.1 Inspection failure. Failure of an inspection comparison tank to meet any requirement specified herein during and as a result of the examination and tests specified in 4.5 shall be cause for rejection of the inspection comparison tank and shall be cause for refusal by the Government to continue acceptance of production tanks until evidence has been provided by the contractor that corrective action has been taken to eliminate the deficiencies. Correction of such deficiencies shall be accomplished by the contractor at no cost to the Government on tanks previously accepted and produced under the contract. Any deficiencies found as a result of the inspection comparison will be considered prima facie evidence that all tanks accepted in that lot prior to the completion of inspection comparison are similarly deficient unless evidence to the contrary is furnished by the contractor and such evidence is acceptable to the contracting officer.

4.7 Inspection of packaging.

4.7.1 First article pack inspection.

4.7.1.1 Examination. Examine the first article pack for the defects specified in 4.7.2.3. Presence of one or more defects shall be cause for rejection.

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the currentversion before use.

4.7.1.2 Test. The first article pack shall be subjected to the pendulum-impact test as specified in FED. STD. 101, method 5012. Failure of the test shall be cause for rejection of the pack.

4.7.2 Quality conformance inspection of pack.

4.7.2.1 Unit of product. For the purpose of inspection, a completed pack prepared for shipment shall be considered a unit of product.

4.7.2.2 Sampling. Sampling for examination shall be in accordance with MIL-STD-105.

4.7.2.3 Examination. Samples selected in accordance with 4.7.2.2 shall be examined for the following defects. AQL shall be 1.0 percent defective.

No.	Defect	Level A	Comm.
114.	Preservation application and selection not as specified.	5.2.1.1	5.2.2
115.	When required, interior surfaces of tank not preserved as specified.	5.2.1.2	
116.	When required, excess preservative not drained as specified.	5.2.1.2	
117.	Openings into tank not sealed with tape as specified.	5..2.1.3	
118	Drain valve control level not secured in partially open position as specified.	5.2.1.3	
119.	Repair parts not preserved as specified.	5.2.1.4	
120.	Maintenance tools not preserved and packaged as specified.	5.2.1.5	
121.	Consolidation of repair parts, tools, accessories and overpack items not as specified.	5.2.1.6	
122.	Packing not as specified.	5.3.1	5.3.2
123.	Marking illegible, incomplete, incorrect or missing.	5.4.1	5.4.2

5. PACKAGING

5.1 First article pack. The contractor shall furnish a first article pack for examination and test within the time frame specified (see 6.2), to prove prior to starting production packaging that the applied preservation, packing and marking comply with the requirements of this specification. Examination and test shall be as specified in section 4 and shall be subject to surveillance and approval by the Government (see 6.4). The first article pack may be acomplished utilizing either the first article tank or a production tank. If the first article tank is utilized, any preservation, and packing shall be removed by the contractor at no expense to the Government, when requested by the Government to facilitate comparison between the first article tank and production tanks.

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the currentversion before use.

5.2 Preservation. Preservation shall be level A or commercial, as specified (see 6.2).

5.2.1 Level A.

5.2.1.1 Preservative application and selection. The provisions of MIL-P-116 shall apply when selecting and determining the applicability of preservatives. Preservatives specified herein by "P" numbers shall conform to the applicable specifications listed in MIL-P-116 and shall be applied in accordance with MIL-P-116.

5.2.1.2 Interior surfaces. Interior surfaces of tanks requiring a contact preservative (see 5.2.1.1), shall be coated with type P10, grade 30 preservative. Excess preservative shall be drained, and all openings shall be sealed with metal or plastic caps or plugs as applicable.

5.2.1.3 Openings. Openings into the tank that would permit the entrance of water such as the vent openings and crevices around the manhole cover and drain valve control lever shall be sealed with tape conforming to PPP-T-60, type IV, class 1. Prior to sealing around the drain valve control lever, the lever shall be secured in a parstially open position. The partially open tank drain shall not be sealed.

5.2.1.4 Repair parts. The preservative application criteria and applicable method(s) of preservation of MIL-R-196 shall be used to preserve the repair parts.

5.2.1.5 Maintenance tools. Preservation and packaging shall be level A or commercial in accordance with PPP-P-40, except that MIL-STD-1188, which is referenced therein, shall be replaced by ASTM D 3951.

5.2.1.6 Consolidation. The preserved repair parts, tools, accessories, and other overpack items, for each tank shall be placed together in a box comforming to PPP-B-601, overseas type, style I. The box shall be of minimum cube and shall be designed to be located and secured within the confines of the crate specified in 5.3.1. Strapping of the box shall not be required.

5.2.2 Commercial. Each tank and its accessories, spare parts and tools shall be preserved in accordance with ASTM D 3951. Accessories, spare parts and tools shall be consolidated in a weather resistant fiberboard box.

5.3 Packing. Packing shall be level A or commercial, as specified (see 6.2).

5.3.1 Level A. The tank and tank components preserved as specified in 5.2, shall be packed in a crate conforming to MIL-C-52950, style A, type V. Blocking, bracing, anchoring, and cushioning shall be in accordance with the appendix to the crate specification. Strapping shall be zinc coated.

5.3.2 Commercial. Each tank preserved as specified in 5.2, shall be packed in accordance with ASTM D 3951. Tanks may be shipped uncrated.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

5.4 Marking.

5.4.1 Level A. Level A marking shall be in accordance with MIL-STD-129.

5.4.2 Commercial. Commercial marking shall be in accordance with ASTM D 3951. Additionally, each tank or shipping container shall be marked with the gross weight and cube.

6. NOTES

6.1 Intended use. The tank covered by this specification is intended to be mounted on a vehicle and used for storage, transportation and dispensing of liquid petroleum products. The tank may also be used for storage and dispensing on a ground location.

6.2 Ordering data. Procurement documents should specify the following:

a. Title, number and date of this specification.
b. Time frame required for submission of first article tank (see 3.2).
c. Color if other than as specified (see 3.5).
d. Time frame required for submission of preproduction pack (see 5.1).
e. Degree of preservation and degree of packing required (see 5.2 and 5.3).

6.3 First article. When a first article inspection is required, the items should be a preproduction model. The first article should consist of 2 units. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examinations, tests, and approval of the first article test results and disposition of the first article.

6.4 First article pack. Any changes or deviations of production packs from the approved first article pack will be subject to the approval of the contracting officer. Approval of the first article pack will not relieve the contractor of his obligation to preserve, pack, and mark the tanks in accordance with this specification.

6.5 Quality assurance provisions (QAP). The contracting officer should require the contractor to maintain records of all QAP inspections. A suggested paragraph is as follows:

"The contractor shall maintain complete records of all examinations and tests performed to verify the requirements of classified QAP characteristics The records shall include as a minimum, lot, size, sample size, drawing requirements, actual measurement, number and type of deficiencies found, quantity approved, quantity rejected, and corrective action taken when applicable."

6.6 Definition. A QAP is a contractual requirement that supplements section 4 of the specification. A QAP indicates the minimum requirements which must be inspected on the product drawings to verify the design objectives of the procuct and assure interchangeability of repair parts.

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the current version before use.

6.7 Subject term (key word) listing.

Low profile aluminum tank
Low profile 600 gallon aluminum tank
Tank liquid storage low profile

6.8 Changes from previous issue. Asterisks (or vertical lines) are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodians:
Army - ME

Review activities:
Army - AT
DLA - CS

Preparing activity:
Army - ME

Project 5430-0159

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-T-22238H(ME)	Tank, Liquid Storage, Metal, for Petroleum Products, Horizontal with Skids, 600-Gallon Capacity

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR ☐ USER ☐ MANUFACTURER ☐ OTHER *(Specify)*: _____
b. ADDRESS *(Street, City, State, ZIP Code)*	

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE ARMY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 12062 WASHINGTON D. C.
POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

USA Belvoir Research, Development, and
Engineering Center
ATTN: STRBE-TSE
Fort Belvoir, VA 22060-5606

Source: https://assist.dla.mil -- Downloaded: 202610-19T11:31Z
Check the source to verify that this is the current version before use.