MILITARY SPECIFICATION

TANK, LIQUID STORAGE, METAL, FOR PETROLEUM PRODUCTS, HORIZONTAL WITH SKIDS, 600-GALLON CAPACITY

This amendment forms a part of MIL-T-22238H(ME), dated 10 February 1987, and is approved for use within the USA Belvoir Research, Development, and Engineering Center, Department of the Army and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

Under title block, delete "600-GALLON CAPACITY" and substitute "500-GALLON, LOW PROFILE".

1.1, line 1, delete "600-gallon" and substitute "500-gallon, low profile".

PAGE 5

3.7.3, lines 4 and 5 after "AWS D1.2.", delete the period and add "or ASME Boiler and Pressure Vessel Code, Section IX".

3.7.4, lines 10 and 11, delete last sentence and replace with: "In the event of poor welds, the Government reserves the right to require retesting of any welder or welding operator. The test results shall be made available for review by the contracting officer or his designated representative".

3.7.5, line 2, after "AWS D1.2.", delete the period and add: "or ASME Boiler and Pressure Code, Section IX" ....and shall be. Line 3, after "designated representatives.", add: "The appropriate qualified procedures shall be available at each welding station."

Custodians:
Army - ME

Review activities:
Army - AT
DLA - CS

Preparing activity:
Army - ME

Project 5430-A198

AMSC N/A FSC 5430

DISTRIBUTION STATEMENT A. Approved for public release, distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:31Z
Check the source to verify that this is the current version before use.