FF–S–760a
AMENDMENT—2
August 26, 1966
SUPERSEDING
Int. Amendment—1
February 11, 1965

FEDERAL SPECIFICATION

STRAP, RETAINING, (METAL FOR CONDUIT, PIPE, AND CABLE)

This amendment, which forms a part of Federal Specification FF-S-760a, dated April 30, 1964, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

PAGE 1

Paragraph 2.1: Under *"Federal Standards"* delete "Fed. Std. No. 102—Preservation, Packaging and Packing Levels."

PAGE 2

Delete table I in its entirety and substitute the following:

TABLE I. *Type I, style A, dimensional requirements*

Thinwall (EMT)	Size, inches		Figure 1, dimensions, inches						
	Pipe or conduit	Cable OD	A[1]	B[2]	C[3]	D[4]	E[5]	Hole size[6]	T[7]
		3/16	3/16	0.187		11/32	7/8		
		1/4	1/4	.250		1/2	15/16		
		5/16	5/16	.312			1		
		3/8	3/8	.375	5/8	37/64	1- 1/8	7/32	
	1/8	13/32	13/32	.405			1- 1/4		
	1/4	17/32	17/32	.540		21/32	1- 5/16		
		9/16	9/16	.562		11/16			
		5/8	5/8	.625		3/4	1- 3/8		7/32
	3/8	11/16	21/32	.675	11/16	27/32	1-13/16		
1/2			21/32	.706		13/16	1- 3/4		
	1/2	27/32	27/32	.840		15/16	2- 1/16		
3/4		29/32	29/32	.922	3/4	1	2- 1/8	9/32	9/32
	3/4	1- 1/16	1- 1/32	1.050		1- 1/16	2- 7/16		
		1- 1/8	1- 1/8	1.125		1- 1/4	2-11/16		11/32
1		1- 5/32	1- 5/32	1.163	7/8	1- 5/16			
	1	1- 5/16	1- 5/16	1.315	7/8	1- 9/32	2- 3/4		5/16
1-1/4		1- 1/2	1- 1/2	1.510	7/8	1- 5/8	3- 1/4		11/32
	1-1/4	1-21/32	1-21/32	1.660	1.00	1-41/64	3- 3/8	11/32	11/32
1-1/2		1- 3/4	1- 3/4	1.740	1- 1/8	1-11/16	3- 3/4	13/32	1/2
	1-1/2	1-29/32	1-29/32	1.900		1-23/32	4		
2		2- 3/16	2- 1/8	2.197	1- 1/2	1-15/16	4- 1/8		
	2	2- 3/8	2- 3/8	2.375	1- 1/4	2- 1/4	5- 1/8	15/32	17/32
	2-1/2	2- 7/8	2- 7/8	2.875	1- 5/8	2- 3/4	6- 7/16	9/16	23/32
	3	3- 1/2	3- 1/2	3.500	1- 3/4	3- 1/16	7- 1/8	[illegible]	25/32
	3-1/2	4	4	4.000	1- 7/8	3- 1/2	8- 1/8		27/32
	4	4- 1/2	4- 1/2	4.500	2	3- 3/4	8- 3/4	21/32	29/32
	4-1/2	5	5	5.000	2- 1/8	4	9- 3/8	[illegible]	31/32
	5	5- 5/8	5- 5/8	5.563	2- 1/4	4- 1/2	10- 7/16		1- 1/32

[1] Plus nothing, minus 0.062 inch.

[2] Plus nothing, minus 0.062 inch for steel straps, and plus 0.062 inch, minus nothing for malleable iron

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:47Z
Check the source to verify that this is the current version before use.

straps.
[3] Plus or minus 0.125 inch.
[4] Plus or minus 0.062 inch.
[5] Plus or minus 0.125 inch.
[6] Plus 0.031 inch, minus 0.015 inch.
[7] Plus or minus 0.031 inch.

PAGE 3

Delete table II in its entirety and substitute the following:

TABLE II. *Type I, style B, dimensional requirements*

Size, inches		Figure 2, dimensions, inches						
Thinwall (EMT)	Pipe or conduit	Cable OD	A[1]	B[2]	C[3]	D[4]	E[5]	Hole size[6]	T1[7]
		3/16	3/16	0.187		11/23	7/8		
		1/4	1/4	.250		1/2	15/16		1/16
		5/16	5/16	.312	5/8		1		
		3/8	3/8	.375		37/64	1- 1/8	7/32	
	1/8	13/32	13/32	.405			1- 1/4		
	1/4	17/32	17/32	.540		21/32	1- 5/16		
		9/16	9/16	.562		11/16			
		5/8	5/8	.625		3/4	1- 3/8		5/64
	3/8	11/16	21/32	.675	11/16	27/32	1-13/16		
1/2			21/32	.706		13/16	1- 3/4		
	1/2	27/32	27/32	.840		15/16	2- 1/16		
3/4		29/32	29/32	.922	3/4	1	2- 1/8	9/32	
	3/4	1- 1/16	1- 1/32	1.050		1- 1/16	2- 7/16		
		1- 1/8	1- 1/8	1.125		1- 1/4	2-11/16		
1		1- 5/32	1- 5/32	1.163	7/8	1- 5/16			3/32
	1	1- 5/16	1- 5/16	1.315	7/8	1- 9/32	2- 3/4		
1-1/4		1- 1/2	1- 1/2	1.510		1- 5/8	3- 1/4		
	1-1/4	1-21/32	1-21/32	1.660	1	1-41/64	3- 3/8	11/32	
1-1/2		1- 3/4	1- 3/4	1.740	1- 1/8	1-11/16	3- 1/2		
			1- 3/4		1- 1/8	1-11/16		13/32	1/8
	1-1/2	1-29/32	1-29/32	1.900		1-23/32	4		
2		2- 3/16	2- 1/8	2.197	1- 1/2	1-15/16	4- 1/8		
	2	2- 3/8	2- 3/8	2.375	1- 1/4	2- 1/4	5- 1/8	15/32	
	2-1/2	2- 7/8	2- 7/8	2.875	1- 5/8	2- 3/4	6- 7/16	9/16	1/4
	3	3- 1/2	3- 1/2	3.500	1- 3/4	3- 1/16	7- 1/8		
	3-1/2	4	4	4.000	1- 7/8	3- 1/2	8- 1/8		
	4	4- 1/2	4- 1/2	4.500	2	3- 3/4	8- 3/4	21/32	
	4-1/2	5	5	5.000	2- 1/8	4	9- 3/8		
	5	5- 5/8	5- 5/8	5.563	2- 1/4	4- 1/2	10- 7/16		3/8

[1] Plus nothing, minus 0.062 inch.
[2] Plus nothing, minus 0.062 inch.
[3] Plus or minus 0.125 inch.
[4] Plus or minus 0.062 inch.
[5] Plus or minus 0.062 inch.
[6] Plus 0.031 inch, minus 0.015 inch.
[7] Plus or minus 0.031 inch.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:47Z
Check the source to verify that this is the current version before use.

PAGE 6

Paragraph 5: Delete parenthetical reference to "Fed. Std. No. 102".

PAGES 6 and 7

Paragraph 6.3: Delete in its entirety.

Add new paragraph 6.3 as follows:

6.3 This specification includes the requirements of MIL-S-3960.

Add a new paragraph 6.4 as follows:

6.4 **Military procurement.** Items procured under this specification for military use are to be limited to the designs covered by MS21314, MS21315, MS35140, and MS51956.

PAGE 7

MILITARY CUSTODIANS:
Army—WC
Navy—YD
Air Force—69

Review activities:
Army—WC
Navy—SH, WP, YD
Air Force—69
DSA—IS

User activities:
Army—EL, MI, MO, MU
Navy—MC

MILITARY COORDINATING ACTIVITY:
Army—WC

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:47Z
Check the source to verify that this is the current version before use.