INTERIM AMENDMENT-1
TO
FEDERAL SPECIFICATION

STRAP, RETAINING

This Interim Amendment was developed by the General Services Administration, Federal Supply Service, Washington, D. C. 20407, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized Federal agencies to use this Interim Amendment as a valid exception to Federal Specification FF-S-760a dated April 30, 1964.

Page 2, delete Table I in its entirety and substitute:

TABLE I.—*Type I, style A, dimensional requirements*

Size, inches			Figure 1, dimensions, inches						
Thinwall (EMT)	Pipe or Conduit	Cable OD	A[1]	B[2]	C[3]	D[4]	E[5]	Hole size[6]	T[7]
		3/16	3/16	.187		11/32	7/8		
		1/4	1/4	.250		1/2	15/16		
		5/16	5/16	.312			1		
		3/8	3/8	.375	5/8	37/64	1- 1/8	7/32	
	1/8	13/32	13/32	.405			1- 1/4		
	1/4	17/32	17/32	.540		21/32	1- 5/16		
		9/16	9/16	.562		11/16			
		5/8	5/8	.625		3/4	1- 3/8		7/32
	3/8	11/16	21/32	.675	11/16	27/32	1-13/16		
1/2			21/32	.706		13/16	1-3/4		
	1/2	27/32	27/32	.840		15/16	2- 1/16		
3/4		29/32	29/32	.922	3/4	1	2- 1/8	9/32	9/32
	3/4	1- 1/16	1- 1/32	1.050		1- 1/16	2- 7/16		
		1- 1/8	1- 1/8	1.125		1- 1/4	2-11/16		11/32
1		1-5/32	1-5/32	1.163	7/8	1-5/16			
	1	1- 5/16	1- 5/16	1.315	1	1- 9/32	2- 3/4		
1-1/4		1- 1/2	1- 1/2	1.500		1- 5/8	3- 1/4		
	1-1/4	1-21/32	1-21/32	1.660		1-41/64	3- 3/8	11/32	
1-1/2		1- 3/4	1- 3/4	1.738	1- 1/8	1-11/16	3-3/4	13/32	1/2
	1-1/2	1-29/32	1-29/32	1.900		1-23/32	4		
2		2-3/16	2-1/8	2.197	1-1/2	1-15/16	4-1/8		
	2	2- 3/8	2- 3/8	2.375	1- 1/4	2- 1/4	5- 1/8	15/32	17/32
	2-1/2	2- 7/8	2- 7/8	2.875	1- 5/8	2- 3/4	6- 7/16	9/16	23/32
	3	3- 1/2	3- 1/2	3.500	1- 3/4	3- 1/16	7- 1/8		25/32
	3-1/2	4	4	4.000	1- 7/8	3- 1/2	8- 1/8		27/32
	4	4- 1/2	4- 1/2	4.500	2	3- 3/4	8- 3/4	21/32	29/32
	4-1/2	5	5	5.000	2- 1/8	4	9- 3/8		31/32
	5	5- 5/8	5- 5/8	5.625	2- 1/4	4- 1/2	10- 7/16		1- 1/32

[1] Plus nothing, minus 0.062 inch
[2] Plus nothing, minus 0.062 inch for steel straps, and plus 0.062 inch, minus nothing for malleable iron straps
[3] Plus or minus 0.125 inch
[4] Plus or minus 0.062 inch
[5] Plus or minus 0.125 inch
[6] Plus 0.031 inch, minus 0.015 inch
[7] Plus or minus 0.031 inch

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:47Z
Check the source to verify that this is the current version before use.

Page 3, delete Table II in its entirety and substitute:

TABLE II.—*Type I, styles B, dimensional requirements*

Size, inches			Figure 2, dimensions, inches						
Thinwall (EMT)	Pipe or Conduit	Cable OD	A[1]	B[2]	C[3]	D[4]	E[5]	Hole size[6]	T1[7]
		3/16	3/16	.187		11/23	7/8		
		1/4	1/4	.250		1/2	15/16		
		5/16	5/16	.312	5/8		1		1/16
		3/8	3/8	.375		37/64	1- 1/8	7/32	
	1/8	13/32	13/32	.405			1- 1/4		
	1/4	17/32	17/32	.540		21/32	1- 5/16		
		9/16	9/16	.562		11/16			
		5/8	5/8	.625		3/4	1- 3/8		
	3/8	11/16	21/32	.675	11/16	27/32	1-13/16		5/64
1/2			21/32	.706		13/16	1-3/4		
	1/2	27/32	27/32	.840		15/16	2- 1/16		
3/4		29/32	29/32	.922	3/4	1	2- 1/8	9/32	
	3/4	1- 1/16	1- 1/32	1.050		1- 1/16	2- 7/16		
		1- 1/8	1- 1/8	1.125		1- 1/4	2-11/16		
1		1-5/32	1-5/32	1.163		1-5/16			3/32
	1	1- 5/16	1- 5/16	1.315	7/8	1- 9/32	2- 3/4		
1-1/4		1- 1/2	1- 1/2	1.500		1- 5/8	3- 1/4		
	1-1/4	1-21/32	1-21/32	1.660	1	1-41/64	3- 3/8	11/32	
1-1/2		1-3/4	1-3/4	1.738		1-11/16	3-1/2		
		1- 3/4	1- 3/4		1- 1/8	1-11/16		13/32	1/8
	1-1/2	1-29/32	1-29/32	1.900		1-23/32	4		
2		2-3/16	2-1/8	2.197	1-1/2	1-15/16	4-1/8		
	2	2- 3/8	2- 3/8	2.375	1- 1/4	2- 1/4	5- 1/8	15/32	
	2-1/2	2- 7/8	2- 7/8	2.875	1- 5/8	2- 3/4	6- 7/16	9/16	1/4
	3	3- 1/2	3- 1/2	3.500	1- 3/4	3- 1/16	7- 1/8		
	3-1/2	4	4	4.000	1- 7/8	3- 1/2	8- 1/8		
	4	4- 1/2	4- 1/2	4.500	2-	3- 3/4	8- 3/4	21/32	
	4-1/2	5	5	5.000	2- 1/8	4	9- 3/8		
	5	5- 5/8	5- 5/8	5.625	2- 1/4	4- 1/2	10- 7/16		3/8

[1] Plus nothing, minus 0.062 inch
[2] Plus nothing, minus 0.062 inch
[3] Plus or minus 0.125 inch
[4] Plus or minus 0.062 inch
[5] Plus or minus 0.062 inch
[6] Plus 0.031 inch, minus 0.015
[7] Plus or minus 0.031 inch

Page 7, add:

6.4 This specification includes the requirements of Military Specification MIL-S-3960.

GSA DC 65-12216

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:47Z
Check the source to verify that this is the current version before use.