MILITARY SPECIFICATION SHEET

GENERATOR SET, GASOLINE ENGINE DRIVEN, 3 KW, 28 VOLT DIRECT CURRENT, TYPE I (TACTICAL), CLASS 2 (UTILITY)

This specification is mandatory for use by all Departments and Agencies of the Department of Defense.

The complete requirements for procuring the generator set described herein shall consist of this document and the issue in effect of specification MIL-G-52732.

1. SCOPE.

1.1 Scope. This specification covers the detail requirements for mode IV, size 3 sets, model MEP-026A.

1.2 Classification.

1.2.1 Set rating. The mode IV set shall be rated 28 volts direct current (VDC).

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on the date of invitation for bids or request for proposal form a part of this specification to the extent specified herein:

SPECIFICATIONS

Military

MIL-H-52112	- Heating Torches, Equipment Winterization, Instant Lighting.
MIL-G-52732	- Generator Sets, Gasoline Engine Driven, 0.5 KW thru 10 KW, 60 Hertz, 400 Hertz and 28 Volt Direct Current, Type I (Tactical), Class 2 (Utility) General Specification for.

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

STANDARDS

Military

MS39299 - Engine, Gasoline, Air-Cooled, Industrial-Type, 4 Cycle, 6 Net Continuous HP.

DRAWINGS

ME

TA13208E6000 - Generator Set, Gasoline Engine Driven, 3 KW, 28 VDC Air Cooled, Portable, Tubular Frame, Skid Mounted.

TA13213E4430 - Winterization Kit, 3 KW, Generator Sets.

(Copies of specifications, standards, and drawings required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

3. REQUIREMENTS

3.1 Requirements shall be in accordance with MIL-G-52732, and as specified herein.

3.2 Description. The set shall be in accordance with Top Assembly TA13208E6000 and as specified herein.

3.3 Starting and operating. Servicing, adjustment, and replacement shall be as specified in table I.

3.3.1 With winterization. At ambient temperatures from minus 25° F. (minus 31.7° C.) to minus 65° F. (minus 53.9° C.), the set shall start within 15 minutes with the application of external heat from a torch conforming to MIL-H-52112, type I. The set shall meet these requirements utilizing a winterization kit in accordance with TA13213E4430.

3.4 Maximum power. The maximum power (corrected) in kilowatts of the set shall be not less than 4.5 kw when operated at rated speed, voltage, and at unity power factor.

3.5 Engine.

3.5.1 Engine design. The Government furnished engine will conform to MS39299.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the current version before use.

3.5.2 Engine temperature. Engine temperatures shall not exceed the following:

Location	Maximum Temperature	
	First 10 hours of engine operation	After 10 hours of engine operation
Sump oil	300° F. (148.9° C.)	265° F. (129.2° C.)
Cylinder head	500° F. (260° C.)	475° F. (246.1° C.)
Exhaust	1200° F. (648.9° C.)	1200° F. (648.9° C.)

Table I. Schedule of Servicing and Adjusting

All Items May Be Serviced Before Test

Item No.	Hours between service periods	Test
1	8	Any minor maintenance such as retightening and retorquing nuts, bolts and screws that can be performed without disturbing or removing adjacent components, accessories, or shrouding (except top shroud, pump, intake manifold, and exhaust system).
2	Not allowed	Any major maintenance that requires removal of other components, accessories or shrouding such as oil pans, cylinder heads and connecting rods.
3	As required	Cleaning and regapping or replacing spark plugs.
4	As required	Servicing fuel filter.
5	100	Checking compression pressures.
6	8	Checking and adding lubricating oil, as necessary.
7	8	Adjusting carburetor.
8	As required	Cleaning carburetor.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the current version before use.

Table I. Schedule of Servicing and Adjusting (continued

All Items May Be Serviced Before Test

Item No.	Hours between service periods	Test
9	8	Adjusting governor (normal speed adjustment).
10	100	Changing lubricating oil.
11	100	Changing lubricating oil filter element.
12	100	Servicing air cleaner.
13	300	Adjusting and dressing breaker points.
14	300	Adjusting ignition timing.
15	250	Valve adjustment.
16	1500	Cleaning and inspection of combustion chamber, manifolds and valves.
17	500	Replacing breaker points.
18	As required	Replacing condenser.
19	*	Gasket replacement.

* Not allowed except where component is removed for servicing.

3.5.3 Governing system.

3.5.3.1 Short term, steady-state stability (30 seconds), mode II and III sets. Not applicable for the mode IV, size 3 set.

3.5.3.2 Long term, steady-state stability (4 hours), mode II and III sets. Not applicable for the mode IV, size 3 set.

3.5.3.3 Transient performance, mode II and III sets. Not applicable for the mode IV, size 3 set.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the current version before use.

3.6 Generator.

3.6.1 Voltage unbalance, mode II and III sets. Not applicable for the mode IV, size 3 set.

3.6.2 Phase balance (voltage), mode II and III sets. Not applicable for the mode IV, size 3 set.

3.6.3 Voltage waveform, mode II and III sets. Not applicable for the mode IV, size 3 set.

3.6.4 Output voltage ripple, mode II and III sets. The output voltage ripple shall not exceed 5.5 percent of rated voltage.

3.6.5 Saturation curves. With the generator temperature stabilized at normal ambient conditions the exciter field current for rated voltage shall not exceed 0.25 ampere at no load and 0.77 ampere at rated load.

3.6.6 Voltage adjustment range. The minimum acceptable voltage adjustment range at normal ambient conditions shall be 23 to 35 volts. The minimum voltage adjustment range at extreme temperature conditions of minus 65° F. (minus 53.9° C.) and plus 125° F. (51.7° C.) shall be 5 percent above and below rated voltage.

3.6.7 Voltage regulation. The voltage regulation percentage shall not exceed 4 percent.

3.6.8 Voltage steady-state performance. The voltage steady-state stability bandwidth percentage shall not exceed 2 percent.

3.6.9 Voltage transient performance. The voltage dip percentage shall not exceed 30 percent and the voltage rise percentage shall not exceed 40 percent.

3.6.10 Phase sequence (rotation), mode II and III sets. Not applicable for the mode IV, size 3 set.

3.6.11 Generator efficiency. The generator efficiency shall not be less than 72 percent.

3.7 Circuit interrupter. The circuit interrupter shall open within 0.25 seconds under the condition of a short circuit.

Source: https://assist.dla.mil -- Downloaded: 20260-22T21:31Z
Check the source to verify that this is the current version before use.

3.8 Instruments. The inaccuracy or error of the metering system shall not exceed the following:

Instrument	Allowable Value
Ammeter (percent load)	10 percent inaccuracy
Voltmeter	3 percent inaccuracy
Speed	108 rpm error

4. QUALITY ASSURANCE PROVISIONS

4.1 Quality assurance provisions. The quality assurance provisions shall be in accordance with MIL-G-52732 and as specified herein.

4.2 Engine preventative maintenance services. The engine preventative maintenance services shall be performed as specified in table I.

4.3 Drop test (free fall). The height of the drop shall be 18 inches for the mode IV, size 3 set.

4.4 Vibration test. The handrail or shock mount resonances shall not be utilized for resonant dwell conditions.

5. PREPARATION FOR DELIVERY

5.1 Preparation for delivery. Preparation for delivery shall be in accordance with MIL-G-52732.

6. NOTES

6.1 Notes. The notes specified in MIL-G-52732 are applicable to this specification and as specified herein.

6.2 Stable operation (voltage). Stable operation is operation within a bandwidth of 2 percent of the rated voltage.

6.3 International standardization. Not applicable for the mode IV, size 3 set.

Custodians:
Army - ME
Air Force - 80
Navy - YD

Review activities:
Army - EL, MI, MU

Preparing activity:
Army - ME

Project No. 6115-0144-8

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 22-R255

INSTRUCTIONS: This sheet is to be filled out by personnel, either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments and suggestions submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or serve to amend contractual requirements.

SPECIFICATION MIL-G-[illegible] Generator Set, Gasoline Engine Driven, 3 KW, 28 Volt Direct Current, Type I (Tactical), Class 2 (Utility)

ORGANIZATION

CITY AND STATE | CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?

☐ YES ☐ NO (If "Yes", in what way?)

4. REMARKS (Attach any pertinent data which may be of use in improving this specification. If there are additional papers attach to form and place both in an envelope addressed to preparing activity.)

5. SUBMITTED BY (Printed or typed name and activity — Optional)

DD FORM 1426 REPLACES [illegible] WHICH MAY BE USED.

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE ARMY
U. A. ARMY MOBILITY EQUIPMENT COMMAND
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: AMSME-RZD
FORT BELVOIR, VIRGINIA 22060

OFFICIAL BUSINESS

POSTAGE AND FEES PAID

DEPARTMENT OF THE ARMY
U. S. ARMY MOBILITY EQUIPMENT COMMAND
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: AMSME-RZD
FORT BELVOIR, VIRGINIA 22060

FOLD

D—36.455—Ft Belvoir

Source: https://assist.dla.mil -- Downloaded: 202610-22T21:31Z
Check the source to verify that this is the currentversion before use.