RR-C-901/2
January 15, 1971
SUPERSEDING
MS39225
February 4, 1969

FEDERAL SPECIFICATION SHEET

CYLINDER, COMPRESSED GAS:

DOT SPECIFICATION 3AA

AND ALUMINUM APPLICATIONS

FOR CARBON DIOXIDE

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal Agencies.

The complete requirements for procuring compressed gas cylinders, Specification DOT 3AA described herein, shall consist of this document and the issue in effect of Specification RR-C-901.

TABLE I

Part Number	Capacity Gas lbs	Dimensions Inches Dia	H	Tare Max lbs	Valve MIL-V-2	Water Capacity cu in	Service Pressure psi
C901/2-1	15	6-1/2	26	35	FIRE	615	2015
C901/2-2	20	6-3/4	29	45	V15-321	855	2015
C901/2-3	20	6-3/4	29	45	PLUG	855	2015
C901/2-4	35	8-1/2	35	80	FIRE	1500	2015
C901/2-5	55	8-1/2	51	108	V15-321	2320	2015
C901/2-6	55	8-1/2	51	108	FIRE	2320	2015
C901/2-7	55	8-1/2	51	108	PLUG	2320	2015

1. Cylinders with Dash Numbers 1, 4, and 6 shall be used for fire extinguisher applications and each shall be fabricated without a neck flange. The neck shall be drilled and tapped 1-11-1/2 NGT for fire extinguisher application. Cylinders with Dash Numbers 2, 3, 5 and 7 shall be used for general carbon dioxide service and shall be supplied with neck flange and cap, and drilled and tapped 3/4-14 NGT. When valves are not specified the cylinder, while hot from drying, shall be plugged for preservation.

FSC 8120

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.

DESIGN REQUIREMENTS:

1. The cylinder shall be as specified in table I. All dimensions are in inches with tolerances for diameter plus or minus 1/4 inch and for height plus or minus 1 inch.
2. When aluminum cylinders are specified they shall conform to the issue of RR-C-901 in effect.
3. Cylinders for carbon dioxide service shall be color coded and stenciled in accordance with MIL-STD-101. Cylinders required for fire extinguisher applications shall be treated, primed, and finish coated with fire protection red.

INTENDED USE:

The cylinders in this specification sheet are intended for carbon dioxide, for general service, beverage carbonation, and for fire extinguisher applications.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.




FIGURE 1. Cylinder configuration.

X-3178A

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians:

Army - ME
Navy - SH
Air Force - 68

Review activities:

Army - MI, EA
Navy - MS, AS, OS

User activities:

Navy - YD, MC
DLA - GS, PS

Civil Agency Coordinating Activities.

GSA-FSS
DOT-OHM
HEW-NIH
JUS-FPI
VA-DMS

Preparing activity:

Army - ME

Project No. 8120-0369

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Document. See section 2 of this specification to obtain extra copies and other documents referenced herein.

Source: https://assist.dla.mil Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval No 22-R755

INSTRUCTIONS The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost at minimum delay or will otherwise enhance use of the document DoD contractors, government activities or manufacturers' vendors who are prospective suppliers of the product are invited to submit comments to the government Fold on lines on reverse side staple in corner and send to preparing activity Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements Attach any pertinent data which may be of use in improving this document If there are additional papers, attach to form and place both in an envelope addressed to preparing activity

DOCUMENT IDENTIFIER AND TITLE RR-C-901/2 Cylinder, Compressed Gas: DOT Specification 3AA and Aluminum Applications for Carbon Dioxide

NAME OF ORGANIZATION AND ADDRESS	CONTRACT NUMBER
	MATERIAL PROCURED UNDER A ☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1 HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A GIVE PARAGRAPH NUMBER AND WORDING

B RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2 COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3 IS THE DOCUMENT RESTRICTIVE?

☐ YES ☐ NO (If "Yes" in what way?)

4 REMARKS

SUBMITTED BY (Printed or typed name and address - Optional)	TELEPHONE NO
	DATE

DD FORM 1 JAN 72 1426 REPLACES EDITION OF 1 JAN 68 WHICH MAY BE USED

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.

FOLD

POSTAGE AND FEES PAID
DEPARTMENT OF THE ARMY
DOD – 314

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

Commander
US Army Mobility Equipment Research and
Development Command
DRDME-DE/DS
Fort Belvoir, VA 22060

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:11Z
Check the source to verify that this is the current version before use.