INCH-POUND

MIL-C-24643/18C
14 March 1994
SUPERSEDING
MIL-C-24643/18B
3 October 1986

MILITARY SPECIFICATION SHEET

CABLE, ELECTRICAL, 1000 VOLTS, TYPE LSMSCU (INCLUDING VARIATION LSMSCA AND LSMSCS)

This specification is approved for the use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and the issue of the following specification listed in that issue of the Department of Defense Index of Specifications and Standards (DODISS) specified in the solicitation: MIL-C-24643.

This cable can be manufactured in three variations: LSMSCU (unarmored), LSMSCA (armored) and LSMSCS (double overall shield).

REQUIREMENTS:

Qualification required.

Construction (watertight with circuit integrity)

First - Copper conductor, uncoated, AWG size 18, class B stranding.

* Second - Extruded Silicone rubber insulation. Minimum average wall thickness of 0.018 inch. Diameter insulation 0.084 inch minimum.

* Third - Glass braid, providing 80% coverage.

Fourth - Braid covering (see table I for diameter). Standard identification code applied by method 1. Diameter over braid covering 0.113 inch maximum.

* Fifth - The required number of conductors (see table I) cabled together with a lay not greater than 24 times the pitch diameter of the layer, except the lay of the two outer layers for sizes 44, 61 and 91 shall not exceed 18 times the pitch diameter of the layer. Fillers shall be used as necessary to form a firm, well rounded assembly. Cabling sequence shall be consecutive, starting with No. 1, from the center outward.

Sixth - Binder or combination binder and barrier.

AMSC N/A FSC 6145

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:00Z
Check the source to verify that this is the current version before use.

Construction (watertight with circuit integrity) (continued)

Construction variant type LSMSCU

* Seventh - Cross-linked polyolefin jacket. (see table I for thickness).

Construction variant type LSMSCA

* Seventh - Cross-linked polyolefin jacket. (see table I for thickness).
* Eighth - Braided metal armor.

Construction variant type LSMSCS

Seventh - Braided shield of tin coated copper. Minimum coverage of 85 percent.
Eighth - Spirally wrapped 0.002 inch thick polyethylene terephthalate (mylar) separator tape with 25 percent minimum overlap.
Ninth - Braided shield of tin coated copper. Minimum coverage of 85 percent.
Tenth - Binder tape applied helically with overlap.
* Eleventh - Cross-linked polyolefin jacket. (see table I for thickness).

TABLE I. Details

Military 1/ part no. M24643/18	Size 2/	No. of conductors	Jacket thickness min avg (in.)	Dia over Shielded core (in. nom)	Overall diameter (inches)					
					TYPE LSMSCU		TYPE LSMSCA		TYPE LSMSCS	
					min	max	min	max	min	max
-01UN	7	7	0.040	0.409	0.447	0.484	0.497	0.534	0.507	0.544
-02UN	10	10	.050	.497	.575	.622	.625	.672	.635	.682
-03UN	14	14	.050	.563	.617	.668	.667	.718	.677	.728
-04UN	19	19	.050	.631	.682	.738	.732	.788	.742	.798
-05UN	24	24	.050	.738	.790	.855	.840	.905	.850	.915
-06UN	30	30	.050	.788	.833	.901	.883	.951	.893	.961
-07UN	37	37	.060	.855	.926	1.002	.976	1.055	.986	1.065
-08UN	44	44	.060	.950	1.030	1.114	1.080	1.164	1.090	1.174
-09UN	61	61	.060	1.080	1.156	1.250	1.206	1.300	1.216	1.310
-10UN	91	91	.060	1.294	1.369	1.480	1.419	1.530	1.429	1.540

1/ Unarmored. When armor option or double shield is required, see MIL-C-24643 for configuration of part number.
2/ Type LSMSCU, LSMSCA and LSMSCS.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:00Z
Check the source to verify that this is the current version before use.

EXAMINATION AND TESTS:

Basic electrical:	Requirements
Conductor Resistance - ohms/1000 feet at 25°C, maximum	7.07
Voltage withstand - volts, root mean square, minimum	
Conductor to conductor	3000
* Shield to shield (LSMSCS only, overall shields only)	200
Insulation resistance, Megohms/1000 feet minimum	
conductor to conductor	500
* shield to shield (LSMSCS, overall shield only)	100
* Jacket flaws (LSMSCS only)	No failure
* Conductor and shield continuity	No failure
Group A:	
Visual and dimensional	No failure
Watertightness - see MIL-C-24643 for limits of water leakage	No failure
Abrasion resistance - minimum	250
Crack resistance -	No damage
Group B:	
Cross-linked proof test (percent maximum)	
Insulation	50
Jacket (When tested at 200°C)	50
Glass Flame 3/ - 1 hour	No failure
Drip - 95 ± 1°C	Zero
Tear - pounds per inch thickness, minimum (ASTM D 470)	35
Cold bending, cable - maximum mandrel diameter, 12 times cable diameter	No damage
Physicals (unaged)	
Insulation	
Tensile strength - lb/in^2, minimum	750
Elongation - percent, minimum	125
Jacket (cable)	
Tensile strength - lb/in^2, minimum	1300
Elongation - percent, minimum	160
Group C:	
Physicals (aged)	
Jacket (cable)	
Air oven	
Tensile strength - percent of unaged, minimum	60
Elongation - percent of unaged minimum	60
Hot oil immersion	
* Tensile strength - percent of unaged, minimum	50
* Elongation - percent of unaged, minimum	50

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:00Z
Check the source to verify that this is the current version before use.

EXAMINATION AND TESTS (continued):	Requirements
Shrinkage	No failure
Heat distortion - percent of unaged, maximum	30
* Permanence of printing (conductor) - cycles, minimum	25
* Permanence of printing (jacket) - (types LSMSCU and LSMSCS) cycles, minimum	125
* Cable sealant removability	No failure
Armor (type LSMSCA ONLY) - conformance to material, construction and coverage	No failure
Shield (type LSMSCA only) - conformance to material, construction and coverage	No failure
Surface transfer impedance (type LSMSCS only)	
* Milliohms per meter, maximum	700
EMP response, db, minimum	60

Group D:

* Flame propagation (cable)	No failure

QUALIFICATION INSPECTION:

* Qualification inspection shall include basic electrical, all of groups A, B, C and D, plus the following:

	Requirements
Cold working (minus 20 ± 2°C)	No damage
Gas flame (3 hours)	No failure
Specific gravity of extruded silicone insulation, maximum	1.55
Aging and compatibility (cable) (125± 5°C)	No failure
Abrasion resistance (jacket) - scrapes, minimum	75
Acid gas equivalent - percent, maximum	
Jacket	2
Fillers	2
Insulation	18
Halogen content - percent, maximum	
Jacket	0.2
Fillers	0.2
Immersion (jacket)	
Tensile strength - percent of unaged, minimum	50
Elongation - percent of unaged, minimum	50
Smoke index, maximum	
Jacket	25
* Fillers	45
Insulation	35
Toxicity index, maximum	
Jacket	5
Fillers	5
Insulation	1.5
Durometer (jacket) - (type A) hardness, minimum	80
Weathering (jacket)	No failure

3/ Type LSMSCS only. Shields shall not be grounded during test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:00Z
Check the source to verify that this is the current version before use.

UNIT ORDERING LENGTHS:

Type and Size	Feet (nominal)
LSMSCU-7, LSMSCA-7, LSMSCS-7	1500
LSMSCU-10, LSMSCA-10, LSMSCS-10	1500
All others	1000

NOTE: The margins of this specification are marked with asterisks to indicate where changes (additions, modifications, corrections, deletions) from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Custodians:
Army - MI
Navy - SH

Review Activities:
Army - AV, CR, ER, ME, AR, AL
Navy - EC, CG
DLA - IS

Preparing Activity:
Navy - SH

Agent:
DLA-IS

(Project No. 6145-2057-18)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:00Z
Check the source to verify that this is the current version before use.