A-A-603
November 14, 1979

# COMMERCIAL ITEM DESCRIPTION

## DETECTOR, NATURAL AND PROPANE GAS LEAK ALARM, AC POWERED

The General Services Administration has authorized the use of this commercial item description.

Salient characteristics:

Mode of operation - Sounds audible alarm when natural gas or propane gas exceeds density limits.

Natural gas density limit - 0.5 percent.

Propane gas density limit - 1.0 percent.

Circuitry - Solid state throughout.

Alarm operation - 85-dBA continuous alarm.

Power - 120-VAC.

Line frequency - 60 Hz.

Sensor validation - Signal warns if sensor circuit fails.

Mounting - Wall mount direct to standard electrical box (hardware included).

Dectector types

| Model | Type | Power connection |
|---|---|---|
| A | Built in | Pigtails |
| B | Plug in | Line cord |

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices and is the same product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Recovered materials. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. The gas leak detector/alarm shall be packaged in accordance with normal commercial practice and packed in fiberboard boxes that will assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping containers shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Marking shall be as specified in the contract or order.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:09Z
Check the source to verify that this is the current version before use.