A-A-1534A
February 23, 1982
SUPERSEDING
A-A-1534
April 22, 1981

COMMERCIAL ITEM DESCRIPTION

FIXTURE, LIGHTING (FLUORESCENT, INDUSTRIAL)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification W-F-1234, type I.

This description covers industrial fluorescent lighting fixtures for use on either 120 V or 277 V, 60 Hz current.

Salient characteristics:

The fixture shall be an individually mounted, open-end reflector.
The fixture shall reflect 85 to 92 percent of the light downward.
The reflective surfaces shall be white and have a minimum reflectance of 86 percent.
Ballasts shall have the UL listing mark, class P, ETL certified and have a nonpolychlorinated biphenyl (PCB) insulating fluid.
Ballasts shall be rapid start with a high power factor.
Ballasts, sockets, all electrical wiring and components shall be replaceable without removing fixture.
The ballasts for two 40 watt F40T12/RS lamps shall not exceed 90 input watts when tested in accordance with ANSI Standard No. C82.2.
Ballasts shall be held firmly in contact with the metal of the fixture.
The fixture shall have a 6-foot electric cable assembly, 18 gage, 3 conductor with an electrical plug in accordance with NEMA WD-1 configuration 5-15P.
Lamps shall not be furnished.
The fixture shall be furnished with a 10-inch central suspension without mounting hardware.
All surfaces shall be finished, except for cut edges.
The fixture shall have the UL listing mark in accordance with UL Standard No. 1570, and be of the type indicated in the following table.

Fixture types

Type	Lamp No.	Volts
1	2F40T12	120
2	2F40T12	277
3	3F40T12	120
4	3F40T12	277
5	4F40T12	120
6	4F40T12	277

Workmanship. The fixture shall have no defect that affects serviceability or appearance.

The issues of NEMA WD-1, ANSI C82.2, and UL 1570 in effect on the date of the solicication shall be used to determine compliance with these requirements.

Regulatory requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

Packaging, packing, and marking. Packaging, packing, and marking shall be as specified in the contract or order.

UL Standard No. 1570 is available from Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062.

ANSI Standard C82.2 is available from the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.

FSC 6210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:14Z
Check the source to verify that this is the current version before use.

NEMA Standard WD-1 is available from National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.

MILITARY INTERESTS:

Custodians

Army - ME
Air Force - 99

Review Activity

Army - ME

CIVIL AGENCY COORDINATING ACTIVITY:

COMMERCE - NBS

PREPARING ACTIVITY:

GSA - FSS

GSA DC-01202212

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:14Z
Check the source to verify that this is the current version before use.