A-A-1922
May 2, 1983

COMMERCIAL ITEM DESCRIPTION

SHIELD, EXPANSION
(CAULKING ANCHORS, SINGLE LEAD)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification FF-S-325.

This description covers single lead caulking anchors for attaching equipment and fixtures to the existing solid masonry.

Salient characteristics:

General

Shall consist of an internally threaded conical expander and/or expansion lead sleeve which is slipped over the expander.

Screw threads for expansion sleeves shall be UNC 2B coarse thread series.

Shall be designated by the screw number or bolt diameter and the number of threads per inch.

Overall dimensions shall be as specified in table I.

Shall withstand pullout proof test loads when set in concrete as specified in table I.

TABLE I

Size			Anchor Dimensions		
Screw No.	Screw or Bolt Diameter	Threads Per inch	Outside Diameter (inch) (minimum)	Assembled Height with an expander (inch) (minimum)	Proof test load[1] (Lbs.) (minimum)
6	0.138	32	1/4	3/8	150
8	.164	32	5/16	1/2	250
10	.190	24	3/8	5/8	300
12	.216	24	7/16	3/4	400
	1/4	20	1/2	3/4	500
	5/16	18	5/8	1	850
	3/8	16	3/4	1-1/4	1,250
	7/16	14	7/8	1-1/2	1,650
	1/2	13	7/8	1-1/2	2,300
	5/8	11	1	1-3/4	3,700
	3/4	10	1-1/4	2	5,500

Expanders

Shall have a conical shape that shall assure proper expansion of the lead sleeves when caulking or tamping them in masonry.

Shall be provided with means (fins, ribs, tongues, knurls, corrogations, etc.) for preventing their rotation when tightening the bolt.

May be of brass, malleable iron, steel or hard zinc alloy.

Shall have no less than five screwthreads.

Expansion sleeves

Shall be of lead or lead alloy, hollow cast with a seat to fit the expanders.

Outer walls shall be either straight cylindrical or tapered with or without horizontal corrugations.

May be capped by a spherical steel washer having scalloped edges which embed into the masonry when tamping the anchor into place.

FSC 5340

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:18Z
Check the source to verify that this is the current version before use.

Test. Shall withstand minimum proof test loads specified in table I when installed with the applicable carbide tipped masonry drill of ANSI B 94.12 and tested in accordance with the tension test of ANSI/ASTM E 488. There shall be no evidence of failure when performing the tension test at -40° and +170° F.

Workmanship. The shields shall be free from defects such as rust, scale, fins, or any other defect which affects their use and serviceability.

The issues of ANSI B 94.12 and ANSI/ASTM E 488 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Note. Purchaser should specify screw number or bolt diameter and the number of threads per inch.

ASTM standards are available from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.

ANSI standards are available from the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018.

MILITARY INTERESTS:

Coordinating Activity

Army - AR

Custodians

Army - AR
Navy - YD
Air Force - 99

PREPARING ACTIVITY:

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:18Z
Check the source to verify that this is the current version before use.