A-A-1860A
August 28, 1984
SUPERSEDING
A-A-1860
June 12, 1981

COMMERCIAL ITEM DESCRIPTION

LAMP, FLUORESCENT
(F96T12/CW ENERGY SAVING)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification W-L-00116/GEN and W-L-00116/51.

This commercial item description covers 60 watt, instant-start types, energy-saving fluorescent lamps at 425 ma operation.

Salient characteristics.

Bulb - T-12
Nominal length - 96 inches
Base - Single pin
Average rated life - 3 hours per start - 12,000 hours
Initial lumens (after 100 hours burning) - 5300 lumens
Lumens at 40 percent of life - 4800 lumens
Color - Cool white when tested in accordance with ANSI C78.376
Designed to operate on one- or two-lamp lead-circuit, high power factor, instant-start indoor ballast that meet ANSI C82 and UL 935 requirements, and in ambient temperature of not less than 18 degrees C (65 degrees F)
Dimensional characteristics shall be in accordance with ANSI C78.3.

The issues of ANSI C78.3, ANSI C78.376, ANSI C82, and UL Standard 935 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Regulatory requirements. The offeror/contractor is encouraged to use recovered material in accordance with Public Law 94-580 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preproduction inspection. One package of lamps, produced using the same tooling, production and assembly methods that are used for prodcution lots, shall be submitted for examination and test in accordance with the above requirements. Documentation consisting of the certification and test data shall be presented for examination during performance of the preproduction inspection. Failure of the preproduction samples to pass the examination of one or more of the tests, the lack of required documentation, or failure of the documentation to substantiate conformance to the requirements of this CID shall be cause for rejection.

Notes. Copies of ANSI standard are available from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

UL Standard No. 935 is available from Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:17Z
Check the source to verify that this is the current version before use.

The commercial item certification clause is not required when this commercial item description is used for procurement.

Military Coordinating Activity
None. DoD has waived coordination on this commercial item description until further notice.

CIVIL AGENCY COORDINATING ACTIVITY:

COMMERCE-NBS

PREPARING ACTIVITY

GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:17Z
Check the source to verify that this is the current version before use.