A-A-606A
May 20, 1981
SUPERSEDING
A-A-606
December 9, 1979

COMMERCIAL ITEM DESCRIPTION

CHARGER, BATTERY
(THREE PHASE, FOR CHARGING 6-CELL INDUSTRIAL STORAGE BATTERIES)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification W-C-260.

This commercial item description covers battery chargers for charging portable lead acid batteries in cycle service such as forklift trucks and other materials handling equipment.

Salient characteristics:

Solid state circuitry
Full wave rectification with minimum three a.c. voltage taps
Reverse polarity and surge voltage protected (output voltage held to ± 1.0 percent for ± 10 percent a.c. voltage variation)
Alternating current and direct current overload protected with fail safe operation (failure of any component will not result in damage to the battery due to overcharging or overheating)
60 Hz a.c.
Scaled ammeter
Indicator light
Automatic timer with charge termination
Automatic taper and equalizing charger
Furnished with 10-foot d.c. leads and any Anderson SB, EC, YC, or Russell & Stoll 31000 and 31010 charging connector
Diodes, transformers, and capacitors conforming to industry standards
Conduit connected
UL listing and markings, including identifying, rating, and cautionary, in accordance with UL Standard No. 1236

The issue of UL Standard No. 1236 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Industrial battery charger - 6 cells, three phase

Model	8-Hour charging range at ampere hours
A	100 - 200
B	201 - 300
C	301 - 380
D	381 - 450
E	451 - 550
F	551 - 600
G	601 - 680
H	681 - 775
I	776 - 850
J	851 - 935
K	936 - 1,050
L	1,051 - 1,200
M	1,201 - 1,400

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards, and quality assurance practices, and is the same product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Regulatory requirements. The manufacturer shall utilize recovered materials to the maximum extent practicable.

FSC 6130

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:09Z
Check the source to verify that this is the current version before use.

1.8 [illegible] bonding and grounding. (See 4.8.1) The equipment shall be designed and

Packaging, packing, and marking. The items shall be packaged in accordance with normal commercial practice and packed to assure acceptance by common carrier and provide product protection against loss and damage during multiple shipments, handling, and storage. The shipping containers shall be in compliance with the National Motor Freight Classification and Uniform Freight Classification. Shipping containers shall be marked as specified in the contract or order.

UL Standard No. 1236 is available from Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.

Preparing activity:

GSA-FSS

GSA DC-01104220

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:09Z
Check the source to verify that this is the current version before use.